



European Network of
Transmission System Operators
for Electricity

ASSESSED ELEMENT PROFILE SPECIFICATION

2022-09-21

SOC APPROVED
VERSION 2.1

1 Copyright notice:

2 **Copyright © ENTSO-E. All Rights Reserved.**

3 This document and its whole translations may be copied and furnished to others, and derivative
4 works that comment on or otherwise explain it or assist in its implementation may be prepared,
5 copied, published and distributed, in whole or in part, without restriction of any kind, provided
6 that the above copyright notice and this paragraph are included on all such copies and
7 derivative works. However, this document itself may not be modified in any way, except for
8 literal and whole translation into languages other than English and under all circumstances, the
9 copyright notice or references to ENTSO-E may not be removed.

10 This document and the information contained herein is provided on an "as is" basis.

11 **ENTSO-E DISCLAIMS ALL WARRANTIES, EXPRESS OR IMPLIED, INCLUDING BUT NOT**
12 **LIMITED TO ANY WARRANTY THAT THE USE OF THE INFORMATION HEREIN WILL NOT**
13 **INFRINGE ANY RIGHTS OR ANY IMPLIED WARRANTIES OF MERCHANTABILITY OR**
14 **FITNESS FOR A PARTICULAR PURPOSE.**

15 **This document is maintained by the ENTSO-E CIM EG. Comments or remarks are to be**
16 **provided at cim@entsoe.eu**

17 **NOTE CONCERNING WORDING USED IN THIS DOCUMENT**

18 The force of the following words is modified by the requirement level of the document in which
19 they are used.

- 20 • **SHALL:** This word, or the terms "REQUIRED" or "MUST", means that the definition is an
21 absolute requirement of the specification.
- 22 • **SHALL NOT:** This phrase, or the phrase "MUST NOT", means that the definition is an
23 absolute prohibition of the specification.
- 24 • **SHOULD:** This word, or the adjective "RECOMMENDED", means that there may exist valid
25 reasons in particular circumstances to ignore a particular item, but the full implications must
26 be understood and carefully weighed before choosing a different course.
- 27 • **SHOULD NOT:** This phrase, or the phrase "NOT RECOMMENDED", means that there may
28 exist valid reasons in particular circumstances when the particular behaviour is acceptable
29 or even useful, but the full implications should be understood and the case carefully weighed
30 before implementing any behaviour described with this label.
- 31 • **MAY:** This word, or the adjective "OPTIONAL", means that an item is truly optional.

32

33

Revision History

Version	Release	Date	Paragraph	Comments
1	0	2021-03-22		Document for SOC approval.
2	0	2021-10-12		For CIM EG review. Additional associations added to Region, OverlappingZone and PowerSystemCorridor.
2	0	2022-02-16		Additional associations added to Region, OverlappingZone and PowerSystemCorridor. SOC approved
2	1	2022-09-21		SOC approved.

34	CONTENTS		
35	Copyright notice:.....		2
36	Revision History.....		3
37	CONTENTS		4
38	1 Introduction		6
39	2 Application profile specification		6
40	2.1 Version information		6
41	2.2 Constraints naming convention		6
42	2.3 Profile constraints		7
43	2.4 Metadata.....		9
44	2.4.1 Constraints		9
45	2.4.2 Reference metadata		10
46	3 Detailed Profile Specification		10
47	3.1 General.....		10
48	3.2 (NC) AssessedElement		11
49	3.3 (NC) AssessedElementWithContingency		12
50	3.4 (NC) AssessedElementWithRemedialAction		13
51	3.5 (abstract) ConductingEquipment root class		13
52	3.6 (abstract) Contingency		13
53	3.7 (abstract) IdentifiedObject root class		14
54	3.8 (abstract,NC) PowerTransferCorridor root class		14
55	3.9 (abstract,NC) Region root class		14
56	3.10 (abstract,NC) RemedialAction		14
57	3.11 (abstract,NC) SystemOperator root class		14
58	3.12 (abstract) Terminal root class.....		15
59	3.13 Boolean primitive		15
60	3.14 Date primitive.....		15
61	3.15 DateTime primitive		15
62	3.16 String primitive.....		15
63	Annex A (informative): Sample data		16
64	A.1 General.....		16
65	A.2 Sample instance data.....		16
66			
67	List of figures		
68	Figure 1 – Class diagram AssessedElementProfile::AssessedElementProfile		10
69	Figure 2 – Class diagram AssessedElementProfile::AssessedElementDatatypes		11
70			
71	List of tables		
72	Table 1 – Attributes of AssessedElementProfile::AssessedElement		11
73	Table 2 – Association ends of AssessedElementProfile::AssessedElement with other		
74	classes		12
75	Table 3 – Attributes of AssessedElementProfile::AssessedElementWithContingency		12

76 Table 4 – Association ends of
77 AssessedElementProfile::AssessedElementWithContingency with other classes 13
78 Table 5 – Attributes of AssessedElementProfile::AssessedElementWithRemedialAction 13
79 Table 6 – Association ends of
80 AssessedElementProfile::AssessedElementWithRemedialAction with other classes 13
81 Table 7 – Attributes of AssessedElementProfile::Contingency 13
82 Table 8 – Attributes of AssessedElementProfile::IdentifiedObject..... 14
83 Table 9 – Attributes of AssessedElementProfile::RemedialAction 14
84

85 1 Introduction

86 The assessed element profile is a profile to exchange a list of assessed elements.

87 An assessed element is a network element for which the electrical state is evaluated in a
88 regional or cross-regional process and which value is expected to fulfil regional rules function
89 of the operational security limits.¹

90 The assessed elements are input data describing the elements that shall be assessed during
91 the security analysis.

92 These are the elements on which limit violations are potentially detected (scanned assessed
93 elements) and resolved (secured assessed elements) by applying defined and agreed remedial
94 actions. Assessed elements can be a conducting equipment e.g. a line, transformer, breaker,
95 etc or just a terminal i.e. the end of the equipment. In cases where an assessed element is
96 associated with a conducting equipment the whole equipment is scanned meaning limits defined
97 at all sides of the equipment are scanned. In cases where an assessed element is associated
98 with a terminal only the limits defined for this terminal are scanned. In addition, it shall be noted
99 that only elements from an IGM that are designated as assessed elements are scanned. This
100 means that the party performing the analysis will normally not report, optimise or resolve any
101 limit violations for elements that are not designated as assessed elements. This is designed in
102 this way in order to provide more flexibility to the remedial action optimisation engines
103 eventually helping to minimise computational effort and increase performance.

104 2 Application profile specification

105 2.1 Version information

106 The content is generated from UML model file CIM100_CGMES31v01_501-
107 20v02_NC21v47_MM10v01.eap.

108 This edition is based on the IEC 61970 UML version 'IEC61970CIM17v40', dated '2020-08-24'.

- 109 - Title: Assessed Element Vocabulary
- 110 - Keyword: AE
- 111 - Description: This vocabulary is describing the assessed element profile.
- 112 - Version IRI: <http://entsoe.eu/ns/CIM/AssessedElement-EU/2.1>
- 113 - Version info: 2.1.0
- 114 - Prior version: <http://entsoe.eu/ns/CIM/AssessedElement-EU/2.0>
- 115 - Conforms to: urn:iso:std:iec:61970-600-2:ed-1|urn:iso:std:iec:61970-301:ed-
116 7:amd1|file://iec61970cim17v40_iec61968cim13v13a_iec62325cim03v17a.eap|urn:iso:
117 std:iec:61970-401:draft:ed-1|urn:iso:std:iec:61970-501:draft:ed-2|file://CGMES-
118 30v25_501-20v01.eap
- 119 - Identifier: urn:uuid:a2de1738-214d-4552-b894-5b33cbc34218

120

121 2.2 Constraints naming convention

122 The naming of the rules shall not be used for machine processing. The rule names are just a
123 string. The naming convention of the constraints is as follows.

124 "{rule.Type}:{rule.Standard}:{rule.Profile}:{rule.Property}:{rule.Name}"

¹ [SOURCE: 2019 Inter-RSC report, BRS CAS consistency function, 4.1]

125 where

126 rule.Type: C – for constraint; R – for requirement

127 rule.Standard: the number of the standard e.g. 301 for 61970-301, 456 for 61970-456, 13 for
128 61968-13. 61970-600 specific constraints refer to 600 although they are related to one or
129 combination of the 61970-450 series profiles. For NC profiles, NC is used.

130 rule.Profile: the abbreviation of the profile, e.g. TP for Topology profile. If set to “ALL” the
131 constraint is applicable to all IEC 61970-600 profiles.

132 rule.Property: for UML classes, the name of the class, for attributes and associations, the name
133 of the class and attribute or association end, e.g. EnergyConsumer, IdentifiedObject.name, etc.
134 If set to “NA” the property is not applicable to a specific UML element.

135 rule.Name: the name of the rule. It is unique for the same property.

136 Example: C:600:ALL:IdentifiedObject.name:stringLength

137 2.3 Profile constraints

138 This clause defines requirements and constraints that shall be fulfilled by applications that
139 conform to this document.

140 This document is the master for rules and constraints tagged "NC". For the sake of self-
141 containment, the list below also includes a copy of the relevant rules from IEC 61970-452,
142 tagged "452".

- 143 • C:452:ALL:NA:datatypes

144 According to 61970-501, datatypes are not exchanged in the instance data. The
145 UnitMultiplier is 1 in cases none value is specified in the profile.

- 146 • R:452:ALL:NA:exchange

147 Optional and required attributes and associations must be imported and exported if they
148 are in the model file prior to import.

- 149 • R:452:ALL:NA:exchange1

150 If an optional attribute does not exist in the imported file, it does not have to be exported
151 in case exactly the same data set is exported, i.e. the tool is not obliged to automatically
152 provide this attribute. If the export is resulting from an action by the user performed after
153 the import, e.g. data processing or model update the export can contain optional
154 attributes.

- 155 • R:452:ALL:NA:exchange2

156 In most of the profiles the selection of optional and required attributes is made so as to
157 ensure a minimum set of required attributes without which the exchange does not fulfil
158 its basic purpose. Business processes governing different exchanges can require
159 mandatory exchange of certain optional attributes or associations. Optional and required
160 attributes and associations shall therefore be supported by applications which claim
161 conformance with certain functionalities of the IEC 61970-452. This provides flexibility
162 for the business processes to adapt to different business requirements and base the
163 exchanges on IEC 61970-452 compliant applications.

- 164 • R:452:ALL:NA:exchange3

- 165 An exporter may, at his or her discretion, produce a serialization containing additional
166 class data described by the CIM Schema but not required by this document provided
167 these data adhere to the conventions established in Clause 5.
- 168 • R:452:ALL:NA:exchange4
- 169 From the standpoint of the model import used by a data recipient, the document
170 describes a subset of the CIM that importing software shall be able to interpret in order
171 to import exported models. Data providers are free to exceed the minimum requirements
172 described herein as long as their resulting data files are compliant with the CIM Schema
173 and the conventions established in Clause 5. The document, therefore, describes
174 additional classes and class data that, although not required, exporters will, in all
175 likelihood, choose to include in their data files. The additional classes and data are
176 labelled as required (cardinality 1..1) or as optional (cardinality 0..1) to distinguish them
177 from their required counterparts. Please note, however, that data importers could
178 potentially receive data containing instances of any and all classes described by the
179 CIM Schema.
- 180 • R:452:ALL:NA:cardinality
- 181 The cardinality defined in the CIM model shall be followed, unless a more restrictive
182 cardinality is explicitly defined in this document. For instance, the cardinality on the
183 association between VoltageLevel and BaseVoltage indicates that a VoltageLevel shall
184 be associated with one and only one BaseVoltage, but a BaseVoltage can be associated
185 with zero to many VoltageLevels.
- 186 • R:452:ALL:NA:associations
- 187 Associations between classes referenced in this document and classes not referenced
188 here are not required regardless of cardinality.
- 189 • R:452:ALL:IdentifiedObject.name:rule
- 190 The attribute “name” inherited by many classes from the abstract class IdentifiedObject
191 is not required to be unique. It must be a human readable identifier without additional
192 embedded information that would need to be parsed. The attribute is used for purposes
193 such as User Interface and data exchange debugging. The MRID defined in the data
194 exchange format is the only unique and persistent identifier used for this data exchange.
195 The attribute IdentifiedObject.name is, however, always required for CoreEquipment
196 profile and Short Circuit profile.
- 197 • R:452:ALL:IdentifiedObject.description:rule
- 198 The attribute “description” inherited by many classes from the abstract class
199 IdentifiedObject must contain human readable text without additional embedded
200 information that would need to be parsed.
- 201 • R:452:ALL:NA:uniqueIdentifier
- 202 All IdentifiedObject-s shall have a persistent and globally unique identifier (Master
203 Resource Identifier - mRID).
- 204 • R:452:ALL:NA:unitMultiplier
- 205 For exchange of attributes defined using CIM Data Types (ActivePower, Susceptance,
206 etc.) a unit multiplier of 1 is used if the UnitMultiplier specified in this document is “none”.
- 207 • C:452:ALL:IdentifiedObject.name:stringLength

- 208 The string IdentifiedObject.name has a maximum of 128 characters.
- 209 • C:452:ALL:IdentifiedObject.description:stringLength
- 210 The string IdentifiedObject.description is maximum 256 characters.
- 211 • C:452:ALL:NA:float
- 212 An attribute that is defined as float (e.g. has a type Float or a type which is a Datatype
213 with .value attribute of type Float) shall support ISO/IEC 60559:2020 for floating-point
214 arithmetic using single precision floating point. A single precision float supports 7
215 significant digits where the significant digits are described as an integer, or a decimal
216 number with 6 decimal digits. Two float values are equal when the significant with 7
217 digits are identical, e.g. 1234567 is equal 1.234567E6 and so are 1.2345678 and
218 1.234567E0.
- 219 • R:NC:ALL:Region:reference
- 220 The reference to the Region is normally a reference to the capacity calculation region,
221 which is identified by “Y” EIC code of the capacity calculation region.
- 222 • R:NC:ALL:SystemOperator:reference
- 223 The reference to the System Operator is normally identified by “X” EIC code of TSO.
- 224 • R:NC:AE:AssessedElement:usage
- 225 All elements that need to be scanned for a base case or contingencies shall be explicitly
226 defined. If not specified otherwise in another document, an application that performs
227 contingency analysis will only report violations that occur on an assessed element and
228 will not report any other violations on elements that have operational limits defined, but
229 the object in the equipment is not designated as an AssessedElement. Therefore, the
230 choice which equipment is scanned shall be made considering multiple factors among
231 which the probability of missing potential violations and the performance of the
232 contingency analysis.
- 233 • C:NC:AE:AssessedElement:associations
- 234 An AssessedElement shall be associated with either
235 AssessedElement.ConductingEquipment or AssessedElement.AssessedTerminal.

236 2.4 Metadata

237 ENTSO-E agreed to extend the header and metadata definitions by IEC 61970-552 Ed2. This
238 new header definitions rely on W3C recommendations which are used worldwide and are
239 positively recognised by the European Commission. The new definitions of the header mainly
240 use Provenance ontology (PROV-O), Time Ontology and Data Catalog Vocabulary (DCAT). The
241 global new header applicable for this profile is included in the metadata and document header
242 specification document.

243 The header vocabulary contains all attributes defined in IEC 61970-552. This is done only for
244 the purpose of having one vocabulary for header and to ensure transition for data exchanges
245 that are using IEC 61970-552:2016 header. This profile does not use IEC 61970-552:2016
246 header attributes and relies only on the extended attributes.

247 2.4.1 Constraints

248 The identification of the constraints related to the metadata follows the same convention for
249 naming of the constraints as for profile constraints.

- R:NC:ALL:wasAttributedTo:usage

The prov:wasAttributedTo should normally be the “X” EIC code of the actor (prov:Agent).

252


2.4.2 Reference metadata

The header defined for this profile requires availability of a set of reference metadata. For instance, the attribute prov:wasGeneratedBy requires a reference to an activity which produced the model or the related process. The activities are defined as reference metadata and their identifiers are referenced from the header to enable the receiving entity to retrieve the “static” (reference) information that it is not modified frequently. This approach imposes a requirement that both the sending entity and the receiving entity have access to a unique version of the reference metadata. Therefore, each business process shall define which reference metadata is used and where it is located.

3 Detailed Profile Specification

3.1 General


This package contains assessed element profile.



265

266 **Figure 1 – Class diagram AssessedElementProfile::AssessedElementProfile**

267 Figure 1: The diagram contains the main classes used in the profile.



268

269 **Figure 2 – Class diagram AssessedElementProfile::AssessedElementDatatypes**

270 Figure 2: The diagram shows datatypes that are used by classes in the profile. Stereotypes are
 271 used to describe the datatypes. The following stereotypes are defined:

- 272 <<enumeration>> A list of permissible constant values.
- 273 <<Primitive>> The most basic data types used to compose all other data types.
- 274 <<CIMDatatype>> A datatype that contains a value attribute, an optional unit of measure and
 275 a unit multiplier. The unit and multiplier may be specified as a static variable initialized to the
 276 allowed value.
- 277 <<Compound>> A composite of Primitive, enumeration, CIMDatatype or other Compound
 278 classes, as long as the Compound classes do not recurse.
- 279 For all datatypes both positive and negative values are allowed unless stated otherwise for a
 280 particular datatype.

281 **3.2 (NC) AssessedElement**

282 Inheritance path = [IdentifiedObject](#)
 283 Assessed element is a network element for which the electrical state is evaluated in the regional
 284 or cross-regional process and which value is expected to fulfil regional rules function of the
 285 operational security limits.
 286 The information of the validity period of the assessed element is derived from the conducting
 287 equipment.
 288 The measurements and limits are as defined in the steady state hypothesis.
 289 Table 1 shows all attributes of AssessedElement.

290 **Table 1 – Attributes of AssessedElementProfile::AssessedElement**

name	mult	type	description
inBaseCase	1..1	Boolean	(NC) Indicates if the assessed element is scanned in the base case. True means that the assessed element is scanned in the base case. False means it is not scanned in the base case. In case of false the association AssessedElement.Contingency is required.
isCritical	0..1	Boolean	(NC) Indicates if the assessed element is critical. True, means that the assessed element is critical. False, means that the assessed element is not critical. Critical means that the assessed element for the conducting equipment or power transfer corridor are considered limiting for the power exchange.
maxMarginAdjustment	0..1	PerCent	(NC) Maximum adjustment, relative to maximum flow allowed for exceeding the maximum flow of this assessed element.

name	mult	type	description
flowReliabilityMargin	0..1	PerCent	(NC) Percentage of the maximum flow (margin) reserved to anticipate forecasting errors.
targetRemainingAvailableMargin	0..1	PerCent	(NC) Target for the remaining available margin as a percentage of maximum flow.
description	0..1	String	inherited from: IdentifiedObject
mRID	1..1	String	inherited from: IdentifiedObject
name	0..1	String	inherited from: IdentifiedObject

291
292

Table 2 shows all association ends of AssessedElement with other classes.

293
294

Table 2 – Association ends of AssessedElementProfile::AssessedElement with other classes

mult from	name	mult to	type	description
0..*	ConservativeForRegion	0..1	Region	(NC) This is the region where the element is considered conservative.
0..*	NativeRegion	0..1	Region	(NC) The native region for an assessed element.
0..*	AssessedSystemOperator	1..1	SystemOperator	(NC) A system operator that assesses the element.
0..*	ScannedForRegion	1..1	Region	(NC) This is the region in which this assessed element is scanned.
0..*	ConductingEquipment	0..1	ConductingEquipment	(NC) The conducting equipment that is designated as an assessed element, i.e. the equipment that is assessed.
0..*	AssessedTerminal	0..1	Terminal	(NC) The terminal that is assessed.
0..*	SecuredForRegion	0..1	Region	(NC) This is the region where the element is secured.
0..*	AssessedPowerTransferCorridor	0..1	PowerTransferCorridor	(NC) The power transfer corridor that is designated as an assessed element.

295

296 3.3 (NC) AssessedElementWithContingency

297 Inheritance path = [IdentifiedObject](#)

298 The combination of an assessed element and a contingency.

299 Table 3 shows all attributes of AssessedElementWithContingency.

300

Table 3 – Attributes of AssessedElementProfile::AssessedElementWithContingency

name	mult	type	description
enabled	0..1	Boolean	(NC) It identifies if the assessed element with contingency shall be considered. True means considered, False means not considered.
description	0..1	String	inherited from: IdentifiedObject
mRID	1..1	String	inherited from: IdentifiedObject
name	0..1	String	inherited from: IdentifiedObject

301

302

Table 4 shows all association ends of AssessedElementWithContingency with other classes.

303 **Table 4 – Association ends of**
304 **AssessedElementProfile::AssessedElementWithContingency with other classes**

mult from	name	mult to	type	description
0..*	AssessedElement	1..1	AssessedElement	(NC) The assessed element defined for this contingency and assessed element combination.
0..*	Contingency	1..1	Contingency	(NC) The contingency defined for this contingency and assessed element combination.

305
306 **3.4 (NC) AssessedElementWithRemedialAction**

307 Inheritance path = [IdentifiedObject](#)
308 The combination of an assessed element and a remedial action.
309 Table 5 shows all attributes of AssessedElementWithRemedialAction.

310 **Table 5 – Attributes of AssessedElementProfile::AssessedElementWithRemedialAction**

name	mult	type	description
enabled	0..1	Boolean	(NC) It identifies if the assessed element with remedial action shall be considered. True means considered, False means not considered.
description	0..1	String	inherited from: IdentifiedObject
mRID	1..1	String	inherited from: IdentifiedObject
name	0..1	String	inherited from: IdentifiedObject

311
312 Table 6 shows all association ends of AssessedElementWithRemedialAction with other classes.

313 **Table 6 – Association ends of**
314 **AssessedElementProfile::AssessedElementWithRemedialAction with other classes**

mult from	name	mult to	type	description
0..*	AssessedElement	1..1	AssessedElement	(NC) The assessed element defined for this assessed element and remedial action combination.
0..*	RemedialAction	1..1	RemedialAction	(NC) The remedial action defined for this assessed element and remedial action combination.

315
316 **3.5 (abstract) ConductingEquipment root class**

317 The parts of the AC power system that are designed to carry current or that are conductively
318 connected through terminals.

319 **3.6 (abstract) Contingency**

320 Inheritance path = [IdentifiedObject](#)
321 An event threatening system reliability, consisting of one or more contingency elements.
322 Table 7 shows all attributes of Contingency.

323 **Table 7 – Attributes of AssessedElementProfile::Contingency**

name	mult	type	description
description	0..1	String	inherited from: IdentifiedObject
mRID	1..1	String	inherited from: IdentifiedObject

name	mult	type	description
name	0..1	String	inherited from: IdentifiedObject

324

325 3.7 (abstract) IdentifiedObject root class

326 This is a root class to provide common identification for all classes needing identification and
327 naming attributes.

328 Table 8 shows all attributes of IdentifiedObject.

329

Table 8 – Attributes of AssessedElementProfile::IdentifiedObject

name	mult	type	description
description	0..1	String	The description is a free human readable text describing or naming the object. It may be non unique and may not correlate to a naming hierarchy.
mRID	1..1	String	Master resource identifier issued by a model authority. The mRID is unique within an exchange context. Global uniqueness is easily achieved by using a UUID, as specified in RFC 4122, for the mRID. The use of UUID is strongly recommended. For CIMXML data files in RDF syntax conforming to IEC 61970-552, the mRID is mapped to rdf:ID or rdf:about attributes that identify CIM object elements.
name	0..1	String	The name is any free human readable and possibly non unique text naming the object.

330

331 3.8 (abstract,NC) PowerTransferCorridor root class

332 A power transfer corridor is defined as a set of circuits (transmission lines or transformers)
333 separating two portions of the power system, or a subset of circuits exposed to a substantial
334 portion of the transmission exchange between two parts of the system.

335 3.9 (abstract,NC) Region root class

336 A region where the system operator belongs to.

337 3.10 (abstract,NC) RemedialAction

338 Inheritance path = [IdentifiedObject](#)

339 Remedial action describes one or more actions that can be performed on a given power system
340 model situation to eliminate one or more identified breaches of constraints. The remedial action
341 can be costly, and have a cost characteristic, or non costly.

342 Table 9 shows all attributes of RemedialAction.

343

Table 9 – Attributes of AssessedElementProfile::RemedialAction

name	mult	type	description
description	0..1	String	inherited from: IdentifiedObject
mRID	1..1	String	inherited from: IdentifiedObject
name	0..1	String	inherited from: IdentifiedObject

344

345 3.11 (abstract,NC) SystemOperator root class

346 System operator.

347 **3.12 (abstract) Terminal root class**

348 An AC electrical connection point to a piece of conducting equipment. Terminals are connected
349 at physical connection points called connectivity nodes.

350 **3.13 Boolean primitive**

351 A type with the value space "true" and "false".

352 **3.14 Date primitive**

353 Date as "yyyy-mm-dd", which conforms with ISO 8601. UTC time zone is specified as "yyyy-
354 mm-ddZ". A local timezone relative UTC is specified as "yyyy-mm-dd(+/-)hh:mm".

355 **3.15 DateTime primitive**

356 Date and time as "yyyy-mm-ddThh:mm:ss.sss", which conforms with ISO 8601. UTC time zone
357 is specified as "yyyy-mm-ddThh:mm:ss.sssZ". A local timezone relative UTC is specified as
358 "yyyy-mm-ddThh:mm:ss.sss-hh:mm". The second component (shown here as "ss.sss") could
359 have any number of digits in its fractional part to allow any kind of precision beyond seconds.

360 **3.16 String primitive**

361 A string consisting of a sequence of characters. The character encoding is UTF-8. The string
362 length is unspecified and unlimited.

363

364

365 **Annex A (informative): Sample data**

366 **A.1 General**

367 This Annex is designed to illustrate the profile by using fragments of sample data. It is not meant
368 to be a complete set of examples covering all possibilities of using the profile. Defining a
369 complete set of test data is considered a separate activity to be performed for the purpose of
370 setting up interoperability testing and conformity related to this profile.

371 **A.2 Sample instance data**

372 Test data files are available in the CIM EG SharePoint.