



European Network of  
Transmission System Operators  
for Electricity

---

# EQUIPMENT RELIABILITY PROFILE SPECIFICATION

---

2022-09-21

---

SOC APPROVED  
VERSION 2.1

## Copyright notice:

### Copyright © ENTSO-E. All Rights Reserved.

This document and its whole translations may be copied and furnished to others, and derivative works that comment on or otherwise explain it or assist in its implementation may be prepared, copied, published and distributed, in whole or in part, without restriction of any kind, provided that the above copyright notice and this paragraph are included on all such copies and derivative works. However, this document itself may not be modified in any way, except for literal and whole translation into languages other than English and under all circumstances, the copyright notice or references to ENTSO-E may not be removed.

This document and the information contained herein is provided on an "as is" basis.

**ENTSO-E DISCLAIMS ALL WARRANTIES, EXPRESS OR IMPLIED, INCLUDING BUT NOT LIMITED TO ANY WARRANTY THAT THE USE OF THE INFORMATION HEREIN WILL NOT INFRINGE ANY RIGHTS OR ANY IMPLIED WARRANTIES OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE.**

**This document is maintained by the ENTSO-E CIM EG. Comments or remarks are to be provided at [cim@entsoe.eu](mailto:cim@entsoe.eu)**

### NOTE CONCERNING WORDING USED IN THIS DOCUMENT

The force of the following words is modified by the requirement level of the document in which they are used.

- **SHALL:** This word, or the terms "REQUIRED" or "MUST", means that the definition is an absolute requirement of the specification.
- **SHALL NOT:** This phrase, or the phrase "MUST NOT", means that the definition is an absolute prohibition of the specification.
- **SHOULD:** This word, or the adjective "RECOMMENDED", means that there may exist valid reasons in particular circumstances to ignore a particular item, but the full implications must be understood and carefully weighed before choosing a different course.
- **SHOULD NOT:** This phrase, or the phrase "NOT RECOMMENDED", means that there may exist valid reasons in particular circumstances when the particular behaviour is acceptable or even useful, but the full implications should be understood and the case carefully weighed before implementing any behaviour described with this label.
- **MAY:** This word, or the adjective "OPTIONAL", means that an item is truly optional.

## Revision History

Version	Release	Date	Paragraph	Comments
0	1	2021-10-12		For CIM EG review. This profile replaces Available Remedial Action Profile. These new profiles includes also information on SIPS, GLSK, limits, area and overlapping zone.
1	0	2022-02-16		SOC approved
2	1	2022-09-21		SOC approved

## 34 CONTENTS

35	Copyright notice:.....	2
36	Revision History.....	3
37	CONTENTS .....	4
38	1 Introduction .....	15
39	2 Application profile specification .....	15
40	2.1 Version information .....	15
41	2.2 Constraints naming convention .....	15
42	2.3 Profile constraints .....	16
43	2.4 Metadata.....	18
44	2.4.1 Constraints .....	18
45	2.4.2 Reference metadata .....	18
46	3 Detailed Profile Specification .....	18
47	3.1 General.....	18
48	3.2 (abstract) ACDCTerminal .....	26
49	3.3 (NC) ActivePowerControlFunction .....	26
50	3.4 (NC) AmbientTemperatureDependencyCurve .....	27
51	3.5 (NC) AreaDispatchableUnit root class .....	27
52	3.6 (abstract,NC) AutomationFunction .....	28
53	3.7 (NC) BaseOverloadLimitCurve .....	28
54	3.8 (NC) BiddingZone .....	29
55	3.9 (NC) BiddingZoneBorder .....	29
56	3.10 (NC) CapacityCalculationRegion .....	30
57	3.11 (NC) ChargingUnit .....	30
58	3.12 (abstract,NC) Circuit .....	31
59	3.13 (NC) CircuitShare .....	32
60	3.14 (NC) ClosedDistributionSystemOperator .....	32
61	3.15 (NC) CompensatorController .....	33
62	3.16 (abstract) ConductingEquipment .....	33
63	3.17 (abstract) ConnectivityNodeContainer .....	34
64	3.18 (Description) ControlArea.....	34
65	3.19 (abstract,NC) ControlFunctionBlock .....	35
66	3.20 (abstract) Curve root class .....	36
67	3.21 CurveData root class .....	36
68	3.22 (Description) DCConverterUnit.....	36
69	3.23 (NC) DCController.....	37
70	3.24 (abstract) DCEquipmentContainer .....	37
71	3.25 (abstract) DCLine.....	37
72	3.26 (NC) DCPole .....	38
73	3.27 (NC) DCTieCorridor .....	38
74	3.28 (NC) DirectCurrentController.....	39
75	3.29 (NC) DirectCurrentSystemOperator .....	39
76	3.30 (NC) DistributionSystemOperator .....	40
77	3.31 (NC) DurationOverloadLimitCurve .....	40

78	3.32	(NC) EnergyAlignmentCoordinator .....	41
79	3.33	(NC) EnergyBlockComponent .....	41
80	3.34	(NC) EnergyBlockOrder .....	42
81	3.35	(abstract,NC) EnergyComponent .....	42
82	3.36	(abstract) EnergyConnection .....	43
83	3.37	(Description) EnergyConsumer .....	44
84	3.38	(NC) EnergyCoordinationRegion .....	44
85	3.39	(NC) EnergyGroup .....	45
86	3.40	(NC) EnergyTypeReference .....	45
87	3.41	(Description) Equipment .....	46
88	3.42	(abstract) EquipmentContainer .....	46
89	3.43	(abstract,NC) EquipmentController .....	47
90	3.44	(NC) ExceptionalPowerTransferCorridor .....	47
91	3.45	(NC) FacilityPlantController .....	47
92	3.46	(abstract,NC) FACTSEquipment .....	48
93	3.47	Feeder .....	49
94	3.48	(NC) FlexibleEnergyUnit .....	49
95	3.49	(abstract,NC) FunctionBlock .....	50
96	3.50	(abstract,NC) FunctionInputVariable .....	51
97	3.51	(NC) FunctionOutputVariable .....	51
98	3.52	(NC) GateInputPin .....	52
99	3.53	(Description) GeneratingUnit .....	53
100	3.54	(NC) GeothermalGeneratingUnit .....	53
101	3.55	(Description) HydroPump .....	54
102	3.56	(abstract) IdentifiedObject root class .....	55
103	3.57	(NC) ImpedanceFunction .....	55
104	3.58	(abstract,NC) LimitDependencyCurve .....	56
105	3.59	(Description) Line .....	56
106	3.60	(NC) LineCircuit .....	57
107	3.61	(NC) LoadFrequencyControlArea .....	57
108	3.62	(NC) LoadFrequencyControlBlock .....	58
109	3.63	(NC) LoadFrequencyControlOperator .....	58
110	3.64	(NC) ModularStaticSynchronousSeriesCompensator .....	59
111	3.65	NuclearGeneratingUnit .....	60
112	3.66	(abstract) OperationalLimit .....	60
113	3.67	OperationalLimitSet .....	61
114	3.68	OperationalLimitType .....	61
115	3.69	(NC) OrdinaryPowerTransferCorridor .....	62
116	3.70	Organisation .....	62
117	3.71	(abstract) OrganisationRole .....	63
118	3.72	(NC) OutageCoordinationRegion .....	63
119	3.73	(NC) OutageCoordinator .....	64
120	3.74	(NC) OutagePlanningAgent .....	64
121	3.75	(NC) PinTerminal .....	65
122	3.76	(NC) PowerElectricalChemicalUnit .....	65
123	3.77	(NC) PowerElectronicsMarineUnit .....	66

124	3.78	(Description) PowerElectronicsUnit .....	67
125	3.79	(NC) PowerFactorFunction .....	67
126	3.80	(abstract,NC) PowerSystemOrganisationRole .....	68
127	3.81	(abstract) PowerSystemResource .....	68
128	3.82	(abstract,NC) PowerTransferCorridor .....	69
129	3.83	(NC) PowerTransformerCircuit .....	69
130	3.84	(abstract,NC) PropertyReference root class .....	70
131	3.85	(NC) ProportionalEnergyComponent .....	70
132	3.86	(NC) PTCTriggeredEquipment .....	70
133	3.87	(NC) ReactivePowerControlFunction .....	71
134	3.88	(NC) RecoveryOverloadLimitCurve .....	71
135	3.89	(abstract,NC) Region .....	72
136	3.90	(abstract) RegulatingCondEq .....	72
137	3.91	(NC) ScheduleResource .....	72
138	3.92	(NC) SchedulingArea .....	73
139	3.93	(NC) SecurityCoordinator .....	74
140	3.94	(NC) SolarRadiationDepedencyCurve .....	74
141	3.95	(NC) StaticSynchronousCompensator .....	75
142	3.96	(NC) StaticSynchronousSeriesCompensator .....	75
143	3.97	(NC) SubSchedulingArea .....	76
144	3.98	(Description) Substation .....	77
145	3.99	(NC) SubstationController .....	77
146	3.100	(NC) SynchronousArea .....	78
147	3.101	(abstract,NC) SystemOperationCoordinator .....	78
148	3.102	(abstract,NC) SystemOperator .....	79
149	3.103	(abstract) TapChanger .....	79
150	3.104	(abstract) Terminal .....	79
151	3.105	(NC) TieCorridor .....	80
152	3.106	(NC) ThyristorControlledSeriesCompensator .....	80
153	3.107	(NC) TransmissionSystemOperator .....	81
154	3.108	(NC) UnifiedPowerFlowController .....	82
155	3.109	(NC) VoltageAngleLimit .....	82
156	3.110	(NC) VoltageControlFunction .....	83
157	3.111	Currency enumeration .....	83
158	3.112	CurveStyle enumeration .....	87
159	3.113	(NC) EnergyKind enumeration .....	88
160	3.114	(NC) MarineUnitKind enumeration .....	88
161	3.115	OperationalLimitDirectionKind enumeration .....	89
162	3.116	(NC) PinTerminalKind enumeration .....	89
163	3.117	(NC) NuclearReactorKind enumeration .....	89
164	3.118	(NC) GeothermalUnitKind enumeration .....	90
165	3.119	(NC) LogicalOperatorsKind enumeration .....	90
166	3.120	(NC) PowerElectricalChemicalUnitKind enumeration .....	90
167	3.121	UnitMultiplier enumeration .....	91
168	3.122	UnitSymbol enumeration .....	92
169	3.123	ActivePower datatype .....	97

170	3.124	ActivePowerChangeRate datatype .....	97
171	3.125	AngleDegrees datatype .....	98
172	3.126	Frequency datatype .....	98
173	3.127	Impedance datatype .....	98
174	3.128	Money datatype .....	98
175	3.129	PerCent datatype .....	99
176	3.130	Reactance datatype .....	99
177	3.131	Seconds datatype .....	99
178	3.132	VoltagePerReactivePower datatype .....	99
179	3.133	Boolean primitive .....	99
180	3.134	Date primitive .....	100
181	3.135	DateTime primitive .....	100
182	3.136	Decimal primitive .....	100
183	3.137	Duration primitive .....	100
184	3.138	Float primitive .....	100
185	3.139	Integer primitive .....	100
186	3.140	String primitive .....	100
187		Annex A (informative): Sample data .....	101
188	A.1	General .....	101
189	A.2	Sample instance data .....	101

190

## 191 List of figures

192	Figure 1 – Class diagram EquipmentReliabilityProfile::Core .....	19
193	Figure 2 – Class diagram EquipmentReliabilityProfile::DirectCurrent .....	20
194	Figure 3 – Class diagram EquipmentReliabilityProfile::EnergyArea .....	20
195	Figure 4 – Class diagram EquipmentReliabilityProfile::EquipmentReliabilityDatatypes .....	21
196	Figure 5 – Class diagram EquipmentReliabilityProfile::FACTS .....	22
197	Figure 6 – Class diagram EquipmentReliabilityProfile::GLSK .....	23
198	Figure 7 – Class diagram EquipmentReliabilityProfile::PowerSystemOrganizationRole .....	24
199	Figure 8 – Class diagram EquipmentReliabilityProfile::PowerTransferCorridor .....	24
200	Figure 9 – Class diagram EquipmentReliabilityProfile::Production .....	25
201	Figure 10 – Class diagram EquipmentReliabilityProfile::ReliabilityLimits .....	26

202

## 203 List of tables

204	Table 1 – Attributes of EquipmentReliabilityProfile::ACDCTerminal .....	26
205	Table 2 – Attributes of EquipmentReliabilityProfile::ActivePowerControlFunction .....	27
206	Table 3 – Association ends of EquipmentReliabilityProfile::ActivePowerControlFunction	
207	with other classes .....	27
208	Table 4 – Attributes of	
209	EquipmentReliabilityProfile::AmbientTemperatureDependencyCurve .....	27
210	Table 5 – Attributes of EquipmentReliabilityProfile::AreaDispatchableUnit .....	27

211	Table 6 – Association ends of EquipmentReliabilityProfile::AreaDispatchableUnit with	
212	other classes .....	28
213	Table 7 – Attributes of EquipmentReliabilityProfile::AutomationFunction .....	28
214	Table 8 – Association ends of EquipmentReliabilityProfile::AutomationFunction with	
215	other classes .....	28
216	Table 9 – Attributes of EquipmentReliabilityProfile::BaseOverloadLimitCurve .....	29
217	Table 10 – Attributes of EquipmentReliabilityProfile::BiddingZone.....	29
218	Table 11 – Association ends of EquipmentReliabilityProfile::BiddingZone with other	
219	classes .....	29
220	Table 12 – Attributes of EquipmentReliabilityProfile::BiddingZoneBorder .....	30
221	Table 13 – Association ends of EquipmentReliabilityProfile::BiddingZoneBorder with	
222	other classes .....	30
223	Table 14 – Attributes of EquipmentReliabilityProfile::CapacityCalculationRegion .....	30
224	Table 15 – Association ends of EquipmentReliabilityProfile::CapacityCalculationRegion	
225	with other classes .....	30
226	Table 16 – Attributes of EquipmentReliabilityProfile::ChargingUnit.....	31
227	Table 17 – Association ends of EquipmentReliabilityProfile::ChargingUnit with other	
228	classes .....	31
229	Table 18 – Attributes of EquipmentReliabilityProfile::Circuit .....	31
230	Table 19 – Association ends of EquipmentReliabilityProfile::Circuit with other classes .....	32
231	Table 20 – Attributes of EquipmentReliabilityProfile::CircuitShare .....	32
232	Table 21 – Association ends of EquipmentReliabilityProfile::CircuitShare with other	
233	classes .....	32
234	Table 22 – Attributes of EquipmentReliabilityProfile::ClosedDistributionSystemOperator .....	32
235	Table 23 – Association ends of	
236	EquipmentReliabilityProfile::ClosedDistributionSystemOperator with other classes .....	33
237	Table 24 – Attributes of EquipmentReliabilityProfile::CompensatorController .....	33
238	Table 25 – Association ends of EquipmentReliabilityProfile::CompensatorController	
239	with other classes .....	33
240	Table 26 – Attributes of EquipmentReliabilityProfile::ConductingEquipment .....	33
241	Table 27 – Association ends of EquipmentReliabilityProfile::ConductingEquipment with	
242	other classes .....	34
243	Table 28 – Attributes of EquipmentReliabilityProfile::ConnectivityNodeContainer .....	34
244	Table 29 – Attributes of EquipmentReliabilityProfile::ControlArea .....	34
245	Table 30 – Association ends of EquipmentReliabilityProfile::ControlArea with other	
246	classes .....	35
247	Table 31 – Attributes of EquipmentReliabilityProfile::ControlFunctionBlock .....	35
248	Table 32 – Association ends of EquipmentReliabilityProfile::ControlFunctionBlock with	
249	other classes .....	35
250	Table 33 – Attributes of EquipmentReliabilityProfile::Curve .....	36
251	Table 34 – Attributes of EquipmentReliabilityProfile::CurveData .....	36
252	Table 35 – Association ends of EquipmentReliabilityProfile::CurveData with other	
253	classes .....	36
254	Table 36 – Attributes of EquipmentReliabilityProfile::DCConverterUnit.....	36



255	Table 37 – Association ends of EquipmentReliabilityProfile::DCConverterUnit with	
256	other classes .....	37
257	Table 38 – Attributes of EquipmentReliabilityProfile::DCController .....	37
258	Table 39 – Attributes of EquipmentReliabilityProfile::DCEquipmentContainer .....	37
259	Table 40 – Attributes of EquipmentReliabilityProfile::DCLine .....	38
260	Table 41 – Attributes of EquipmentReliabilityProfile::DCPole .....	38
261	Table 42 – Association ends of EquipmentReliabilityProfile::DCPole with other classes .....	38
262	Table 43 – Attributes of EquipmentReliabilityProfile::DCTieCorridor .....	38
263	Table 44 – Association ends of EquipmentReliabilityProfile::DCTieCorridor with other	
264	classes .....	39
265	Table 45 – Attributes of EquipmentReliabilityProfile::DirectCurrentController .....	39
266	Table 46 – Association ends of EquipmentReliabilityProfile::DirectCurrentController	
267	with other classes .....	39
268	Table 47 – Attributes of EquipmentReliabilityProfile::DirectCurrentSystemOperator .....	40
269	Table 48 – Association ends of	
270	EquipmentReliabilityProfile::DirectCurrentSystemOperator with other classes .....	40
271	Table 49 – Attributes of EquipmentReliabilityProfile::DistributionSystemOperator .....	40
272	Table 50 – Association ends of	
273	EquipmentReliabilityProfile::DistributionSystemOperator with other classes .....	40
274	Table 51 – Attributes of EquipmentReliabilityProfile::DurationOverloadLimitCurve .....	41
275	Table 52 – Attributes of EquipmentReliabilityProfile::EnergyAlignmentCoordinator .....	41
276	Table 53 – Association ends of	
277	EquipmentReliabilityProfile::EnergyAlignmentCoordinator with other classes .....	41
278	Table 54 – Attributes of EquipmentReliabilityProfile::EnergyBlockComponent .....	41
279	Table 55 – Association ends of EquipmentReliabilityProfile::EnergyBlockComponent	
280	with other classes .....	42
281	Table 56 – Attributes of EquipmentReliabilityProfile::EnergyBlockOrder .....	42
282	Table 57 – Association ends of EquipmentReliabilityProfile::EnergyBlockOrder with	
283	other classes .....	42
284	Table 58 – Attributes of EquipmentReliabilityProfile::EnergyComponent .....	43
285	Table 59 – Association ends of EquipmentReliabilityProfile::EnergyComponent with	
286	other classes .....	43
287	Table 60 – Attributes of EquipmentReliabilityProfile::EnergyConnection .....	43
288	Table 61 – Association ends of EquipmentReliabilityProfile::EnergyConnection with	
289	other classes .....	43
290	Table 62 – Attributes of EquipmentReliabilityProfile::EnergyConsumer .....	44
291	Table 63 – Association ends of EquipmentReliabilityProfile::EnergyConsumer with	
292	other classes .....	44
293	Table 64 – Attributes of EquipmentReliabilityProfile::EnergyCoordinationRegion .....	44
294	Table 65 – Association ends of EquipmentReliabilityProfile::EnergyCoordinationRegion	
295	with other classes .....	45
296	Table 66 – Attributes of EquipmentReliabilityProfile::EnergyGroup .....	45
297	Table 67 – Association ends of EquipmentReliabilityProfile::EnergyGroup with other	
298	classes .....	45

299	Table 68 – Attributes of EquipmentReliabilityProfile::EnergyTypeReference .....	46
300	Table 69 – Attributes of EquipmentReliabilityProfile::Equipment .....	46
301	Table 70 – Association ends of EquipmentReliabilityProfile::Equipment with other	
302	classes .....	46
303	Table 71 – Attributes of EquipmentReliabilityProfile::EquipmentContainer .....	46
304	Table 72 – Attributes of EquipmentReliabilityProfile::EquipmentController .....	47
305	Table 73 – Association ends of EquipmentReliabilityProfile::EquipmentController with	
306	other classes .....	47
307	Table 74 – Attributes of EquipmentReliabilityProfile::ExceptionalPowerTransferCorridor .....	47
308	Table 75 – Attributes of EquipmentReliabilityProfile::FacilityPlantController .....	48
309	Table 76 – Association ends of EquipmentReliabilityProfile::FacilityPlantController with	
310	other classes .....	48
311	Table 77 – Attributes of EquipmentReliabilityProfile::FACTSEquipment .....	48
312	Table 78 – Association ends of EquipmentReliabilityProfile::FACTSEquipment with	
313	other classes .....	48
314	Table 79 – Attributes of EquipmentReliabilityProfile::Feeder .....	49
315	Table 80 – Association ends of EquipmentReliabilityProfile::Feeder with other classes .....	49
316	Table 81 – Attributes of EquipmentReliabilityProfile::FlexibleEnergyUnit .....	49
317	Table 82 – Association ends of EquipmentReliabilityProfile::FlexibleEnergyUnit with	
318	other classes .....	50
319	Table 83 – Attributes of EquipmentReliabilityProfile::FunctionBlock .....	50
320	Table 84 – Association ends of EquipmentReliabilityProfile::FunctionBlock with other	
321	classes .....	51
322	Table 85 – Attributes of EquipmentReliabilityProfile::FunctionInputVariable .....	51
323	Table 86 – Association ends of EquipmentReliabilityProfile::FunctionInputVariable with	
324	other classes .....	51
325	Table 87 – Attributes of EquipmentReliabilityProfile::FunctionOutputVariable .....	51
326	Table 88 – Association ends of EquipmentReliabilityProfile::FunctionOutputVariable	
327	with other classes .....	52
328	Table 89 – Attributes of EquipmentReliabilityProfile::GateInputPin .....	52
329	Table 90 – Association ends of EquipmentReliabilityProfile::GateInputPin with other	
330	classes .....	52
331	Table 91 – Attributes of EquipmentReliabilityProfile::GeneratingUnit.....	53
332	Table 92 – Association ends of EquipmentReliabilityProfile::GeneratingUnit with other	
333	classes .....	53
334	Table 93 – Attributes of EquipmentReliabilityProfile::GeothermalGeneratingUnit .....	53
335	Table 94 – Association ends of EquipmentReliabilityProfile::GeothermalGeneratingUnit	
336	with other classes .....	54
337	Table 95 – Attributes of EquipmentReliabilityProfile::HydroPump .....	54
338	Table 96 – Association ends of EquipmentReliabilityProfile::HydroPump with other	
339	classes .....	55
340	Table 97 – Attributes of EquipmentReliabilityProfile::IdentifiedObject.....	55
341	Table 98 – Attributes of EquipmentReliabilityProfile::ImpedanceFunction .....	55

342	Table 99 – Association ends of EquipmentReliabilityProfile::ImpedanceFunction with	
343	other classes .....	56
344	Table 100 – Attributes of EquipmentReliabilityProfile::LimitDependencyCurve .....	56
345	Table 101 – Attributes of EquipmentReliabilityProfile::Line .....	56
346	Table 102 – Association ends of EquipmentReliabilityProfile::Line with other classes .....	57
347	Table 103 – Attributes of EquipmentReliabilityProfile::LineCircuit .....	57
348	Table 104 – Association ends of EquipmentReliabilityProfile::LineCircuit with other	
349	classes .....	57
350	Table 105 – Attributes of EquipmentReliabilityProfile::LoadFrequencyControlArea .....	57
351	Table 106 – Association ends of	
352	EquipmentReliabilityProfile::LoadFrequencyControlArea with other classes .....	58
353	Table 107 – Attributes of EquipmentReliabilityProfile::LoadFrequencyControlBlock .....	58
354	Table 108 – Association ends of	
355	EquipmentReliabilityProfile::LoadFrequencyControlBlock with other classes .....	58
356	Table 109 – Attributes of EquipmentReliabilityProfile::LoadFrequencyControlOperator .....	59
357	Table 110 – Association ends of	
358	EquipmentReliabilityProfile::LoadFrequencyControlOperator with other classes .....	59
359	Table 111 – Attributes of	
360	EquipmentReliabilityProfile::ModularStaticSynchronousSeriesCompensator .....	59
361	Table 112 – Association ends of	
362	EquipmentReliabilityProfile::ModularStaticSynchronousSeriesCompensator with other	
363	classes .....	60
364	Table 113 – Attributes of EquipmentReliabilityProfile::NuclearGeneratingUnit .....	60
365	Table 114 – Association ends of EquipmentReliabilityProfile::NuclearGeneratingUnit	
366	with other classes .....	60
367	Table 115 – Attributes of EquipmentReliabilityProfile::OperationalLimit .....	61
368	Table 116 – Association ends of EquipmentReliabilityProfile::OperationalLimit with	
369	other classes .....	61
370	Table 117 – Attributes of EquipmentReliabilityProfile::OperationalLimitSet .....	61
371	Table 118 – Association ends of EquipmentReliabilityProfile::OperationalLimitSet with	
372	other classes .....	61
373	Table 119 – Attributes of EquipmentReliabilityProfile::OperationalLimitType .....	62
374	Table 120 – Association ends of EquipmentReliabilityProfile::OperationalLimitType	
375	with other classes .....	62
376	Table 121 – Attributes of EquipmentReliabilityProfile::OrdinaryPowerTransferCorridor .....	62
377	Table 122 – Attributes of EquipmentReliabilityProfile::Organisation .....	63
378	Table 123 – Attributes of EquipmentReliabilityProfile::OrganisationRole .....	63
379	Table 124 – Association ends of EquipmentReliabilityProfile::OrganisationRole with	
380	other classes .....	63
381	Table 125 – Attributes of EquipmentReliabilityProfile::OutageCoordinationRegion .....	63
382	Table 126 – Association ends of	
383	EquipmentReliabilityProfile::OutageCoordinationRegion with other classes .....	64
384	Table 127 – Attributes of EquipmentReliabilityProfile::OutageCoordinator .....	64
385	Table 128 – Association ends of EquipmentReliabilityProfile::OutageCoordinator with	
386	other classes .....	64

387	Table 129 – Attributes of EquipmentReliabilityProfile::OutagePlanningAgent .....	64
388	Table 130 – Association ends of EquipmentReliabilityProfile::OutagePlanningAgent	
389	with other classes .....	65
390	Table 131 – Attributes of EquipmentReliabilityProfile::PinTerminal .....	65
391	Table 132 – Association ends of EquipmentReliabilityProfile::PinTerminal with other	
392	classes .....	65
393	Table 133 – Attributes of EquipmentReliabilityProfile::PowerElectricalChemicalUnit .....	66
394	Table 134 – Association ends of	
395	EquipmentReliabilityProfile::PowerElectricalChemicalUnit with other classes .....	66
396	Table 135 – Attributes of EquipmentReliabilityProfile::PowerElectronicsMarineUnit .....	66
397	Table 136 – Association ends of	
398	EquipmentReliabilityProfile::PowerElectronicsMarineUnit with other classes .....	67
399	Table 137 – Attributes of EquipmentReliabilityProfile::PowerElectronicsUnit .....	67
400	Table 138 – Association ends of EquipmentReliabilityProfile::PowerElectronicsUnit	
401	with other classes .....	67
402	Table 139 – Attributes of EquipmentReliabilityProfile::PowerFactorFunction .....	68
403	Table 140 – Association ends of EquipmentReliabilityProfile::PowerFactorFunction with	
404	other classes .....	68
405	Table 141 – Attributes of EquipmentReliabilityProfile::PowerSystemOrganisationRole .....	68
406	Table 142 – Association ends of	
407	EquipmentReliabilityProfile::PowerSystemOrganisationRole with other classes .....	68
408	Table 143 – Attributes of EquipmentReliabilityProfile::PowerSystemResource .....	69
409	Table 144 – Attributes of EquipmentReliabilityProfile::PowerTransferCorridor .....	69
410	Table 145 – Attributes of EquipmentReliabilityProfile::PowerTransformerCircuit .....	69
411	Table 146 – Association ends of EquipmentReliabilityProfile::PowerTransformerCircuit	
412	with other classes .....	70
413	Table 147 – Attributes of EquipmentReliabilityProfile::ProportionalEnergyComponent.....	70
414	Table 148 – Association ends of	
415	EquipmentReliabilityProfile::ProportionalEnergyComponent with other classes .....	70
416	Table 149 – Attributes of EquipmentReliabilityProfile::PTCTriggeredEquipment .....	70
417	Table 150 – Association ends of EquipmentReliabilityProfile::PTCTriggeredEquipment	
418	with other classes .....	71
419	Table 151 – Attributes of EquipmentReliabilityProfile::ReactivePowerControlFunction .....	71
420	Table 152 – Association ends of	
421	EquipmentReliabilityProfile::ReactivePowerControlFunction with other classes .....	71
422	Table 153 – Attributes of EquipmentReliabilityProfile::RecoveryOverloadLimitCurve .....	71
423	Table 154 – Attributes of EquipmentReliabilityProfile::Region .....	72
424	Table 155 – Attributes of EquipmentReliabilityProfile::RegulatingCondEq .....	72
425	Table 156 – Association ends of EquipmentReliabilityProfile::RegulatingCondEq with	
426	other classes .....	72
427	Table 157 – Attributes of EquipmentReliabilityProfile::ScheduleResource .....	73
428	Table 158 – Association ends of EquipmentReliabilityProfile::ScheduleResource with	
429	other classes .....	73
430	Table 159 – Attributes of EquipmentReliabilityProfile::SchedulingArea.....	73

431	Table 160 – Association ends of EquipmentReliabilityProfile::SchedulingArea with	
432	other classes .....	74
433	Table 161 – Attributes of EquipmentReliabilityProfile::SecurityCoordinator .....	74
434	Table 162 – Association ends of EquipmentReliabilityProfile::SecurityCoordinator with	
435	other classes .....	74
436	Table 163 – Attributes of EquipmentReliabilityProfile::SolarRadiationDependencyCurve .....	75
437	Table 164 – Attributes of EquipmentReliabilityProfile::StaticSynchronousCompensator .....	75
438	Table 165 – Association ends of	
439	EquipmentReliabilityProfile::StaticSynchronousCompensator with other classes .....	75
440	Table 166 – Attributes of	
441	EquipmentReliabilityProfile::StaticSynchronousSeriesCompensator .....	76
442	Table 167 – Association ends of	
443	EquipmentReliabilityProfile::StaticSynchronousSeriesCompensator with other classes .....	76
444	Table 168 – Attributes of EquipmentReliabilityProfile::SubSchedulingArea .....	76
445	Table 169 – Association ends of EquipmentReliabilityProfile::SubSchedulingArea with	
446	other classes .....	77
447	Table 170 – Attributes of EquipmentReliabilityProfile::Substation .....	77
448	Table 171 – Association ends of EquipmentReliabilityProfile::Substation with other	
449	classes .....	77
450	Table 172 – Attributes of EquipmentReliabilityProfile::SubstationController .....	77
451	Table 173 – Association ends of EquipmentReliabilityProfile::SubstationController with	
452	other classes .....	78
453	Table 174 – Attributes of EquipmentReliabilityProfile::SynchronousArea .....	78
454	Table 175 – Attributes of EquipmentReliabilityProfile::SystemOperationCoordinator .....	78
455	Table 176 – Association ends of	
456	EquipmentReliabilityProfile::SystemOperationCoordinator with other classes .....	79
457	Table 177 – Attributes of EquipmentReliabilityProfile::SystemOperator .....	79
458	Table 178 – Association ends of EquipmentReliabilityProfile::SystemOperator with	
459	other classes .....	79
460	Table 179 – Attributes of EquipmentReliabilityProfile::TapChanger .....	79
461	Table 180 – Attributes of EquipmentReliabilityProfile::Terminal .....	80
462	Table 181 – Attributes of EquipmentReliabilityProfile::TieCorridor .....	80
463	Table 182 – Attributes of	
464	EquipmentReliabilityProfile::ThyristorControlledSeriesCompensator .....	80
465	Table 183 – Association ends of	
466	EquipmentReliabilityProfile::ThyristorControlledSeriesCompensator with other classes .....	81
467	Table 184 – Attributes of EquipmentReliabilityProfile::TransmissionSystemOperator .....	81
468	Table 185 – Association ends of	
469	EquipmentReliabilityProfile::TransmissionSystemOperator with other classes .....	81
470	Table 186 – Attributes of EquipmentReliabilityProfile::UnifiedPowerFlowController .....	82
471	Table 187 – Association ends of	
472	EquipmentReliabilityProfile::UnifiedPowerFlowController with other classes .....	82
473	Table 188 – Attributes of EquipmentReliabilityProfile::VoltageAngleLimit .....	82
474	Table 189 – Association ends of EquipmentReliabilityProfile::VoltageAngleLimit with	
475	other classes .....	83

476	Table 190 – Attributes of EquipmentReliabilityProfile::VoltageControlFunction .....	83
477	Table 191 – Association ends of EquipmentReliabilityProfile::VoltageControlFunction	
478	with other classes .....	83
479	Table 192 – Literals of EquipmentReliabilityProfile::Currency .....	83
480	Table 193 – Literals of EquipmentReliabilityProfile::CurveStyle .....	88
481	Table 194 – Literals of EquipmentReliabilityProfile::EnergyKind .....	88
482	Table 195 – Literals of EquipmentReliabilityProfile::MarineUnitKind .....	88
483	Table 196 – Literals of EquipmentReliabilityProfile::OperationalLimitDirectionKind .....	89
484	Table 197 – Literals of EquipmentReliabilityProfile::PinTerminalKind .....	89
485	Table 198 – Literals of EquipmentReliabilityProfile::NuclearReactorKind .....	89
486	Table 199 – Literals of EquipmentReliabilityProfile::GeothermalUnitKind .....	90
487	Table 200 – Literals of EquipmentReliabilityProfile::LogicalOperatorsKind .....	90
488	Table 201 – Literals of EquipmentReliabilityProfile::PowerElectricalChemicalUnitKind .....	91
489	Table 202 – Literals of EquipmentReliabilityProfile::UnitMultiplier .....	91
490	Table 203 – Literals of EquipmentReliabilityProfile::UnitSymbol .....	92
491	Table 204 – Attributes of EquipmentReliabilityProfile::ActivePower .....	97
492	Table 205 – Attributes of EquipmentReliabilityProfile::ActivePowerChangeRate .....	98
493	Table 206 – Attributes of EquipmentReliabilityProfile::AngleDegrees .....	98
494	Table 207 – Attributes of EquipmentReliabilityProfile::Frequency .....	98
495	Table 208 – Attributes of EquipmentReliabilityProfile::Impedance .....	98
496	Table 209 – Attributes of EquipmentReliabilityProfile::Money .....	98
497	Table 210 – Attributes of EquipmentReliabilityProfile::PerCent .....	99
498	Table 211 – Attributes of EquipmentReliabilityProfile::Reactance .....	99
499	Table 212 – Attributes of EquipmentReliabilityProfile::Seconds .....	99
500	Table 213 – Attributes of EquipmentReliabilityProfile::VoltagePerReactivePower .....	99
501		



## 1 Introduction

The equipment reliability profile enables exchanges of additional information related to equipment as well as SIPS, limits, area and overlapping zone.

## 2 Application profile specification

### 2.1 Version information

The content is generated from UML model file CIM100\_CGMES31v01\_501-20v02\_NC21v47\_MM10v01.eap.

This edition is based on the IEC 61970 UML version 'IEC61970CIM17v40', dated '2020-08-24'.

- Title: Equipment Reliability Vocabulary
- Keyword: ER
- Description: This vocabulary is describing the equipment reliability profile.
- Version IRI: <http://entsoe.eu/ns/CIM/EquipmentReliability-EU/1.0>
- Version info: 1.0.0
- Prior version:
- Conforms to: urn:iso:std:iec:61970-600-2:ed-1|urn:iso:std:iec:61970-301:ed-7:amd1|file:///iec61970cim17v40\_iec61968cim13v13a\_iec62325cim03v17a.eap|urn:iso:std:iec:61970-401:draft:ed-1|urn:iso:std:iec:61970-501:draft:ed-2|file:///CGMES-30v25\_501-20v01.eap
- Identifier: urn:uuid:5f727c5c-b49f-47be-b750-a00fefb7e806

### 2.2 Constraints naming convention

The naming of the rules shall not be used for machine processing. The rule names are just a string. The naming convention of the constraints is as follows.

"{rule.Type}:{rule.Standard}:{rule.Profile}:{rule.Property}:{rule.Name}"

where

rule.Type: C – for constraint; R – for requirement

rule.Standard: the number of the standard e.g. 301 for 61970-301, 456 for 61970-456, 13 for 61968-13. 61970-600 specific constraints refer to 600 although they are related to one or combination of the 61970-450 series profiles. For NC profiles, NC is used.

rule.Profile: the abbreviation of the profile, e.g. TP for Topology profile. If set to "ALL" the constraint is applicable to all IEC 61970-600 profiles.

rule.Property: for UML classes, the name of the class, for attributes and associations, the name of the class and attribute or association end, e.g. EnergyConsumer, IdentifiedObject.name, etc. If set to "NA" the property is not applicable to a specific UML element.

rule.Name: the name of the rule. It is unique for the same property.

Example: C:600:ALL:IdentifiedObject.name:stringLength

**2.3 Profile constraints**

This clause defines requirements and constraints that shall be fulfilled by applications that conform to this document.

This document is the master for rules and constraints tagged "NC". For the sake of self-containment, the list below also includes a copy of the relevant rules from IEC 61970-452, tagged "452".

- C:452:ALL:NA:datatypes

According to 61970-501, datatypes are not exchanged in the instance data. The UnitMultiplier is 1 in cases none value is specified in the profile.

- R:452:ALL:NA:exchange

Optional and required attributes and associations must be imported and exported if they are in the model file prior to import.

- R:452:ALL:NA:exchange1

If an optional attribute does not exist in the imported file, it does not have to be exported in case exactly the same data set is exported, i.e. the tool is not obliged to automatically provide this attribute. If the export is resulting from an action by the user performed after the import, e.g. data processing or model update the export can contain optional attributes.

- R:452:ALL:NA:exchange2

In most of the profiles the selection of optional and required attributes is made so as to ensure a minimum set of required attributes without which the exchange does not fulfil its basic purpose. Business processes governing different exchanges can require mandatory exchange of certain optional attributes or associations. Optional and required attributes and associations shall therefore be supported by applications which claim conformance with certain functionalities of the IEC 61970-452. This provides flexibility for the business processes to adapt to different business requirements and base the exchanges on IEC 61970-452 compliant applications.

- R:452:ALL:NA:exchange3

An exporter may, at his or her discretion, produce a serialization containing additional class data described by the CIM Schema but not required by this document provided these data adhere to the conventions established in Clause 5.

- R:452:ALL:NA:exchange4

From the standpoint of the model import used by a data recipient, the document describes a subset of the CIM that importing software shall be able to interpret in order to import exported models. Data providers are free to exceed the minimum requirements described herein as long as their resulting data files are compliant with the CIM Schema and the conventions established in Clause 5. The document, therefore, describes additional classes and class data that, although not required, exporters will, in all likelihood, choose to include in their data files. The additional classes and data are labelled as required (cardinality 1..1) or as optional (cardinality 0..1) to distinguish them from their required counterparts. Please note, however, that data importers could potentially receive data containing instances of any and all classes described by the CIM Schema.

- R:452:ALL:NA:cardinality



582 The cardinality defined in the CIM model shall be followed, unless a more restrictive  
583 cardinality is explicitly defined in this document. For instance, the cardinality on the  
584 association between VoltageLevel and BaseVoltage indicates that a VoltageLevel shall  
585 be associated with one and only one BaseVoltage, but a BaseVoltage can be associated  
586 with zero to many VoltageLevels.

- 587 • R:452:ALL:NA:associations

588 Associations between classes referenced in this document and classes not referenced  
589 here are not required regardless of cardinality.

- 590 • R:452:ALL:IdentifiedObject.name:rule

591 The attribute “name” inherited by many classes from the abstract class IdentifiedObject  
592 is not required to be unique. It must be a human readable identifier without additional  
593 embedded information that would need to be parsed. The attribute is used for purposes  
594 such as User Interface and data exchange debugging. The MRID defined in the data  
595 exchange format is the only unique and persistent identifier used for this data exchange.  
596 The attribute IdentifiedObject.name is, however, always required for CoreEquipment  
597 profile and Short Circuit profile.

- 598 • R:452:ALL:IdentifiedObject.description:rule

599 The attribute “description” inherited by many classes from the abstract class  
600 IdentifiedObject must contain human readable text without additional embedded  
601 information that would need to be parsed.

- 602 • R:452:ALL:NA:uniqueIdentifier

603 All IdentifiedObject-s shall have a persistent and globally unique identifier (Master  
604 Resource Identifier - mRID).

- 605 • R:452:ALL:NA:unitMultiplier

606 For exchange of attributes defined using CIM Data Types (ActivePower, Susceptance,  
607 etc.) a unit multiplier of 1 is used if the UnitMultiplier specified in this document is “none”.

- 608 • C:452:ALL:IdentifiedObject.name:stringLength

609 The string IdentifiedObject.name has a maximum of 128 characters.

- 610 • C:452:ALL:IdentifiedObject.description:stringLength

611 The string IdentifiedObject.description is maximum 256 characters.

- 612 • C:452:ALL:NA:float

613 An attribute that is defined as float (e.g. has a type Float or a type which is a Datatype  
614 with .value attribute of type Float) shall support ISO/IEC 60559:2020 for floating-point  
615 arithmetic using single precision floating point. A single precision float supports 7  
616 significant digits where the significant digits are described as an integer, or a decimal  
617 number with 6 decimal digits. Two float values are equal when the significant with 7  
618 digits are identical, e.g. 1234567 is equal 1.234567E6 and so are 1.2345678 and  
619 1.234567E0.

- 620 • R:NC:ER:AreaDispatchableUnit:hvdclnterconnection

621 In cases where the generating unit is dispatched behind HVDC interconnection  
622 (DCTieCorridor) in order to have an explicit modelling of the relationship between the  
623 generating unit and the HVDC interconnection, the following is recommended:

- 624       ○ The AreaDispatchableUnit shall refer to both DCTieCorridor and the  
625       GeneratingUnit (providing the dispatch capability).
- 626       ○ DCTieCorridor where the capability is provided through.

- 627       • C:NC:ER:AreaDispatchableUnit:associations

628 The AreaDispatchableUnit shall be associated with either GeneratingUnit or  
629 PowerElectronicsUnit.

- 630       • C:NC:ER:EnergyComponent:associations

631 The EnergyComponent shall be associated with either GeneratingUnit,  
632 PowerElectronicsUnit or EnergyConsumer.

## 633 2.4 Metadata

634 ENTSO-E agreed to extend the header and metadata definitions by IEC 61970-552 Ed2. This  
635 new header definitions rely on W3C recommendations which are used worldwide and are  
636 positively recognised by the European Commission. The new definitions of the header mainly  
637 use Provenance ontology (PROV-O), Time Ontology and Data Catalog Vocabulary (DCAT). The  
638 global new header applicable for this profile is included in the metadata and document header  
639 specification document.

640 The header vocabulary contains all attributes defined in IEC 61970-552. This is done only for  
641 the purpose of having one vocabulary for header and to ensure transition for data exchanges  
642 that are using IEC 61970-552:2016 header. This profile does not use IEC 61970-552:2016  
643 header attributes and relies only on the extended attributes.

### 644 2.4.1 Constraints

645 The identification of the constraints related to the metadata follows the same convention for  
646 naming of the constraints as for profile constraints.

- 647       • R:NC:ALL:wasAttributedTo:usage

648 The prov:wasAttributedTo should normally be the “X” EIC code of the actor (prov:Agent).

649


### 650 2.4.2 Reference metadata

651 The header defined for this profile requires availability of a set of reference metadata. For  
652 instance, the attribute prov:wasGeneratedBy requires a reference to an activity which produced  
653 the model or the related process. The activities are defined as reference metadata and their  
654 identifiers are referenced from the header to enable the receiving entity to retrieve the “static”  
655 (reference) information that it is not modified frequently. This approach imposes a requirement  
656 that both the sending entity and the receiving entity have access to a unique version of the  
657 reference metadata. Therefore, each business process shall define which reference metadata  
658 is used and where it is located.

## 659 3 Detailed Profile Specification

### 660 3.1 General

661 This package contains equipment reliability profile.




**Figure 1 – Class diagram EquipmentReliabilityProfile::Core**

Figure 1: The diagram shows classes from Base CIM used in the profile.

Figure 2: The diagram shows direct current related classes.

[illegible]

Figure 3:



**Figure 4 – Class diagram EquipmentReliabilityProfile::EquipmentReliabilityDatatypes**

Figure 4: The diagram shows datatypes that are used by classes in the profile. Stereotypes are used to describe the datatypes. The following stereotypes are defined:

<<enumeration>> A list of permissible constant values.

<<Primitive>> The most basic data types used to compose all other data types.

<<CIMDatatype>> A datatype that contains a value attribute, an optional unit of measure and a unit multiplier. The unit and multiplier may be specified as a static variable initialized to the allowed value.

<<Compound>> A composite of Primitive, enumeration, CIMDatatype or other Compound classes, as long as the Compound classes do not recurse.

For all datatypes both positive and negative values are allowed unless stated otherwise for a particular datatype.




Figure 5 – Class diagram EquipmentReliabilityProfile::FACTS

Figure 5: The diagram shows FACTS related classes.






Figure 6 – Class diagram EquipmentReliabilityProfile::GLSK

Figure 6: The diagram shows generation and load shift keys related classes.



**Figure 7 – Class diagram EquipmentReliabilityProfile::PowerSystemOrganizationRole**


Figure 7: The diagram shows power system organisation role related classes.



**Figure 8 – Class diagram EquipmentReliabilityProfile::PowerTransferCorridor**




695 Figure 8: The diagram shows power transfer corridor related classes.



696

697 **Figure 9 – Class diagram EquipmentReliabilityProfile::Production**

698 Figure 9: The diagram shows production related classes.



**Figure 10 – Class diagram EquipmentReliabilityProfile::ReliabilityLimits**

Figure 10: The diagram contains main classes related to the reliability limits.

### 3.2 (abstract) ACDCTerminal

Inheritance path = [IdentifiedObject](#)

An electrical connection point (AC or DC) to a piece of conducting equipment. Terminals are connected at physical connection points called connectivity nodes.

Table 1 shows all attributes of ACDCTerminal.

**Table 1 – Attributes of EquipmentReliabilityProfile::ACDCTerminal**

name	mult	type	description
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

### 3.3 (NC) ActivePowerControlFunction

Inheritance path = [ControlFunctionBlock](#) : [FunctionBlock](#) : [IdentifiedObject](#)

Active power control function is a function block that calculate the controlled equipment operation point to archive the target active power.

Table 2 shows all attributes of ActivePowerControlFunction.

**Table 2 – Attributes of EquipmentReliabilityProfile::ActivePowerControlFunction**

name	mult	type	description
isDiscrete	1..1	<a href="#">Boolean</a>	(NC) inherited from: <a href="#">ControlFunctionBlock</a>
targetDeadband	0..1	<a href="#">Float</a>	(NC) inherited from: <a href="#">ControlFunctionBlock</a>
maxAllowedTargetValue	0..1	<a href="#">PerCent</a>	(NC) inherited from: <a href="#">ControlFunctionBlock</a>
minAllowedTargetValue	0..1	<a href="#">PerCent</a>	(NC) inherited from: <a href="#">ControlFunctionBlock</a>
priority	0..1	<a href="#">Integer</a>	(NC) inherited from: <a href="#">FunctionBlock</a>
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 3 shows all association ends of ActivePowerControlFunction with other classes.

**Table 3 – Association ends of EquipmentReliabilityProfile::ActivePowerControlFunction with other classes**

mult from	name	mult to	type	description
0..*	AutomationFunction	0..1	<a href="#">AutomationFunction</a>	(NC) inherited from: <a href="#">FunctionBlock</a>
1..1	FunctionOutputVariable	1..*	<a href="#">FunctionOutputVariable</a>	(NC) inherited from: <a href="#">FunctionBlock</a>

### 3.4 (NC) AmbientTemperatureDependencyCurve

Inheritance path = [LimitDependencyCurve](#) : [Curve](#)

A curve or functional relationship between the ambient temperature independent variable (X-axis) and relative temperature dependent (Y-axis) variables.

Table 4 shows all attributes of AmbientTemperatureDependencyCurve.

**Table 4 – Attributes of EquipmentReliabilityProfile::AmbientTemperatureDependencyCurve**

name	mult	type	description
curveStyle	1..1	<a href="#">CurveStyle</a>	inherited from: <a href="#">Curve</a>
xMultiplier	0..1	<a href="#">UnitMultiplier</a>	inherited from: <a href="#">Curve</a>
xUnit	1..1	<a href="#">UnitSymbol</a>	inherited from: <a href="#">Curve</a>
y1Multiplier	0..1	<a href="#">UnitMultiplier</a>	inherited from: <a href="#">Curve</a>
y1Unit	0..1	<a href="#">UnitSymbol</a>	inherited from: <a href="#">Curve</a>

### 3.5 (NC) AreaDispatchableUnit root class

Allocates a given producing or consuming unit, including direct current corridor and collection of units, to a given control area (through the scheduling area) for supporting the control of the given area through dispatch instruction.

Table 5 shows all attributes of AreaDispatchableUnit.

**Table 5 – Attributes of EquipmentReliabilityProfile::AreaDispatchableUnit**

name	mult	type	description
normalEnabled	0..1	<a href="#">Boolean</a>	(NC) Identifies if the unit is normally enabled to accept a dispatch instruction. If true, the unit is

name	mult	type	description
			enabled to accept a dispatch instruction. If false, the unit has the capability, but it is not enabled to receive a dispatch instruction.

Table 6 shows all association ends of AreaDispatchableUnit with other classes.

**Table 6 – Association ends of EquipmentReliabilityProfile::AreaDispatchableUnit with other classes**

mult from	name	mult to	type	description
0..*	PowerElectronicsUnit	0..1	<a href="#">PowerElectronicsUnit</a>	(NC) The power electronics unit that belongs to this area dispatchable unit.
0..*	ScheduleResource	0..1	<a href="#">ScheduleResource</a>	(NC) The resource which is mFRR for the EnergySchedulingArea to which the AreaDispatchableUnit is connected. Note that this can be different than the area for the energy schedule.
0..*	SchedulingArea	1..1	<a href="#">SchedulingArea</a>	(NC) The scheduling area that has this area dispatchable unit.
0..*	GeneratingUnit	0..1	<a href="#">GeneratingUnit</a>	(NC) The generating unit that belongs to area dispatchable unit.

### 3.6 (abstract,NC) AutomationFunction

Inheritance path = [PowerSystemResource](#) : [IdentifiedObject](#)

Automation function is a collection of functional block or other automation function that can be executed as a work cycle program as part of an automated system.

Table 7 shows all attributes of AutomationFunction.

**Table 7 – Attributes of EquipmentReliabilityProfile::AutomationFunction**

name	mult	type	description
type	0..1	<a href="#">String</a>	(NC) Type of automation function.
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 8 shows all association ends of AutomationFunction with other classes.

**Table 8 – Association ends of EquipmentReliabilityProfile::AutomationFunction with other classes**

mult from	name	mult to	type	description
0..*	PartOf	0..1	<a href="#">AutomationFunction</a>	(NC) Automation function is part of this automation function.

### 3.7 (NC) BaseOverloadLimitCurve

Inheritance path = [LimitDependencyCurve](#) : [Curve](#)

A curve or functional relationship between

- the relative loading - current loading over permanent loading (PATL) independent variable (X-axis), and

755 - temporary overloading (TATL) limiting dependent (Y-axis) variables.

756 Table 9 shows all attributes of BaseOverloadLimitCurve.

757 **Table 9 – Attributes of EquipmentReliabilityProfile::BaseOverloadLimitCurve**

name	mult	type	description
curveStyle	1..1	<a href="#">CurveStyle</a>	inherited from: <a href="#">Curve</a>
xMultiplier	0..1	<a href="#">UnitMultiplier</a>	inherited from: <a href="#">Curve</a>
xUnit	1..1	<a href="#">UnitSymbol</a>	inherited from: <a href="#">Curve</a>
y1Multiplier	0..1	<a href="#">UnitMultiplier</a>	inherited from: <a href="#">Curve</a>
y1Unit	0..1	<a href="#">UnitSymbol</a>	inherited from: <a href="#">Curve</a>

758

### 759 3.8 (NC) BiddingZone

760 Inheritance path = [PowerSystemResource](#) : [IdentifiedObject](#)

761 A bidding zone is a market-based method for handling power transmission congestion. It  
762 consists of scheduling areas that include the relevant production (supply) and consumption  
763 (demand) to form an electrical area with the same market price without capacity allocation.

764 Table 10 shows all attributes of BiddingZone.

765 **Table 10 – Attributes of EquipmentReliabilityProfile::BiddingZone**

name	mult	type	description
isTradeEnabled	1..1	<a href="#">Boolean</a>	(NC) Identifies the mechanism for determining the energy price for a given bidding zone. If true, the bid and the offer is expected to be provided for the bidding zone to create the market price. If false, other mechanism determines the price of energy for a given bidding zone, e.g. virtual bidding zone.
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

766

767 Table 11 shows all association ends of BiddingZone with other classes.

768 **Table 11 – Association ends of EquipmentReliabilityProfile::BiddingZone with other**  
769 **classes**

mult from	name	mult to	type	description
0..*	CapacityCalculationRegion	0..1	<a href="#">CapacityCalculationRegion</a>	(NC) The capacity calculation region related to this bidding zone.

770

### 771 3.9 (NC) BiddingZoneBorder

772 Inheritance path = [PowerSystemResource](#) : [IdentifiedObject](#)

773 Defines the aggregated connection capacity between two Bidding Zones.

774 Table 12 shows all attributes of BiddingZoneBorder.

**Table 12 – Attributes of EquipmentReliabilityProfile::BiddingZoneBorder**

name	mult	type	description
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 13 shows all association ends of BiddingZoneBorder with other classes.

**Table 13 – Association ends of EquipmentReliabilityProfile::BiddingZoneBorder with other classes**

mult from	name	mult to	type	description
1..*	BiddingZoneOne	1..1	<a href="#">BiddingZone</a>	(NC) The bidding zone for the primary side.
0..*	BiddingZoneTwo	1..1	<a href="#">BiddingZone</a>	(NC) The bidding zone for the secondary side.
0..*	CapacityCalculationRegion	0..1	<a href="#">CapacityCalculationRegion</a>	(NC) The capacity calculation region for which the capacity is derived from.

### 3.10 (NC) CapacityCalculationRegion

Inheritance path = [Region](#) : [PowerSystemResource](#) : [IdentifiedObject](#)

Capacity calculation region is a coherent part of the interconnected system that is used for calculating the transmission capacity for a bidding zone or between bidding zones.

Table 14 shows all attributes of CapacityCalculationRegion.

**Table 14 – Attributes of EquipmentReliabilityProfile::CapacityCalculationRegion**

name	mult	type	description
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 15 shows all association ends of CapacityCalculationRegion with other classes.

**Table 15 – Association ends of EquipmentReliabilityProfile::CapacityCalculationRegion with other classes**

mult from	name	mult to	type	description
0..*	SecurityCoordinator	0..1	<a href="#">SecurityCoordinator</a>	(NC) The security coordinator responsible for the capacity calculation region.

### 3.11 (NC) ChargingUnit

Inheritance path = [PowerElectronicsUnit](#) : [Equipment](#) : [PowerSystemResource](#) : [IdentifiedObject](#)

An unit that supplies electrical power for charging electrical non-stationary entities, e.g. electrical vehicle, trucks, buses, ferries, boat and airplanes. The characteristic is that the energy consumption is highly schedule dependent.  
Table 16 shows all attributes of ChargingUnit.

**Table 16 – Attributes of EquipmentReliabilityProfile::ChargingUnit**

name	mult	type	description
longPF	0..1	<a href="#">Float</a>	(NC) inherited from: <a href="#">PowerElectronicsUnit</a>
maxEconomicP	0..1	<a href="#">ActivePower</a>	(NC) inherited from: <a href="#">PowerElectronicsUnit</a>
minEconomicP	0..1	<a href="#">ActivePower</a>	(NC) inherited from: <a href="#">PowerElectronicsUnit</a>
shortPF	0..1	<a href="#">Float</a>	(NC) inherited from: <a href="#">PowerElectronicsUnit</a>
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 17 shows all association ends of ChargingUnit with other classes.

**Table 17 – Association ends of EquipmentReliabilityProfile::ChargingUnit with other classes**

mult from	name	mult to	type	description
0..*	ScheduleResource	0..1	<a href="#">ScheduleResource</a>	(NC) inherited from: <a href="#">PowerElectronicsUnit</a>
1..*	Circuit	0..1	<a href="#">Circuit</a>	(NC) inherited from: <a href="#">Equipment</a>
0..*	AggregatedEquipment	0..1	<a href="#">Equipment</a>	(NC) inherited from: <a href="#">Equipment</a>

### 3.12 (abstract,NC) Circuit

Inheritance path = [PowerSystemResource](#) : [IdentifiedObject](#)

A circuit is a collection of equipment in a network graph that provide common stability limits. The relevant equipment is in general given by the identifying terminal. A software application that can do topology processing shall calculate the equipment belonging to the circuit, if there are no stability limits associated to it. In case of stability limits, the containment reflects the equipments that were used in the calculation/analysis.

Table 18 shows all attributes of Circuit.

**Table 18 – Attributes of EquipmentReliabilityProfile::Circuit**

name	mult	type	description
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 19 shows all association ends of Circuit with other classes.

**Table 19 – Association ends of EquipmentReliabilityProfile::Circuit with other classes**

mult from	name	mult to	type	description
0..*	CircuitShare	0..1	<a href="#">CircuitShare</a>	(NC) The share of this circuit.

**3.13 (NC) CircuitShare**

Inheritance path = [IdentifiedObject](#)

Defines the share of the circuit which is part of this power transfer corridor.

Table 20 shows all attributes of CircuitShare.

**Table 20 – Attributes of EquipmentReliabilityProfile::CircuitShare**

name	mult	type	description
normalContributionFactor	0..1	<a href="#">PerCent</a>	(NC) Normal contribution factor for the circuit which is part of a power transfer corridor.
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 21 shows all association ends of CircuitShare with other classes.

**Table 21 – Association ends of EquipmentReliabilityProfile::CircuitShare with other classes**

mult from	name	mult to	type	description
0..*	PowerTransferCorridor	1..1	<a href="#">PowerTransferCorridor</a>	(NC) The power transfer corridor that has this circuit share.

**3.14 (NC) ClosedDistributionSystemOperator**

Inheritance path = [SystemOperator](#) : [PowerSystemOrganisationRole](#) : [OrganisationRole](#) : [IdentifiedObject](#)

A system operator which distributes electricity (or gas) within a geographically confined industrial, commercial or shared services and does not supply household customers.

Table 22 shows all attributes of ClosedDistributionSystemOperator.

**Table 22 – Attributes of EquipmentReliabilityProfile::ClosedDistributionSystemOperator**

name	mult	type	description
globalLocationNumber	0..1	<a href="#">String</a>	(NC) inherited from: <a href="#">OrganisationRole</a>
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 23 shows all association ends of ClosedDistributionSystemOperator with other classes.



**Table 23 – Association ends of EquipmentReliabilityProfile::ClosedDistributionSystemOperator with other classes**

mult from	name	mult to	type	description
0..*	Organisation	0..1	<a href="#">Organisation</a>	inherited from: <a href="#">OrganisationRole</a>

### 3.15 (NC) CompensatorController

Inheritance path = [EquipmentController](#) : [AutomationFunction](#) : [PowerSystemResource](#) : [IdentifiedObject](#)

Compensator controller is controlling the equipment to optimize the use of the compensators. Table 24 shows all attributes of CompensatorController.

**Table 24 – Attributes of EquipmentReliabilityProfile::CompensatorController**

name	mult	type	description
type	0..1	<a href="#">String</a>	(NC) inherited from: <a href="#">AutomationFunction</a>
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 25 shows all association ends of CompensatorController with other classes.

**Table 25 – Association ends of EquipmentReliabilityProfile::CompensatorController with other classes**

mult from	name	mult to	type	description
0..*	PartOf	0..1	<a href="#">AutomationFunction</a>	(NC) inherited from: <a href="#">AutomationFunction</a>

### 3.16 (abstract) ConductingEquipment

Inheritance path = [Equipment](#) : [PowerSystemResource](#) : [IdentifiedObject](#)

The parts of the AC power system that are designed to carry current or that are conductively connected through terminals.

Table 26 shows all attributes of ConductingEquipment.

**Table 26 – Attributes of EquipmentReliabilityProfile::ConductingEquipment**

name	mult	type	description
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 27 shows all association ends of ConductingEquipment with other classes.

**Table 27 – Association ends of EquipmentReliabilityProfile::ConductingEquipment with other classes**

mult from	name	mult to	type	description
1..*	Circuit	0..1	<a href="#">Circuit</a>	(NC) inherited from: <a href="#">Equipment</a>
0..*	AggregatedEquipment	0..1	<a href="#">Equipment</a>	(NC) inherited from: <a href="#">Equipment</a>

**3.17 (abstract) ConnectivityNodeContainer**

Inheritance path = [PowerSystemResource](#) : [IdentifiedObject](#)

A base class for all objects that may contain connectivity nodes or topological nodes.

Table 28 shows all attributes of ConnectivityNodeContainer.

**Table 28 – Attributes of EquipmentReliabilityProfile::ConnectivityNodeContainer**

name	mult	type	description
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

**3.18 (Description) ControlArea**

Inheritance path = [PowerSystemResource](#) : [IdentifiedObject](#)

A control area is a grouping of generating units and/or loads and a cutset of tie lines (as terminals) which may be used for a variety of purposes including automatic generation control, power flow solution area interchange control specification, and input to load forecasting. All generation and load within the area defined by the terminals on the border are considered in the area interchange control. Note that any number of overlapping control area specifications can be superimposed on the physical model. The following general principles apply to ControlArea:

1. The control area orientation for net interchange is positive for an import, negative for an export.
2. The control area net interchange is determined by summing flows in Terminals. The Terminals are identified by creating a set of TieFlow objects associated with a ControlArea object. Each TieFlow object identifies one Terminal.
3. In a single network model, a tie between two control areas must be modelled in both control area specifications, such that the two representations of the tie flow sum to zero.
4. The normal orientation of Terminal flow is positive for flow into the conducting equipment that owns the Terminal. (i.e. flow from a bus into a device is positive.) However, the orientation of each flow in the control area specification must align with the control area convention, i.e. import is positive. If the orientation of the Terminal flow referenced by a TieFlow is positive into the control area, then this is confirmed by setting TieFlow.positiveFlowIn flag TRUE. If not, the orientation must be reversed by setting the TieFlow.positiveFlowIn flag FALSE.

Table 29 shows all attributes of ControlArea.

**Table 29 – Attributes of EquipmentReliabilityProfile::ControlArea**

name	mult	type	description
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

name	mult	type	description
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 30 shows all association ends of ControlArea with other classes.

**Table 30 – Association ends of EquipmentReliabilityProfile::ControlArea with other classes**

mult from	name	mult to	type	description
0..*	SystemOperator	0..1	<a href="#">SystemOperator</a>	(NC) The system operator that operates this control area.
0..*	OutageCoordinationRegion	0..1	<a href="#">OutageCoordinationRegion</a>	(NC) The outage coordination region that has this control area.

### 3.19 (abstract,NC) ControlFunctionBlock

Inheritance path = [FunctionBlock](#) : [IdentifiedObject](#)

Control function block is a function block that contain algorithm for controlling equipment.

Table 31 shows all attributes of ControlFunctionBlock.

**Table 31 – Attributes of EquipmentReliabilityProfile::ControlFunctionBlock**

name	mult	type	description
isDiscrete	1..1	<a href="#">Boolean</a>	(NC) True, if the control function is discrete. This applies to equipment with discrete controls, e.g. tap changers and shunt compensators.
targetDeadband	0..1	<a href="#">Float</a>	(NC) Target deadband is used with discrete control to avoid excessive update of controls like tap changers and shunt compensator banks while regulating. The attribute shall be a positive value or zero. If isDiscrete is set to "false", the targetDeadband is to be ignored. Note that for instance, if the targetValue is 100 kV and the targetDeadband is 2 kV the range is from 99 to 101 kV.
maxAllowedTargetValue	0..1	<a href="#">PerCent</a>	(NC) Maximum allowed target value given by the percent of target value.
minAllowedTargetValue	0..1	<a href="#">PerCent</a>	(NC) Minimum allowed target value given by the percent of target value.
priority	0..1	<a href="#">Integer</a>	(NC) inherited from: <a href="#">FunctionBlock</a>
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 32 shows all association ends of ControlFunctionBlock with other classes.

**Table 32 – Association ends of EquipmentReliabilityProfile::ControlFunctionBlock with other classes**

mult from	name	mult to	type	description
0..*	AutomationFunction	0..1	<a href="#">AutomationFunction</a>	(NC) inherited from: <a href="#">FunctionBlock</a>
1..1	FunctionOutputVariable	1..*	<a href="#">FunctionOutputVariable</a>	(NC) inherited from: <a href="#">FunctionBlock</a>

**3.20 (abstract) Curve root class**

A multi-purpose curve or functional relationship between an independent variable (X-axis) and dependent (Y-axis) variables.

Table 33 shows all attributes of Curve.

**Table 33 – Attributes of EquipmentReliabilityProfile::Curve**

name	mult	type	description
curveStyle	1..1	<a href="#">CurveStyle</a>	The style or shape of the curve.
xMultiplier	0..1	<a href="#">UnitMultiplier</a>	Multiplier for X-axis.
xUnit	1..1	<a href="#">UnitSymbol</a>	The X-axis units of measure.
y1Multiplier	0..1	<a href="#">UnitMultiplier</a>	Multiplier for Y1-axis.
y1Unit	0..1	<a href="#">UnitSymbol</a>	The Y1-axis units of measure.

**3.21 CurveData root class**

Multi-purpose data points for defining a curve. The use of this generic class is discouraged if a more specific class can be used to specify the X and Y axis values along with their specific data types.

Table 34 shows all attributes of CurveData.

**Table 34 – Attributes of EquipmentReliabilityProfile::CurveData**

name	mult	type	description
xvalue	1..1	<a href="#">Float</a>	The data value of the X-axis variable, depending on the X-axis units.
y1value	1..1	<a href="#">Float</a>	The data value of the first Y-axis variable, depending on the Y-axis units.

Table 35 shows all association ends of CurveData with other classes.

**Table 35 – Association ends of EquipmentReliabilityProfile::CurveData with other classes**

mult from	name	mult to	type	description
1..*	Curve	1..1	<a href="#">Curve</a>	The curve of this curve data point.

**3.22 (Description) DCConverterUnit**

Inheritance path = [DCEquipmentContainer](#) : [EquipmentContainer](#) : [ConnectivityNodeContainer](#) : [PowerSystemResource](#) : [IdentifiedObject](#)

Indivisible operative unit comprising all equipment between the point of common coupling on the AC side and the point of common coupling – DC side, essentially one or more converters, together with one or more converter transformers, converter control equipment, essential protective and switching devices and auxiliaries, if any, used for conversion.

Table 36 shows all attributes of DCConverterUnit.

**Table 36 – Attributes of EquipmentReliabilityProfile::DCConverterUnit**

name	mult	type	description
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

name	mult	type	description
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 37 shows all association ends of DCConverterUnit with other classes.

**Table 37 – Association ends of EquipmentReliabilityProfile::DCConverterUnit with other classes**

mult from	name	mult to	type	description
0..2	DCPole	0..1	<a href="#">DCPole</a>	(NC) The DC pole that has this DC converter unit.
0..*	Substation	0..1	<a href="#">Substation</a>	The containing substation of the DC converter unit.

### 3.23 (NC) DCController

Inheritance path = [PowerSystemResource](#) : [IdentifiedObject](#)

The direct current controller providing the power regulation setpoint for one or more direct current poles.

Table 38 shows all attributes of DCController.

**Table 38 – Attributes of EquipmentReliabilityProfile::DCController**

name	mult	type	description
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

### 3.24 (abstract) DCEquipmentContainer

Inheritance path = [EquipmentContainer](#) : [ConnectivityNodeContainer](#) : [PowerSystemResource](#) : [IdentifiedObject](#)

A modelling construct to provide a root class for containment of DC as well as AC equipment. The class differ from the EquipmentContainer for AC in that it may also contain DCNode-s. Hence it can contain both AC and DC equipment.

Table 39 shows all attributes of DCEquipmentContainer.

**Table 39 – Attributes of EquipmentReliabilityProfile::DCEquipmentContainer**

name	mult	type	description
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

### 3.25 (abstract) DCLine

Inheritance path = [DCEquipmentContainer](#) : [EquipmentContainer](#) : [ConnectivityNodeContainer](#) : [PowerSystemResource](#) : [IdentifiedObject](#)

Overhead lines and/or cables connecting two or more HVDC substations.

958 Table 40 shows all attributes of DCLine.

959 **Table 40 – Attributes of EquipmentReliabilityProfile::DCLine**

name	mult	type	description
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

960

### 961 3.26 (NC) DCPole

962 Inheritance path = [PowerSystemResource](#) : [IdentifiedObject](#)

963 The direct current (DC) pole is the circuit which includes converter units from both sides and  
964 the relevant direct current line. This forms the smallest unit of transmission control.

965 Table 41 shows all attributes of DCPole.

966 **Table 41 – Attributes of EquipmentReliabilityProfile::DCPole**

name	mult	type	description
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

967

968 Table 42 shows all association ends of DCPole with other classes.

969 **Table 42 – Association ends of EquipmentReliabilityProfile::DCPole with other classes**

mult from	name	mult to	type	description
0..*	DCController	0..1	<a href="#">DCController</a>	(NC) This is the DCController for this Pole.
0..*	DCTieCorridor	0..1	<a href="#">DCTieCorridor</a>	(NC) The DCTieCorridor that has this DC pole.
0..*	SchedulingArea	0..1	<a href="#">SchedulingArea</a>	(NC) The scheduling area that has this DC pole.
0..1	DCLine	0..1	<a href="#">DCLine</a>	(NC) The DC line that is related to this DC pole.

970

### 971 3.27 (NC) DCTieCorridor

972 Inheritance path = [TieCorridor](#) : [PowerSystemResource](#) : [IdentifiedObject](#)

973 A collection of one or more direct current poles that connect to different control areas together.

974 Table 43 shows all attributes of DCTieCorridor.

975 **Table 43 – Attributes of EquipmentReliabilityProfile::DCTieCorridor**

name	mult	type	description
maxFRRlimit	0..1	<a href="#">ActivePower</a>	(NC) Maximum allocated limit for Frequency Restoration Reserve (FRR).
minFRRlimit	0..1	<a href="#">ActivePower</a>	(NC) Minimum allocated limit for Frequency Restoration Reserve (FRR).

name	mult	type	description
delayFRR	0..1	<a href="#">Seconds</a>	(NC) inherited from: <a href="#">TieCorridor</a>
maxFRRramp	0..1	<a href="#">Float</a>	(NC) inherited from: <a href="#">TieCorridor</a>
thresholdFRR	0..1	<a href="#">ActivePower</a>	(NC) inherited from: <a href="#">TieCorridor</a>
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 44 shows all association ends of DCTieCorridor with other classes.

**Table 44 – Association ends of EquipmentReliabilityProfile::DCTieCorridor with other classes**

mult from	name	mult to	type	description
0..*	AreaDispatchableUnit	0..1	<a href="#">AreaDispatchableUnit</a>	(NC) The AreaDispatchableUnit for the DCTieCorridor.

### 3.28 (NC) DirectCurrentController

Inheritance path = [EquipmentController](#) : [AutomationFunction](#) : [PowerSystemResource](#) : [IdentifiedObject](#)

Power flow controller for direct current that can be used in high-voltage direct current grids and for low-voltage direct current microgrids. It uses a high-frequency isolated dc-dc converter cascaded with a controllable full-bridge inverter that creates a small bipolar voltage in series with the line. The controller can control the power and compensate for accumulated voltage drop in a distribution line.

Table 45 shows all attributes of DirectCurrentController.

**Table 45 – Attributes of EquipmentReliabilityProfile::DirectCurrentController**

name	mult	type	description
type	0..1	<a href="#">String</a>	(NC) inherited from: <a href="#">AutomationFunction</a>
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 46 shows all association ends of DirectCurrentController with other classes.

**Table 46 – Association ends of EquipmentReliabilityProfile::DirectCurrentController with other classes**

mult from	name	mult to	type	description
0..*	PartOf	0..1	<a href="#">AutomationFunction</a>	(NC) inherited from: <a href="#">AutomationFunction</a>

### 3.29 (NC) DirectCurrentSystemOperator

Inheritance path = [SystemOperator](#) : [PowerSystemOrganisationRole](#) : [OrganisationRole](#) : [IdentifiedObject](#)

System operator of the direct current pole. There are typically one or two system operators that are operating either the control area at one side or the control areas at both sides of the direct current pole. In some cases it is operated by an operator from the connected control areas. Table 47 shows all attributes of DirectCurrentSystemOperator.

**Table 47 – Attributes of EquipmentReliabilityProfile::DirectCurrentSystemOperator**

name	mult	type	description
globalLocationNumber	0..1	<a href="#">String</a>	(NC) inherited from: <a href="#">OrganisationRole</a>
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 48 shows all association ends of DirectCurrentSystemOperator with other classes.

**Table 48 – Association ends of EquipmentReliabilityProfile::DirectCurrentSystemOperator with other classes**

mult from	name	mult to	type	description
0..*	Organisation	0..1	<a href="#">Organisation</a>	inherited from: <a href="#">OrganisationRole</a>

### 3.30 (NC) DistributionSystemOperator

Inheritance path = [SystemOperator](#) : [PowerSystemOrganisationRole](#) : [OrganisationRole](#) : [IdentifiedObject](#)

A system operator that is responsible for operating of energy distribution network from transmission level down to low voltage levels including the connection to household.

Table 49 shows all attributes of DistributionSystemOperator.

**Table 49 – Attributes of EquipmentReliabilityProfile::DistributionSystemOperator**

name	mult	type	description
globalLocationNumber	0..1	<a href="#">String</a>	(NC) inherited from: <a href="#">OrganisationRole</a>
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 50 shows all association ends of DistributionSystemOperator with other classes.

**Table 50 – Association ends of EquipmentReliabilityProfile::DistributionSystemOperator with other classes**

mult from	name	mult to	type	description
0..*	Organisation	0..1	<a href="#">Organisation</a>	inherited from: <a href="#">OrganisationRole</a>

### 3.31 (NC) DurationOverloadLimitCurve

Inheritance path = [LimitDependencyCurve](#) : [Curve](#)

A curve or functional relationship between



- 1024 - the overload duration independent variable (X-axis), and  
 1025 - temporary overloading (TATL) limiting dependent (Y-axis) variables.  
 1026 Table 51 shows all attributes of DurationOverloadLimitCurve.

1027 **Table 51 – Attributes of EquipmentReliabilityProfile::DurationOverloadLimitCurve**

name	mult	type	description
curveStyle	1..1	<a href="#">CurveStyle</a>	inherited from: <a href="#">Curve</a>
xMultiplier	0..1	<a href="#">UnitMultiplier</a>	inherited from: <a href="#">Curve</a>
xUnit	1..1	<a href="#">UnitSymbol</a>	inherited from: <a href="#">Curve</a>
y1Multiplier	0..1	<a href="#">UnitMultiplier</a>	inherited from: <a href="#">Curve</a>
y1Unit	0..1	<a href="#">UnitSymbol</a>	inherited from: <a href="#">Curve</a>

1028

### 1029 3.32 (NC) EnergyAlignmentCoordinator

1030 Inheritance path = [SystemOperationCoordinator](#) : [PowerSystemOrganisationRole](#) :  
 1031 [OrganisationRole](#) : [IdentifiedObject](#)

1032 A role that is responsible for alignment of forecast and schedule energy to a given energy  
 1033 coordination region.

1034 Table 52 shows all attributes of EnergyAlignmentCoordinator.

1035 **Table 52 – Attributes of EquipmentReliabilityProfile::EnergyAlignmentCoordinator**

name	mult	type	description
globalLocationNumber	0..1	<a href="#">String</a>	(NC) inherited from: <a href="#">OrganisationRole</a>
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

1036

1037 Table 53 shows all association ends of EnergyAlignmentCoordinator with other classes.

1038 **Table 53 – Association ends of**  
 1039 **EquipmentReliabilityProfile::EnergyAlignmentCoordinator with other classes**

mult from	name	mult to	type	description
0..*	Organisation	0..1	<a href="#">Organisation</a>	inherited from: <a href="#">OrganisationRole</a>

1040

### 1041 3.33 (NC) EnergyBlockComponent

1042 Inheritance path = [EnergyComponent](#) : [IdentifiedObject](#)

1043 The energy block component is an energy component where the energy group active power is  
 1044 distributed according to the energy block order of each energy component in an energy group.

1045 Table 54 shows all attributes of EnergyBlockComponent.

1046 **Table 54 – Attributes of EquipmentReliabilityProfile::EnergyBlockComponent**

name	mult	type	description
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

name	mult	type	description
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 55 shows all association ends of EnergyBlockComponent with other classes.

**Table 55 – Association ends of EquipmentReliabilityProfile::EnergyBlockComponent with other classes**

mult from	name	mult to	type	description
0..*	EnergyGroup	0..1	<a href="#">EnergyGroup</a>	(NC) inherited from: <a href="#">EnergyComponent</a>
0..*	HydroPump	0..1	<a href="#">HydroPump</a>	(NC) inherited from: <a href="#">EnergyComponent</a>
0..*	GeneratingUnit	0..1	<a href="#">GeneratingUnit</a>	(NC) inherited from: <a href="#">EnergyComponent</a>
0..*	EnergyConsumer	0..1	<a href="#">EnergyConsumer</a>	(NC) inherited from: <a href="#">EnergyComponent</a>
0..*	PowerElectronicsUnit	0..1	<a href="#">PowerElectronicsUnit</a>	(NC) inherited from: <a href="#">EnergyComponent</a>

### 3.34 (NC) EnergyBlockOrder

Inheritance path = [IdentifiedObject](#)

The energy block order is a block (an amount) of active power that forms the sequence of active power orders that are going to be distrusted to an energy block component.

Table 56 shows all attributes of EnergyBlockOrder.

**Table 56 – Attributes of EquipmentReliabilityProfile::EnergyBlockOrder**

name	mult	type	description
sequence	1..1	<a href="#">Integer</a>	(NC) The sequence order for a given block dispatch instruction. The sequence number need to be unique for a given block dispatch instruction, e.g. two order in the same instruction cannot have the same sequence.
longPF	0..1	<a href="#">Float</a>	(NC) Block order long term economic participation factor.
shortPF	0..1	<a href="#">Float</a>	(NC) Block order short term economic participation factor.
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 57 shows all association ends of EnergyBlockOrder with other classes.

**Table 57 – Association ends of EquipmentReliabilityProfile::EnergyBlockOrder with other classes**

mult from	name	mult to	type	description
1..*	EnergyBlockComponent	1..1	<a href="#">EnergyBlockComponent</a>	(NC) The energy block component that has this energy block order.

### 3.35 (abstract,NC) EnergyComponent

Inheritance path = [IdentifiedObject](#)

The energy component is an active power component for an energy producer or a consumer that has the same energy characteristic, e.g. fuel type and technology.  
Table 58 shows all attributes of EnergyComponent.

**Table 58 – Attributes of EquipmentReliabilityProfile::EnergyComponent**

name	mult	type	description
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 59 shows all association ends of EnergyComponent with other classes.

**Table 59 – Association ends of EquipmentReliabilityProfile::EnergyComponent with other classes**

mult from	name	mult to	type	description
0..*	EnergyGroup	0..1	<a href="#">EnergyGroup</a>	(NC) The energy group that has this energy component.
0..*	HydroPump	0..1	<a href="#">HydroPump</a>	(NC) The hydro pump that relates to this energy component.
0..*	GeneratingUnit	0..1	<a href="#">GeneratingUnit</a>	(NC) The generating unit that is part of this energy component.
0..*	EnergyConsumer	0..1	<a href="#">EnergyConsumer</a>	(NC) The energy consumer that relates to this energy component.
0..*	PowerElectronicsUnit	0..1	<a href="#">PowerElectronicsUnit</a>	(NC) The power electronics unit that relates to this energy component.

### 3.36 (abstract) EnergyConnection

Inheritance path = [ConductingEquipment](#) : [Equipment](#) : [PowerSystemResource](#) : [IdentifiedObject](#)

A connection of energy generation or consumption on the power system model.

Table 60 shows all attributes of EnergyConnection.

**Table 60 – Attributes of EquipmentReliabilityProfile::EnergyConnection**

name	mult	type	description
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 61 shows all association ends of EnergyConnection with other classes.

**Table 61 – Association ends of EquipmentReliabilityProfile::EnergyConnection with other classes**

mult from	name	mult to	type	description
1..*	Circuit	0..1	<a href="#">Circuit</a>	(NC) inherited from: <a href="#">Equipment</a>

mult from	name	mult to	type	description
0..*	AggregatedEquipment	0..1	<a href="#">Equipment</a>	(NC) inherited from: <a href="#">Equipment</a>

### 3.37 (Description) EnergyConsumer

Inheritance path = [EnergyConnection](#) : [ConductingEquipment](#) : [Equipment](#) : [PowerSystemResource](#) : [IdentifiedObject](#)

Generic user of energy - a point of consumption on the power system model.

EnergyConsumer.pfixed, .qfixed, .pfixedPct and .qfixedPct have meaning only if there is no

LoadResponseCharacteristic associated with EnergyConsumer or if

LoadResponseCharacteristic.exponentModel is set to False.

Table 62 shows all attributes of EnergyConsumer.

**Table 62 – Attributes of EquipmentReliabilityProfile::EnergyConsumer**

name	mult	type	description
longPF	0..1	<a href="#">Float</a>	(NC) Energy consumer long term economic participation factor.
maxEconomicP	0..1	<a href="#">ActivePower</a>	(NC) Maximum high economic active power limit, that should not exceed the maximum operating active power limit.
minEconomicP	0..1	<a href="#">ActivePower</a>	(NC) Low economic active power limit that shall be greater than or equal to the minimum operating active power limit.
shortPF	0..1	<a href="#">Float</a>	(NC) Energy consumer short term economic participation factor.
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 63 shows all association ends of EnergyConsumer with other classes.

**Table 63 – Association ends of EquipmentReliabilityProfile::EnergyConsumer with other classes**

mult from	name	mult to	type	description
1..*	Circuit	0..1	<a href="#">Circuit</a>	(NC) inherited from: <a href="#">Equipment</a>
0..*	AggregatedEquipment	0..1	<a href="#">Equipment</a>	(NC) inherited from: <a href="#">Equipment</a>

### 3.38 (NC) EnergyCoordinationRegion

Inheritance path = [Region](#) : [PowerSystemResource](#) : [IdentifiedObject](#)

A region that has a common organisation or a service that is responsible for alignment of forecast and scheduling of energy.

Table 64 shows all attributes of EnergyCoordinationRegion.

**Table 64 – Attributes of EquipmentReliabilityProfile::EnergyCoordinationRegion**

name	mult	type	description
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>

name	mult	type	description
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 65 shows all association ends of EnergyCoordinationRegion with other classes.

**Table 65 – Association ends of EquipmentReliabilityProfile::EnergyCoordinationRegion with other classes**

mult from	name	mult to	type	description
0..*	EnergyAlignmentCoordinator	0..1	<a href="#">EnergyAlignmentCoordinator</a>	(NC) The energy alignment coordinator that operates this energy coordination region.

### 3.39 (NC) EnergyGroup

Inheritance path = [PowerSystemResource](#) : [IdentifiedObject](#)

An energy group is an aggregation of energy components which have the same energy characteristic, e.g. fuel type and technology. It can be used to distribute forecast of a given energy characteristic.

Table 66 shows all attributes of EnergyGroup.

**Table 66 – Attributes of EquipmentReliabilityProfile::EnergyGroup**

name	mult	type	description
longPF	0..1	<a href="#">Float</a>	(NC) Energy group long term economic participation factor.
shortPF	0..1	<a href="#">Float</a>	(NC) Energy group short term economic participation factor.
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 67 shows all association ends of EnergyGroup with other classes.

**Table 67 – Association ends of EquipmentReliabilityProfile::EnergyGroup with other classes**

mult from	name	mult to	type	description
0..*	SchedulingArea	0..1	<a href="#">SchedulingArea</a>	(NC) The scheduling area that has this energy group.
0..*	EnergyType	0..1	<a href="#">EnergyTypeReference</a>	(NC) The energy type that the energy group are defined by.

### 3.40 (NC) EnergyTypeReference

Inheritance path = [IdentifiedObject](#)

An energy type reference refers to an energy characteristic that is needed for reporting, e.g. European Energy Certificate System (EECS). The kind of energy should be possible to be linked with different type of energy forecast, e.g. wind production for a given area based on wind forecast.

1128 Table 68 shows all attributes of EnergyTypeReference.

1129 **Table 68 – Attributes of EquipmentReliabilityProfile::EnergyTypeReference**

name	mult	type	description
energyKind	1..1	<a href="#">EnergyKind</a>	(NC) The kind of energy type.
reference	1..1	IRI	(NC) The reference IRI or URI to the energy type.
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

1130

### 1131 3.41 (Description) Equipment

1132 Inheritance path = [PowerSystemResource](#) : [IdentifiedObject](#)

1133 The parts of a power system that are physical devices, electronic or mechanical.

1134 Table 69 shows all attributes of Equipment.

1135 **Table 69 – Attributes of EquipmentReliabilityProfile::Equipment**

name	mult	type	description
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

1136

1137 Table 70 shows all association ends of Equipment with other classes.

1138 **Table 70 – Association ends of EquipmentReliabilityProfile::Equipment with other**  
1139 **classes**

mult from	name	mult to	type	description
1..*	Circuit	0..1	<a href="#">Circuit</a>	(NC) The circuit that contains its member equipment.
0..*	AggregatedEquipment	0..1	<a href="#">Equipment</a>	(NC) An aggregated representation of the detailed equipment.

1140

### 1141 3.42 (abstract) EquipmentContainer

1142 Inheritance path = [ConnectivityNodeContainer](#) : [PowerSystemResource](#) : [IdentifiedObject](#)

1143 A modelling construct to provide a root class for containing equipment.

1144 Table 71 shows all attributes of EquipmentContainer.

1145 **Table 71 – Attributes of EquipmentReliabilityProfile::EquipmentContainer**

name	mult	type	description
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

name	mult	type	description
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

### 3.43 (abstract,NC) EquipmentController

Inheritance path = [AutomationFunction](#) : [PowerSystemResource](#) : [IdentifiedObject](#)

Equipment controller is an automation function that can control one or multiple equipment function to archive all the targets inside the given tolerance.

Table 72 shows all attributes of EquipmentController.

**Table 72 – Attributes of EquipmentReliabilityProfile::EquipmentController**

name	mult	type	description
type	0..1	<a href="#">String</a>	(NC) inherited from: <a href="#">AutomationFunction</a>
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 73 shows all association ends of EquipmentController with other classes.

**Table 73 – Association ends of EquipmentReliabilityProfile::EquipmentController with other classes**

mult from	name	mult to	type	description
0..*	PartOf	0..1	<a href="#">AutomationFunction</a>	(NC) inherited from: <a href="#">AutomationFunction</a>

### 3.44 (NC) ExceptionalPowerTransferCorridor

Inheritance path = [PowerTransferCorridor](#) : [PowerSystemResource](#) : [IdentifiedObject](#)

Potential power transfer corridor that can be triggered by equipment which changes its in service status or it is operating in an island.

Table 74 shows all attributes of ExceptionalPowerTransferCorridor.

**Table 74 – Attributes of EquipmentReliabilityProfile::ExceptionalPowerTransferCorridor**

name	mult	type	description
normalEnabled	0..1	<a href="#">Boolean</a>	(NC) inherited from: <a href="#">PowerTransferCorridor</a>
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

### 3.45 (NC) FacilityPlantController

Inheritance path = [EquipmentController](#) : [AutomationFunction](#) : [PowerSystemResource](#) : [IdentifiedObject](#)

Facility plant controller is controlling the equipment to optimize the facility plant.

Table 75 shows all attributes of FacilityPlantController.

1170 **Table 75 – Attributes of EquipmentReliabilityProfile::FacilityPlantController**

name	mult	type	description
type	0..1	<a href="#">String</a>	(NC) inherited from: <a href="#">AutomationFunction</a>
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

1171  
1172 Table 76 shows all association ends of FacilityPlantController with other classes.

1173 **Table 76 – Association ends of EquipmentReliabilityProfile::FacilityPlantController with**  
1174 **other classes**

mult from	name	mult to	type	description
0..*	PartOf	0..1	<a href="#">AutomationFunction</a>	(NC) inherited from: <a href="#">AutomationFunction</a>

1175  
1176 **3.46 (abstract,NC) FACTSEquipment**

1177 Inheritance path = [RegulatingCondEq](#) : [EnergyConnection](#) : [ConductingEquipment](#) :  
1178 [Equipment](#) : [PowerSystemResource](#) : [IdentifiedObject](#)

1179 Flexible Alternating Current Transmission System regulating equipment.

1180 Table 77 shows all attributes of FACTSEquipment.

1181 **Table 77 – Attributes of EquipmentReliabilityProfile::FACTSEquipment**

name	mult	type	description
capacitiveRating	1..1	<a href="#">Reactance</a>	Capacitive reactance at maximum capacitive reactive power. Shall always be positive.
inductiveRating	1..1	<a href="#">Reactance</a>	Inductive reactance at maximum inductive reactive power. Shall always be negative.
slope	1..1	<a href="#">VoltagePerReactivePower</a>	The characteristics slope of an SVC defines how the reactive power output changes in proportion to the difference between the regulated bus voltage and the voltage setpoint. The attribute shall be a positive value or zero.
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

1182  
1183 Table 78 shows all association ends of FACTSEquipment with other classes.

1184 **Table 78 – Association ends of EquipmentReliabilityProfile::FACTSEquipment with**  
1185 **other classes**

mult from	name	mult to	type	description
0..*	EquipmentController	0..1	<a href="#">EquipmentController</a>	(NC) inherited from: <a href="#">RegulatingCondEq</a>
1..*	Circuit	0..1	<a href="#">Circuit</a>	(NC) inherited from: <a href="#">Equipment</a>
0..*	AggregatedEquipment	0..1	<a href="#">Equipment</a>	(NC) inherited from: <a href="#">Equipment</a>



1186

1187 **3.47 Feeder**

1188 Inheritance path = [EquipmentContainer](#) : [ConnectivityNodeContainer](#) : [PowerSystemResource](#) :  
 1189 [IdentifiedObject](#)

1190 A collection of equipment for organizational purposes, used for grouping distribution resources.

1191 The organization a feeder does not necessarily reflect connectivity or current operation state.

1192 Table 79 shows all attributes of Feeder.

1193

**Table 79 – Attributes of EquipmentReliabilityProfile::Feeder**

name	mult	type	description
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

1194

1195 Table 80 shows all association ends of Feeder with other classes.

1196 **Table 80 – Association ends of EquipmentReliabilityProfile::Feeder with other classes**

mult from	name	mult to	type	description
0..*	NormalEnergizingSubstation	0..1	<a href="#">Substation</a>	The substation that nominally energizes the feeder. Also used for naming purposes.
0..1	NamingSecondarySubstation	0..*	<a href="#">Substation</a>	The secondary substations that are normally energized from the feeder. Used for naming purposes. Should be consistent with the other associations for energizing terminal specification and the feeder energization specification.
0..*	SubSchedulingArea	0..1	<a href="#">SubSchedulingArea</a>	(NC) The subscheduling area that has this feeder.
0..*	NormalEnergizedSubstation	0..*	<a href="#">Substation</a>	The substations that are normally energized by the feeder.

1197

1198 **3.48 (NC) FlexibleEnergyUnit**

1199 Inheritance path = [PowerElectronicsUnit](#) : [Equipment](#) : [PowerSystemResource](#) :  
 1200 [IdentifiedObject](#)

1201 Flexible consumer or embedded producer of energy. The unit can not be a net producer.

1202 Table 81 shows all attributes of FlexibleEnergyUnit.

1203

**Table 81 – Attributes of EquipmentReliabilityProfile::FlexibleEnergyUnit**

name	mult	type	description
uncontrollable	0..1	<a href="#">ActivePower</a>	(NC) The effect, active power, that forms the base consumption for the unit. This is measured and expected consumption. Load sign convention is used, i.e. positive sign means flow out from a node.
timeShift	0..1	<a href="#">ActivePower</a>	(NC) The effect, active power, that can be shifted from one pricing interval (market time unit) to another. It is expected to be a limited on the length of the shift. Example from household could be washing machine or dishwasher. Example from industry is the possible to shut

name	mult	type	description
			down a machine for the relevant period. Load sign convention is used, i.e. positive sign means flow out from a node.
buffer	0..1	<a href="#">ActivePower</a>	(NC) The effect, active power, that has the flexibility to operate as production and/or consumption. The buffer is bound. Example are heat pump, cooling system, embedded batteries including electric vehicle. Load sign convention is used, i.e. positive sign means flow out from a node.
unconstrained	0..1	<a href="#">ActivePower</a>	(NC) The effect, active power, that has the flexibility to operate as production without any bound by a buffer. Example are alternative heating (wood, gas, diesel etc) or power generators. Load sign convention is used, i.e. positive sign means flow out from a node.
longPF	0..1	<a href="#">Float</a>	(NC) inherited from: <a href="#">PowerElectronicsUnit</a>
maxEconomicP	0..1	<a href="#">ActivePower</a>	(NC) inherited from: <a href="#">PowerElectronicsUnit</a>
minEconomicP	0..1	<a href="#">ActivePower</a>	(NC) inherited from: <a href="#">PowerElectronicsUnit</a>
shortPF	0..1	<a href="#">Float</a>	(NC) inherited from: <a href="#">PowerElectronicsUnit</a>
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 82 shows all association ends of FlexibleEnergyUnit with other classes.

**Table 82 – Association ends of EquipmentReliabilityProfile::FlexibleEnergyUnit with other classes**

mult from	name	mult to	type	description
0..*	ScheduleResource	0..1	<a href="#">ScheduleResource</a>	(NC) inherited from: <a href="#">PowerElectronicsUnit</a>
1..*	Circuit	0..1	<a href="#">Circuit</a>	(NC) inherited from: <a href="#">Equipment</a>
0..*	AggregatedEquipment	0..1	<a href="#">Equipment</a>	(NC) inherited from: <a href="#">Equipment</a>

### 3.49 (abstract,NC) FunctionBlock

Inheritance path = [IdentifiedObject](#)

Function block is a function described as a set of elementary blocks. The blocks describe the function between input variables and output variables.

Table 83 shows all attributes of FunctionBlock.

**Table 83 – Attributes of EquipmentReliabilityProfile::FunctionBlock**

name	mult	type	description
priority	0..1	<a href="#">Integer</a>	(NC) Value 0 means ignore priority. 1 means the highest priority, 2 is the second highest priority.
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

name	mult	type	description
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 84 shows all association ends of FunctionBlock with other classes.

**Table 84 – Association ends of EquipmentReliabilityProfile::FunctionBlock with other classes**

mult from	name	mult to	type	description
0..*	AutomationFunction	0..1	<a href="#">AutomationFunction</a>	(NC) Automation function describe automation that this function block is part of.
1..1	FunctionOutputVariable	1..*	<a href="#">FunctionOutputVariable</a>	(NC) Function output variable describe the output or codomain to the function block.

### 3.50 (abstract,NC) FunctionInputVariable

Inheritance path = [IdentifiedObject](#)

Functional input variable defines the domain of the function.

Table 85 shows all attributes of FunctionInputVariable.

**Table 85 – Attributes of EquipmentReliabilityProfile::FunctionInputVariable**

name	mult	type	description
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 86 shows all association ends of FunctionInputVariable with other classes.

**Table 86 – Association ends of EquipmentReliabilityProfile::FunctionInputVariable with other classes**

mult from	name	mult to	type	description
1..*	Function	1..1	<a href="#">FunctionBlock</a>	(NC) Function block describe the function that function input variable provides the domain for.

### 3.51 (NC) FunctionOutputVariable

Inheritance path = [IdentifiedObject](#)

Functional output variable defines the codomain of the function.

Table 87 shows all attributes of FunctionOutputVariable.

**Table 87 – Attributes of EquipmentReliabilityProfile::FunctionOutputVariable**

name	mult	type	description
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

name	mult	type	description
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 88 shows all association ends of FunctionOutputVariable with other classes.

**Table 88 – Association ends of EquipmentReliabilityProfile::FunctionOutputVariable with other classes**

mult from	name	mult to	type	description
1..*	FunctionBlock	1..1	<a href="#">FunctionBlock</a>	(NC) Function block describe the function that function output variable provides the codomain for.
0..*	PropertyReference	1..1	<a href="#">PropertyReference</a>	(NC) Property reference refers to a given class and property that is populated by the function output variable.

### 3.52 (NC) GateInputPin

Inheritance path = [FunctionInputVariable](#) : [IdentifiedObject](#)

Input pin for a logical gate. The condition described in the input pin gives a logical true or false.

The result from measurement and calculation are converted to a true or false.

Table 89 shows all attributes of GateInputPin.

**Table 89 – Attributes of EquipmentReliabilityProfile::GateInputPin**

name	mult	type	description
absoluteValue	0..1	<a href="#">Boolean</a>	(NC) Indicates if the absolute value is used for comparison. If true, use the absolute value. If false, use the complex value (vector).
logicKind	0..1	<a href="#">LogicalOperatorsKind</a>	(NC) The logical operator kind used for comparison.
duration	0..1	<a href="#">Duration</a>	(NC) The time duration for which the condition is satisfied before acting. Default is 0 seconds.
negate	0..1	<a href="#">Boolean</a>	(NC) Invert/negate the result of the comparison.
thresholdPercentage	0..1	<a href="#">PerCent</a>	(NC) The threshold percentage that should be used for compare with the percentage change between input value and threshold value.
thresholdValue	0..1	<a href="#">Float</a>	(NC) The threshold value that should be used for compare with the input value.
energyIdemtCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 90 shows all association ends of GateInputPin with other classes.

**Table 90 – Association ends of EquipmentReliabilityProfile::GateInputPin with other classes**

mult from	name	mult to	type	description
1..*	Function	1..1	<a href="#">FunctionBlock</a>	(NC) inherited from: <a href="#">FunctionInputVariable</a>

**3.53 (Description) GeneratingUnit**

Inheritance path = [Equipment](#) : [PowerSystemResource](#) : [IdentifiedObject](#)

A single or set of synchronous machines for converting mechanical power into alternating-current power. For example, individual machines within a set may be defined for scheduling purposes while a single control signal is derived for the set. In this case there would be a GeneratingUnit for each member of the set and an additional GeneratingUnit corresponding to the set.

Table 91 shows all attributes of GeneratingUnit.

**Table 91 – Attributes of EquipmentReliabilityProfile::GeneratingUnit**

name	mult	type	description
shutdownTime	0..1	<a href="#">Seconds</a>	(NC) Time it takes to shutdown the unit.
shutdownCost	0..1	<a href="#">Money</a>	(NC) The shutdown cost incurred for each shutdown of the GeneratingUnit.
maxStartupLoad	0..1	<a href="#">ActivePower</a>	(NC) Maximum consumption by the generating unit as part of the startup process.
maxEconomicP	0..1	<a href="#">ActivePower</a>	Maximum high economic active power limit, that should not exceed the maximum operating active power limit.
minEconomicP	0..1	<a href="#">ActivePower</a>	Low economic active power limit that shall be greater than or equal to the minimum operating active power limit.
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 92 shows all association ends of GeneratingUnit with other classes.

**Table 92 – Association ends of EquipmentReliabilityProfile::GeneratingUnit with other classes**

mult from	name	mult to	type	description
0..*	ScheduleResource	0..1	<a href="#">ScheduleResource</a>	(NC) The schedule resource that has this generating unit.
1..*	Circuit	0..1	<a href="#">Circuit</a>	(NC) inherited from: <a href="#">Equipment</a>
0..*	AggregatedEquipment	0..1	<a href="#">Equipment</a>	(NC) inherited from: <a href="#">Equipment</a>

**3.54 (NC) GeothermalGeneratingUnit**

Inheritance path = [GeneratingUnit](#) : [Equipment](#) : [PowerSystemResource](#) : [IdentifiedObject](#)

Generating unit that is generating electrical power from geothermal energy. Technologies in use include dry steam power stations, flash steam power stations and binary cycle power stations.

Table 93 shows all attributes of GeothermalGeneratingUnit.

**Table 93 – Attributes of EquipmentReliabilityProfile::GeothermalGeneratingUnit**

name	mult	type	description
kind	1..1	<a href="#">GeothermalUnitKind</a>	(NC) Kind of geothermal generating unit.
shutdownTime	0..1	<a href="#">Seconds</a>	(NC) inherited from: <a href="#">GeneratingUnit</a>

name	mult	type	description
shutdownCost	0..1	<a href="#">Money</a>	(NC) inherited from: <a href="#">GeneratingUnit</a>
maxStartupLoad	0..1	<a href="#">ActivePower</a>	(NC) inherited from: <a href="#">GeneratingUnit</a>
maxEconomicP	0..1	<a href="#">ActivePower</a>	inherited from: <a href="#">GeneratingUnit</a>
minEconomicP	0..1	<a href="#">ActivePower</a>	inherited from: <a href="#">GeneratingUnit</a>
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 94 shows all association ends of GeothermalGeneratingUnit with other classes.

**Table 94 – Association ends of EquipmentReliabilityProfile::GeothermalGeneratingUnit with other classes**

mult from	name	mult to	type	description
0..*	ScheduleResource	0..1	<a href="#">ScheduleResource</a>	(NC) inherited from: <a href="#">GeneratingUnit</a>
1..*	Circuit	0..1	<a href="#">Circuit</a>	(NC) inherited from: <a href="#">Equipment</a>
0..*	AggregatedEquipment	0..1	<a href="#">Equipment</a>	(NC) inherited from: <a href="#">Equipment</a>

### 3.55 (Description) HydroPump

Inheritance path = [Equipment](#) : [PowerSystemResource](#) : [IdentifiedObject](#)

A synchronous motor-driven pump, typically associated with a pumped storage plant.

Table 95 shows all attributes of HydroPump.

**Table 95 – Attributes of EquipmentReliabilityProfile::HydroPump**

name	mult	type	description
longPF	0..1	<a href="#">Float</a>	(NC) Hydro pump long term economic participation factor.
maxEconomicP	0..1	<a href="#">ActivePower</a>	(NC) Maximum high economic active power limit, that should not exceed the maximum operating active power limit.
minEconomicP	0..1	<a href="#">ActivePower</a>	(NC) Low economic active power limit that shall be greater than or equal to the minimum operating active power limit.
shortPF	0..1	<a href="#">Float</a>	(NC) Hydro pump short term economic participation factor.
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 96 shows all association ends of HydroPump with other classes.

**Table 96 – Association ends of EquipmentReliabilityProfile::HydroPump with other classes**

mult from	name	mult to	type	description
0..*	ScheduleResource	0..1	<a href="#">ScheduleResource</a>	(NC) The schedule resource that has this hydro pump.
1..*	Circuit	0..1	<a href="#">Circuit</a>	(NC) inherited from: <a href="#">Equipment</a>
0..*	AggregatedEquipment	0..1	<a href="#">Equipment</a>	(NC) inherited from: <a href="#">Equipment</a>

**3.56 (abstract) IdentifiedObject root class**

This is a root class to provide common identification for all classes needing identification and naming attributes.

Table 97 shows all attributes of IdentifiedObject.

**Table 97 – Attributes of EquipmentReliabilityProfile::IdentifiedObject**

name	mult	type	description
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) The attribute is used for an exchange of the EIC code (Energy identification Code). The length of the string is 16 characters as defined by the EIC code. For details on EIC scheme please refer to ENTSO-E web site.
description	0..1	<a href="#">String</a>	The description is a free human readable text describing or naming the object. It may be non unique and may not correlate to a naming hierarchy.
mRID	1..1	<a href="#">String</a>	Master resource identifier issued by a model authority. The mRID is unique within an exchange context. Global uniqueness is easily achieved by using a UUID, as specified in RFC 4122, for the mRID. The use of UUID is strongly recommended.  For CIMXML data files in RDF syntax conforming to IEC 61970-552, the mRID is mapped to rdf:ID or rdf:about attributes that identify CIM object elements.
name	0..1	<a href="#">String</a>	The name is any free human readable and possibly non unique text naming the object.

**3.57 (NC) ImpedanceFunction**

Inheritance path = [ControlFunctionBlock](#) : [FunctionBlock](#) : [IdentifiedObject](#)

Impedance function is a function block that calculates the controlled equipment operation point to archive the target impedance.

Table 98 shows all attributes of ImpedanceFunction.

**Table 98 – Attributes of EquipmentReliabilityProfile::ImpedanceFunction**

name	mult	type	description
isDiscrete	1..1	<a href="#">Boolean</a>	(NC) inherited from: <a href="#">ControlFunctionBlock</a>
targetDeadband	0..1	<a href="#">Float</a>	(NC) inherited from: <a href="#">ControlFunctionBlock</a>
maxAllowedTargetValue	0..1	<a href="#">PerCent</a>	(NC) inherited from: <a href="#">ControlFunctionBlock</a>
minAllowedTargetValue	0..1	<a href="#">PerCent</a>	(NC) inherited from: <a href="#">ControlFunctionBlock</a>
priority	0..1	<a href="#">Integer</a>	(NC) inherited from: <a href="#">FunctionBlock</a>

name	mult	type	description
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 99 shows all association ends of ImpedanceFunction with other classes.

**Table 99 – Association ends of EquipmentReliabilityProfile::ImpedanceFunction with other classes**

mult from	name	mult to	type	description
0..*	AutomationFunction	0..1	<a href="#">AutomationFunction</a>	(NC) inherited from: <a href="#">FunctionBlock</a>
1..1	FunctionOutputVariable	1..*	<a href="#">FunctionOutputVariable</a>	(NC) inherited from: <a href="#">FunctionBlock</a>

### 3.58 (abstract,NC) LimitDependencyCurve

Inheritance path = [Curve](#)

A curve or functional relationship between an independent variable (X-axis) and limiting dependent (Y-axis) variables.

Table 100 shows all attributes of LimitDependencyCurve.

**Table 100 – Attributes of EquipmentReliabilityProfile::LimitDependencyCurve**

name	mult	type	description
curveStyle	1..1	<a href="#">CurveStyle</a>	inherited from: <a href="#">Curve</a>
xMultiplier	0..1	<a href="#">UnitMultiplier</a>	inherited from: <a href="#">Curve</a>
xUnit	1..1	<a href="#">UnitSymbol</a>	inherited from: <a href="#">Curve</a>
y1Multiplier	0..1	<a href="#">UnitMultiplier</a>	inherited from: <a href="#">Curve</a>
y1Unit	0..1	<a href="#">UnitSymbol</a>	inherited from: <a href="#">Curve</a>

### 3.59 (Description) Line

Inheritance path = [EquipmentContainer](#) : [ConnectivityNodeContainer](#) : [PowerSystemResource](#) : [IdentifiedObject](#)

Contains equipment beyond a substation belonging to a power transmission line.

Table 101 shows all attributes of Line.

**Table 101 – Attributes of EquipmentReliabilityProfile::Line**

name	mult	type	description
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 102 shows all association ends of Line with other classes.



1319 **Table 102 – Association ends of EquipmentReliabilityProfile::Line with other classes**

mult from	name	mult to	type	description
0..*	SchedulingArea	0..1	<a href="#">SchedulingArea</a>	(NC) The scheduling area that has this line.

1320

1321 **3.60 (NC) LineCircuit**1322 Inheritance path = [Circuit](#) : [PowerSystemResource](#) : [IdentifiedObject](#)

1323 A line circuit is a circuit that has at least one ACLineSegment and may or may not include related switching and/or auxiliary equipment.

1325 Table 103 shows all attributes of LineCircuit.

1326 **Table 103 – Attributes of EquipmentReliabilityProfile::LineCircuit**

name	mult	type	description
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

1327

1328 Table 104 shows all association ends of LineCircuit with other classes.

1329 **Table 104 – Association ends of EquipmentReliabilityProfile::LineCircuit with other classes**

1330

mult from	name	mult to	type	description
0..*	CircuitShare	0..1	<a href="#">CircuitShare</a>	(NC) inherited from: <a href="#">Circuit</a>

1331

1332 **3.61 (NC) LoadFrequencyControlArea**1333 Inheritance path = [PowerSystemResource](#) : [IdentifiedObject](#)

1334 A part of a synchronous area or an entire synchronous area, physically demarcated by points of measurement at interconnectors to other load frequency control (LFC) areas, operated by one or more TSOs fulfilling the obligations of load-frequency control.

1337 Table 105 shows all attributes of LoadFrequencyControlArea.

1338 **Table 105 – Attributes of EquipmentReliabilityProfile::LoadFrequencyControlArea**

name	mult	type	description
deficientGenerationLimit	0..1	<a href="#">PerCent</a>	(NC) Percentage of average dispatch target plus average regulation used to calculate Deficient Generation Limit. Analyst enterable online. Defaulted to 96 in the model if null, negative, or greater than 100.
frequencyBiasFactor	0..1	<a href="#">Float</a>	(NC) Manually entered frequency bias in MW/Hz.
includeFrequencyBias	1..1	<a href="#">Boolean</a>	(NC) True means the frequency bias that is taken into consideration in the frequency bias computation.
frequencyRestorationReserveDelay	0..1	<a href="#">Seconds</a>	(NC) FRR delay expressed in seconds. Must be a positive multiple of AGC's cycle duration.
frequencyRestorationReserveMaxRamp	0..1	<a href="#">ActivePowerChangeRate</a>	(NC) Maximum authorized ramp for both FRR dispatching and ramp to zero.

name	mult	type	description
frequencyRestorationReserveThreshold	0..1	<a href="#">ActivePower</a>	(NC) Authorized threshold for both FRR dispatching and ramp to zero.
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 106 shows all association ends of LoadFrequencyControlArea with other classes.

**Table 106 – Association ends of  
EquipmentReliabilityProfile::LoadFrequencyControlArea with other classes**

mult from	name	mult to	type	description
0..*	FrequencyControlOperator	0..1	<a href="#">LoadFrequencyControlOperator</a>	(NC) The frequency control operator that operates this frequency control area.
0..*	LoadFrequencyControlBlock	0..1	<a href="#">LoadFrequencyControlBlock</a>	(NC) The load frequency control block that has this load frequency control area.

### 3.62 (NC) LoadFrequencyControlBlock

Inheritance path = [PowerSystemResource](#) : [IdentifiedObject](#)

A part of a synchronous area or an entire synchronous area, physically demarcated by points of measurement at interconnectors to other load frequency control (LFC) blocks, consisting of one or more LFC areas, operated by one or more TSOs fulfilling the obligations of load-frequency control.

Table 107 shows all attributes of LoadFrequencyControlBlock.

**Table 107 – Attributes of EquipmentReliabilityProfile::LoadFrequencyControlBlock**

name	mult	type	description
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 108 shows all association ends of LoadFrequencyControlBlock with other classes.

**Table 108 – Association ends of  
EquipmentReliabilityProfile::LoadFrequencyControlBlock with other classes**

mult from	name	mult to	type	description
0..*	SynchronousArea	0..1	<a href="#">SynchronousArea</a>	(NC) The synchronous area that has this load frequency control block.

### 3.63 (NC) LoadFrequencyControlOperator

Inheritance path = [PowerSystemOrganisationRole](#) : [OrganisationRole](#) : [IdentifiedObject](#)

A role that is responsible for operational security by operating the load frequency control (LFC) mechanism.

Table 109 shows all attributes of LoadFrequencyControlOperator.

**Table 109 – Attributes of EquipmentReliabilityProfile::LoadFrequencyControlOperator**

name	mult	type	description
globalLocationNumber	0..1	<a href="#">String</a>	(NC) inherited from: <a href="#">OrganisationRole</a>
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 110 shows all association ends of LoadFrequencyControlOperator with other classes.

**Table 110 – Association ends of  
EquipmentReliabilityProfile::LoadFrequencyControlOperator with other classes**

mult from	name	mult to	type	description
0..*	Organisation	0..1	<a href="#">Organisation</a>	inherited from: <a href="#">OrganisationRole</a>

### 3.64 (NC) ModularStaticSynchronousSeriesCompensator

Inheritance path = [FACTSEquipment](#) : [RegulatingCondEq](#) : [EnergyConnection](#) : [ConductingEquipment](#) : [Equipment](#) : [PowerSystemResource](#) : [IdentifiedObject](#)

Modular static synchronous series compensator (MSSSC) is a type of flexible AC transmission system regulating equipment which consists of solid-state voltage source inverter connected in series with a transmission line. This is similar to static synchronous series compensator (SSSC), but without injection transformer. This enables the MSSSC to be truly modular with the ability to simply install a number of equipment in series to provide a desired maximum level of impedance. MSSSC can be dispersed into multiple location in a circuit working collectively under the same controller scheme.

Table 111 shows all attributes of ModularStaticSynchronousSeriesCompensator.

**Table 111 – Attributes of  
EquipmentReliabilityProfile::ModularStaticSynchronousSeriesCompensator**

name	mult	type	description
capacitiveRating	1..1	<a href="#">Reactance</a>	inherited from: <a href="#">FACTSEquipment</a>
inductiveRating	1..1	<a href="#">Reactance</a>	inherited from: <a href="#">FACTSEquipment</a>
slope	1..1	<a href="#">VoltagePerReactivePower</a>	inherited from: <a href="#">FACTSEquipment</a>
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 112 shows all association ends of ModularStaticSynchronousSeriesCompensator with other classes.

**Table 112 – Association ends of EquipmentReliabilityProfile::ModularStaticSynchronousSeriesCompensator with other classes**

mult from	name	mult to	type	description
0..*	EquipmentController	0..1	<a href="#">EquipmentController</a>	(NC) inherited from: <a href="#">RegulatingCondEq</a>
1..*	Circuit	0..1	<a href="#">Circuit</a>	(NC) inherited from: <a href="#">Equipment</a>
0..*	AggregatedEquipment	0..1	<a href="#">Equipment</a>	(NC) inherited from: <a href="#">Equipment</a>

### 3.65 NuclearGeneratingUnit

Inheritance path = [GeneratingUnit](#) : [Equipment](#) : [PowerSystemResource](#) : [IdentifiedObject](#)

A nuclear generating unit.

Table 113 shows all attributes of NuclearGeneratingUnit.

**Table 113 – Attributes of EquipmentReliabilityProfile::NuclearGeneratingUnit**

name	mult	type	description
reactorKind	1..1	<a href="#">NuclearReactorKind</a>	(NC) Kind of nuclear reactor.
shutdownTime	0..1	<a href="#">Seconds</a>	(NC) inherited from: <a href="#">GeneratingUnit</a>
shutdownCost	0..1	<a href="#">Money</a>	(NC) inherited from: <a href="#">GeneratingUnit</a>
maxStartupLoad	0..1	<a href="#">ActivePower</a>	(NC) inherited from: <a href="#">GeneratingUnit</a>
maxEconomicP	0..1	<a href="#">ActivePower</a>	inherited from: <a href="#">GeneratingUnit</a>
minEconomicP	0..1	<a href="#">ActivePower</a>	inherited from: <a href="#">GeneratingUnit</a>
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 114 shows all association ends of NuclearGeneratingUnit with other classes.

**Table 114 – Association ends of EquipmentReliabilityProfile::NuclearGeneratingUnit with other classes**

mult from	name	mult to	type	description
0..*	ScheduleResource	0..1	<a href="#">ScheduleResource</a>	(NC) inherited from: <a href="#">GeneratingUnit</a>
1..*	Circuit	0..1	<a href="#">Circuit</a>	(NC) inherited from: <a href="#">Equipment</a>
0..*	AggregatedEquipment	0..1	<a href="#">Equipment</a>	(NC) inherited from: <a href="#">Equipment</a>

### 3.66 (abstract) OperationalLimit

Inheritance path = [IdentifiedObject](#)

A value and normal value associated with a specific kind of limit.

The sub class value and normalValue attributes vary inversely to the associated OperationalLimitType.acceptableDuration (acceptableDuration for short).

If a particular piece of equipment has multiple operational limits of the same kind (apparent power, current, etc.), the limit with the greatest acceptableDuration shall have the smallest limit value and the limit with the smallest acceptableDuration shall have the largest limit value. Note: A large current can only be allowed to flow through a piece of equipment for a short duration without causing damage, but a lesser current can be allowed to flow for a longer duration.

1408 Table 115 shows all attributes of OperationalLimit.

1409 **Table 115 – Attributes of EquipmentReliabilityProfile::OperationalLimit**

name	mult	type	description
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

1410

1411 Table 116 shows all association ends of OperationalLimit with other classes.

1412 **Table 116 – Association ends of EquipmentReliabilityProfile::OperationalLimit with**  
1413 **other classes**

mult from	name	mult to	type	description
1..*	OperationalLimitType	1..1	<a href="#">OperationalLimitType</a>	The limit type associated with this limit.
1..*	OperationalLimitSet	1..1	<a href="#">OperationalLimitSet</a>	The limit set to which the limit values belong.

1414

### 1415 3.67 OperationalLimitSet

1416 Inheritance path = [IdentifiedObject](#)

1417 A set of limits associated with equipment. Sets of limits might apply to a specific temperature,  
1418 or season for example. A set of limits may contain different severities of limit levels that would  
1419 apply to the same equipment. The set may contain limits of different types such as apparent  
1420 power and current limits or high and low voltage limits that are logically applied together as a  
1421 set.

1422 Table 117 shows all attributes of OperationalLimitSet.

1423 **Table 117 – Attributes of EquipmentReliabilityProfile::OperationalLimitSet**

name	mult	type	description
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

1424

1425 Table 118 shows all association ends of OperationalLimitSet with other classes.

1426 **Table 118 – Association ends of EquipmentReliabilityProfile::OperationalLimitSet with**  
1427 **other classes**

mult from	name	mult to	type	description
0..*	Terminal	1..1	<a href="#">ACDCTerminal</a>	The terminal where the operational limit set apply.
0..*	PowerTransferCorridor	0..1	<a href="#">PowerTransferCorridor</a>	(NC) The power transfer corridor that has this operational limit set.

1428

### 1429 3.68 OperationalLimitType

1430 Inheritance path = [IdentifiedObject](#)

1431 The operational meaning of a category of limits.

1432 Table 119 shows all attributes of OperationalLimitType.

1433 **Table 119 – Attributes of EquipmentReliabilityProfile::OperationalLimitType**

name	mult	type	description
direction	1..1	<a href="#">OperationalLimitDirectionKind</a>	The direction of the limit.
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

1434

1435 Table 120 shows all association ends of OperationalLimitType with other classes.

1436 **Table 120 – Association ends of EquipmentReliabilityProfile::OperationalLimitType with other classes**

1437

mult from	name	mult to	type	description
0..*	PermanentAmbientTemperatureDependencyCurve	0..1	<a href="#">AmbientTemperatureDependencyCurve</a>	(NC) The permanent ambient temperature dependency curve for this operational limit type.
0..*	TemporaryBaseOverloadLimitCurve	0..1	<a href="#">BaseOverloadLimitCurve</a>	(NC) The temporary base overload limit curve for this operational limit type.
0..*	TemporaryDurationOverloadLimitCurve	0..1	<a href="#">DurationOverloadLimitCurve</a>	(NC) The temporary duration overload limit curve for this operational limit type.
0..*	PermanentSolarRadiationCurve	0..1	<a href="#">SolarRadiationDependencyCurve</a>	(NC) The permanent solar radiation curve for this operational limit type.
0..*	RecoveryOverloadLimitCurve	0..1	<a href="#">RecoveryOverloadLimitCurve</a>	(NC) This is the curve which provides the recovery time information for this limit type.

1438

### 1439 3.69 (NC) OrdinaryPowerTransferCorridor

1440 Inheritance path = [PowerTransferCorridor](#) : [PowerSystemResource](#) : [IdentifiedObject](#)

1441 Power transfer corridor defined for normal operating network.

1442 Table 121 shows all attributes of OrdinaryPowerTransferCorridor.

1443 **Table 121 – Attributes of EquipmentReliabilityProfile::OrdinaryPowerTransferCorridor**

name	mult	type	description
normalEnabled	0..1	<a href="#">Boolean</a>	(NC) inherited from: <a href="#">PowerTransferCorridor</a>
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

1444

### 1445 3.70 Organisation

1446 Inheritance path = [IdentifiedObject](#)

1447 Organisation that might have roles as utility, contractor, supplier, manufacturer, customer, etc.

1448 Table 122 shows all attributes of Organisation.

1449

**Table 122 – Attributes of EquipmentReliabilityProfile::Organisation**

name	mult	type	description
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

1450

**3.71 (abstract) OrganisationRole**1452 Inheritance path = [IdentifiedObject](#)

1453 Identifies a way in which an organisation may participate in the utility enterprise (e.g., customer, manufacturer, etc).

1455 Table 123 shows all attributes of OrganisationRole.

1456

**Table 123 – Attributes of EquipmentReliabilityProfile::OrganisationRole**

name	mult	type	description
globalLocationNumber	0..1	<a href="#">String</a>	(NC) The Global Location Number (GLN) is part of the GS1 systems of standards. GLN is a 13-digit number structured that include GS1 Company Prefix, Location Reference (N1-N12) and Check Digit (N13). GS1 is a neutral, not-for-profit, international organisation that develops and maintains standards for supply and demand chains across multiple sectors.
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

1457

1458 Table 124 shows all association ends of OrganisationRole with other classes.

**Table 124 – Association ends of EquipmentReliabilityProfile::OrganisationRole with other classes**

mult from	name	mult to	type	description
0..*	Organisation	0..1	<a href="#">Organisation</a>	Organisation having this role.

1461

**3.72 (NC) OutageCoordinationRegion**1463 Inheritance path = [Region](#) : [PowerSystemResource](#) : [IdentifiedObject](#)

1464 A region that has a common organisation or service responsible for outage planning and coordination and its impact on grid operation.

1466 Table 125 shows all attributes of OutageCoordinationRegion.

1467

**Table 125 – Attributes of EquipmentReliabilityProfile::OutageCoordinationRegion**

name	mult	type	description
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>



name	mult	type	description
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 126 shows all association ends of OutageCoordinationRegion with other classes.

**Table 126 – Association ends of EquipmentReliabilityProfile::OutageCoordinationRegion with other classes**

mult from	name	mult to	type	description
0..*	OutageCoordinator	0..1	<a href="#">OutageCoordinator</a>	(NC) The outage coordinator responsible for this outage coordination region.
0..*	SecurityCoordinator	0..1	<a href="#">SecurityCoordinator</a>	(NC) The security coordinator that is responsible for this outage coordination region.

### 3.73 (NC) OutageCoordinator

Inheritance path = [SystemOperationCoordinator](#) : [PowerSystemOrganisationRole](#) : [OrganisationRole](#) : [IdentifiedObject](#)

A role that coordinates the planned availability status of relevant power system equipment to meet the need by the asset owner or operator and the security of the power system.

Table 127 shows all attributes of OutageCoordinator.

**Table 127 – Attributes of EquipmentReliabilityProfile::OutageCoordinator**

name	mult	type	description
globalLocationNumber	0..1	<a href="#">String</a>	(NC) inherited from: <a href="#">OrganisationRole</a>
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 128 shows all association ends of OutageCoordinator with other classes.

**Table 128 – Association ends of EquipmentReliabilityProfile::OutageCoordinator with other classes**

mult from	name	mult to	type	description
0..*	Organisation	0..1	<a href="#">Organisation</a>	inherited from: <a href="#">OrganisationRole</a>

### 3.74 (NC) OutagePlanningAgent

Inheritance path = [PowerSystemOrganisationRole](#) : [OrganisationRole](#) : [IdentifiedObject](#)

An entity with the task of planning the availability status of a relevant power generating module, a relevant demand facility or a relevant grid element.

Table 129 shows all attributes of OutagePlanningAgent.

**Table 129 – Attributes of EquipmentReliabilityProfile::OutagePlanningAgent**

name	mult	type	description
globalLocationNumber	0..1	<a href="#">String</a>	(NC) inherited from: <a href="#">OrganisationRole</a>



name	mult	type	description
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 130 shows all association ends of OutagePlanningAgent with other classes.

**Table 130 – Association ends of EquipmentReliabilityProfile::OutagePlanningAgent with other classes**

mult from	name	mult to	type	description
0..*	Organisation	0..1	<a href="#">Organisation</a>	inherited from: <a href="#">OrganisationRole</a>

### 3.75 (NC) PinTerminal

Inheritance path = [GateInputPin](#) : [FunctionInputVariable](#) : [IdentifiedObject](#)

Input pin associated with a Terminal. It is used for comparison.

Table 131 shows all attributes of PinTerminal.

**Table 131 – Attributes of EquipmentReliabilityProfile::PinTerminal**

name	mult	type	description
kind	1..1	<a href="#">PinTerminalKind</a>	(NC) The kind of quantity which is used as an input value.
absoluteValue	0..1	<a href="#">Boolean</a>	(NC) inherited from: <a href="#">GateInputPin</a>
logicKind	0..1	<a href="#">LogicalOperatorsKind</a>	(NC) inherited from: <a href="#">GateInputPin</a>
duration	0..1	<a href="#">Duration</a>	(NC) inherited from: <a href="#">GateInputPin</a>
negate	0..1	<a href="#">Boolean</a>	(NC) inherited from: <a href="#">GateInputPin</a>
thresholdPercentage	0..1	<a href="#">PerCent</a>	(NC) inherited from: <a href="#">GateInputPin</a>
thresholdValue	0..1	<a href="#">Float</a>	(NC) inherited from: <a href="#">GateInputPin</a>
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 132 shows all association ends of PinTerminal with other classes.

**Table 132 – Association ends of EquipmentReliabilityProfile::PinTerminal with other classes**

mult from	name	mult to	type	description
1..*	Function	1..1	<a href="#">FunctionBlock</a>	(NC) inherited from: <a href="#">FunctionInputVariable</a>

### 3.76 (NC) PowerElectricalChemicalUnit

Inheritance path = [PowerElectronicsUnit](#) : [Equipment](#) : [PowerSystemResource](#) : [IdentifiedObject](#)

1509 An unit capable of either generating electrical energy from chemical reactions or using electrical  
1510 energy to cause chemical reactions.

1511 Table 133 shows all attributes of PowerElectricalChemicalUnit.

1512 **Table 133 – Attributes of EquipmentReliabilityProfile::PowerElectricalChemicalUnit**

name	mult	type	description
kind	1..1	<a href="#">PowerElectricalChemicalUnitKind</a>	(NC) Kind of power electrical chemical unit.
longPF	0..1	<a href="#">Float</a>	(NC) inherited from: <a href="#">PowerElectronicsUnit</a>
maxEconomicP	0..1	<a href="#">ActivePower</a>	(NC) inherited from: <a href="#">PowerElectronicsUnit</a>
minEconomicP	0..1	<a href="#">ActivePower</a>	(NC) inherited from: <a href="#">PowerElectronicsUnit</a>
shortPF	0..1	<a href="#">Float</a>	(NC) inherited from: <a href="#">PowerElectronicsUnit</a>
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

1513  
1514 Table 134 shows all association ends of PowerElectricalChemicalUnit with other classes.

1515 **Table 134 – Association ends of**  
1516 **EquipmentReliabilityProfile::PowerElectricalChemicalUnit with other classes**

mult from	name	mult to	type	description
0..*	ScheduleResource	0..1	<a href="#">ScheduleResource</a>	(NC) inherited from: <a href="#">PowerElectronicsUnit</a>
1..*	Circuit	0..1	<a href="#">Circuit</a>	(NC) inherited from: <a href="#">Equipment</a>
0..*	AggregatedEquipment	0..1	<a href="#">Equipment</a>	(NC) inherited from: <a href="#">Equipment</a>

### 1517 1518 3.77 (NC) PowerElectronicsMarineUnit

1519 Inheritance path = [PowerElectronicsUnit](#) : [Equipment](#) : [PowerSystemResource](#) :  
1520 [IdentifiedObject](#)

1521 An unit that capture energy from marine sources, e.g. waves, for generating electrical power.

1522 Table 135 shows all attributes of PowerElectronicsMarineUnit.

1523 **Table 135 – Attributes of EquipmentReliabilityProfile::PowerElectronicsMarineUnit**

name	mult	type	description
kind	1..1	<a href="#">MarineUnitKind</a>	(NC) Kind of marine unit.
longPF	0..1	<a href="#">Float</a>	(NC) inherited from: <a href="#">PowerElectronicsUnit</a>
maxEconomicP	0..1	<a href="#">ActivePower</a>	(NC) inherited from: <a href="#">PowerElectronicsUnit</a>
minEconomicP	0..1	<a href="#">ActivePower</a>	(NC) inherited from: <a href="#">PowerElectronicsUnit</a>
shortPF	0..1	<a href="#">Float</a>	(NC) inherited from: <a href="#">PowerElectronicsUnit</a>
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

1524

1525 Table 136 shows all association ends of PowerElectronicsMarineUnit with other classes.

1526 **Table 136 – Association ends of**  
1527 **EquipmentReliabilityProfile::PowerElectronicsMarineUnit with other classes**

mult from	name	mult to	type	description
0..*	ScheduleResource	0..1	<a href="#">ScheduleResource</a>	(NC) inherited from: <a href="#">PowerElectronicsUnit</a>
1..*	Circuit	0..1	<a href="#">Circuit</a>	(NC) inherited from: <a href="#">Equipment</a>
0..*	AggregatedEquipment	0..1	<a href="#">Equipment</a>	(NC) inherited from: <a href="#">Equipment</a>

1528

### 1529 3.78 (Description) PowerElectronicsUnit

1530 Inheritance path = [Equipment](#) : [PowerSystemResource](#) : [IdentifiedObject](#)

1531 A generating unit or battery or aggregation that connects to the AC network using power  
1532 electronics rather than rotating machines.

1533 Table 137 shows all attributes of PowerElectronicsUnit.

1534 **Table 137 – Attributes of EquipmentReliabilityProfile::PowerElectronicsUnit**

name	mult	type	description
longPF	0..1	<a href="#">Float</a>	(NC) Power electronics unit long term economic participation factor.
maxEconomicP	0..1	<a href="#">ActivePower</a>	(NC) Maximum high economic active power limit, that should not exceed the maximum operating active power limit.
minEconomicP	0..1	<a href="#">ActivePower</a>	(NC) Low economic active power limit that shall be greater than or equal to the minimum operating active power limit.
shortPF	0..1	<a href="#">Float</a>	(NC) Power electronics unit short term economic participation factor.
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

1535

1536 Table 138 shows all association ends of PowerElectronicsUnit with other classes.

1537 **Table 138 – Association ends of EquipmentReliabilityProfile::PowerElectronicsUnit with**  
1538 **other classes**

mult from	name	mult to	type	description
0..*	ScheduleResource	0..1	<a href="#">ScheduleResource</a>	(NC) The schedule resource that has this power electronics unit.
1..*	Circuit	0..1	<a href="#">Circuit</a>	(NC) inherited from: <a href="#">Equipment</a>
0..*	AggregatedEquipment	0..1	<a href="#">Equipment</a>	(NC) inherited from: <a href="#">Equipment</a>

1539

### 1540 3.79 (NC) PowerFactorFunction

1541 Inheritance path = [ControlFunctionBlock](#) : [FunctionBlock](#) : [IdentifiedObject](#)

1542 Power factor function is a function block that calculates the controlled equipment operation  
1543 point to archive the target power factor.

1544 Table 139 shows all attributes of PowerFactorFunction.

1545 **Table 139 – Attributes of EquipmentReliabilityProfile::PowerFactorFunction**

name	mult	type	description
isDiscrete	1..1	<a href="#">Boolean</a>	(NC) inherited from: <a href="#">ControlFunctionBlock</a>
targetDeadband	0..1	<a href="#">Float</a>	(NC) inherited from: <a href="#">ControlFunctionBlock</a>
maxAllowedTargetValue	0..1	<a href="#">PerCent</a>	(NC) inherited from: <a href="#">ControlFunctionBlock</a>
minAllowedTargetValue	0..1	<a href="#">PerCent</a>	(NC) inherited from: <a href="#">ControlFunctionBlock</a>
priority	0..1	<a href="#">Integer</a>	(NC) inherited from: <a href="#">FunctionBlock</a>
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

1546  
1547 Table 140 shows all association ends of PowerFactorFunction with other classes.

1548 **Table 140 – Association ends of EquipmentReliabilityProfile::PowerFactorFunction with**  
1549 **other classes**

mult from	name	mult to	type	description
0..*	AutomationFunction	0..1	<a href="#">AutomationFunction</a>	(NC) inherited from: <a href="#">FunctionBlock</a>
1..1	FunctionOutputVariable	1..*	<a href="#">FunctionOutputVariable</a>	(NC) inherited from: <a href="#">FunctionBlock</a>

1550  
1551 **3.80 (abstract,NC) PowerSystemOrganisationRole**

1552 Inheritance path = [OrganisationRole](#) : [IdentifiedObject](#)

1553 A role that is responsible for the functional operational of a power system resource.

1554 Table 141 shows all attributes of PowerSystemOrganisationRole.

1555 **Table 141 – Attributes of EquipmentReliabilityProfile::PowerSystemOrganisationRole**

name	mult	type	description
globalLocationNumber	0..1	<a href="#">String</a>	(NC) inherited from: <a href="#">OrganisationRole</a>
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

1556  
1557 Table 142 shows all association ends of PowerSystemOrganisationRole with other classes.

1558 **Table 142 – Association ends of**  
1559 **EquipmentReliabilityProfile::PowerSystemOrganisationRole with other classes**

mult from	name	mult to	type	description
0..*	Organisation	0..1	<a href="#">Organisation</a>	inherited from: <a href="#">OrganisationRole</a>

1560  
1561 **3.81 (abstract) PowerSystemResource**

1562 Inheritance path = [IdentifiedObject](#)

1563 A power system resource (PSR) can be an item of equipment such as a switch, an equipment  
1564 container containing many individual items of equipment such as a substation, or an  
1565 organisational entity such as sub-control area. Power system resources can have  
1566 measurements associated.

1567 Table 143 shows all attributes of PowerSystemResource.

1568 **Table 143 – Attributes of EquipmentReliabilityProfile::PowerSystemResource**

name	mult	type	description
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

1569

### 1570 3.82 (abstract,NC) PowerTransferCorridor

1571 Inheritance path = [PowerSystemResource](#) : [IdentifiedObject](#)

1572 A power transfer corridor is defined as a set of circuits (transmission lines or transformers)  
1573 separating two portions of the power system, or a subset of circuits exposed to a substantial  
1574 portion of the transmission exchange between two parts of the system.

1575 Table 144 shows all attributes of PowerTransferCorridor.

1576 **Table 144 – Attributes of EquipmentReliabilityProfile::PowerTransferCorridor**

name	mult	type	description
normalEnabled	0..1	<a href="#">Boolean</a>	(NC) It is the normal enable/disable the monitoring/assessment of a power transfer corridor. True means that the monitoring of the power transfer corridor is assessed. False means the power transfer corridor is not assessed.
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

1577

### 1578 3.83 (NC) PowerTransformerCircuit

1579 Inheritance path = [Circuit](#) : [PowerSystemResource](#) : [IdentifiedObject](#)

1580 A power transformer circuit is a circuit that has at least one PowerTransformer and may or may  
1581 not include related switching and/or auxiliary equipment.

1582 Table 145 shows all attributes of PowerTransformerCircuit.

1583 **Table 145 – Attributes of EquipmentReliabilityProfile::PowerTransformerCircuit**

name	mult	type	description
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

1584

1585 Table 146 shows all association ends of PowerTransformerCircuit with other classes.

**Table 146 – Association ends of EquipmentReliabilityProfile::PowerTransformerCircuit with other classes**

mult from	name	mult to	type	description
0..*	CircuitShare	0..1	<a href="#">CircuitShare</a>	(NC) inherited from: <a href="#">Circuit</a>

### 3.84 (abstract,NC) PropertyReference root class

The reference to a class and one of its properties.

### 3.85 (NC) ProportionalEnergyComponent

Inheritance path = [EnergyComponent](#) : [IdentifiedObject](#)

The proportional energy component is an energy component where there is proportional distribution of the energy group active power between energy components in each energy group.

Table 147 shows all attributes of ProportionalEnergyComponent.

**Table 147 – Attributes of EquipmentReliabilityProfile::ProportionalEnergyComponent**

name	mult	type	description
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 148 shows all association ends of ProportionalEnergyComponent with other classes.

**Table 148 – Association ends of EquipmentReliabilityProfile::ProportionalEnergyComponent with other classes**

mult from	name	mult to	type	description
0..*	EnergyGroup	0..1	<a href="#">EnergyGroup</a>	(NC) inherited from: <a href="#">EnergyComponent</a>
0..*	HydroPump	0..1	<a href="#">HydroPump</a>	(NC) inherited from: <a href="#">EnergyComponent</a>
0..*	GeneratingUnit	0..1	<a href="#">GeneratingUnit</a>	(NC) inherited from: <a href="#">EnergyComponent</a>
0..*	EnergyConsumer	0..1	<a href="#">EnergyConsumer</a>	(NC) inherited from: <a href="#">EnergyComponent</a>
0..*	PowerElectronicsUnit	0..1	<a href="#">PowerElectronicsUnit</a>	(NC) inherited from: <a href="#">EnergyComponent</a>

### 3.86 (NC) PTCTriggeredEquipment

Inheritance path = [IdentifiedObject](#)

Equipment that is operating in an island or it is out of service.

Table 149 shows all attributes of PTCTriggeredEquipment.

**Table 149 – Attributes of EquipmentReliabilityProfile::PTCTriggeredEquipment**

name	mult	type	description
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 150 shows all association ends of PTCTriggeredEquipment with other classes.

**Table 150 – Association ends of EquipmentReliabilityProfile::PTCTriggeredEquipment with other classes**

mult from	name	mult to	type	description
0..*	Equipment	1..1	<a href="#">Equipment</a>	(NC) The equipment which is part of power transfer corridor triggering.
1..*	ExceptionalPowerTransferCorridor	1..1	<a href="#">ExceptionalPowerTransferCorridor</a>	(NC) The power transfer corridor which is triggered by this equipment.

### 3.87 (NC) ReactivePowerControlFunction

Inheritance path = [ControlFunctionBlock](#) : [FunctionBlock](#) : [IdentifiedObject](#)

Reactive power control function is a function block that calculate the controlled equipment operation point to archive the target reactive power.

Table 151 shows all attributes of ReactivePowerControlFunction.

**Table 151 – Attributes of EquipmentReliabilityProfile::ReactivePowerControlFunction**

name	mult	type	description
isDiscrete	1..1	<a href="#">Boolean</a>	(NC) inherited from: <a href="#">ControlFunctionBlock</a>
targetDeadband	0..1	<a href="#">Float</a>	(NC) inherited from: <a href="#">ControlFunctionBlock</a>
maxAllowedTargetValue	0..1	<a href="#">PerCent</a>	(NC) inherited from: <a href="#">ControlFunctionBlock</a>
minAllowedTargetValue	0..1	<a href="#">PerCent</a>	(NC) inherited from: <a href="#">ControlFunctionBlock</a>
priority	0..1	<a href="#">Integer</a>	(NC) inherited from: <a href="#">FunctionBlock</a>
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 152 shows all association ends of ReactivePowerControlFunction with other classes.

**Table 152 – Association ends of EquipmentReliabilityProfile::ReactivePowerControlFunction with other classes**

mult from	name	mult to	type	description
0..*	AutomationFunction	0..1	<a href="#">AutomationFunction</a>	(NC) inherited from: <a href="#">FunctionBlock</a>
1..1	FunctionOutputVariable	1..*	<a href="#">FunctionOutputVariable</a>	(NC) inherited from: <a href="#">FunctionBlock</a>

### 3.88 (NC) RecoveryOverloadLimitCurve

Inheritance path = [LimitDependencyCurve](#) : [Curve](#)

The relation between the recovery time and an overload limit.

Table 153 shows all attributes of RecoveryOverloadLimitCurve.

**Table 153 – Attributes of EquipmentReliabilityProfile::RecoveryOverloadLimitCurve**

name	mult	type	description
curveStyle	1..1	<a href="#">CurveStyle</a>	inherited from: <a href="#">Curve</a>

name	mult	type	description
xMultiplier	0..1	<a href="#">UnitMultiplier</a>	inherited from: <a href="#">Curve</a>
xUnit	1..1	<a href="#">UnitSymbol</a>	inherited from: <a href="#">Curve</a>
y1Multiplier	0..1	<a href="#">UnitMultiplier</a>	inherited from: <a href="#">Curve</a>
y1Unit	0..1	<a href="#">UnitSymbol</a>	inherited from: <a href="#">Curve</a>

### 3.89 (abstract,NC) Region

Inheritance path = [PowerSystemResource](#) : [IdentifiedObject](#)

A region where the system operator belongs to.

Table 154 shows all attributes of Region.

**Table 154 – Attributes of EquipmentReliabilityProfile::Region**

name	mult	type	description
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

### 3.90 (abstract) RegulatingCondEq

Inheritance path = [EnergyConnection](#) : [ConductingEquipment](#) : [Equipment](#) : [PowerSystemResource](#) : [IdentifiedObject](#)

A type of conducting equipment that can regulate a quantity (i.e. voltage or flow) at a specific point in the network.

Table 155 shows all attributes of RegulatingCondEq.

**Table 155 – Attributes of EquipmentReliabilityProfile::RegulatingCondEq**

name	mult	type	description
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 156 shows all association ends of RegulatingCondEq with other classes.

**Table 156 – Association ends of EquipmentReliabilityProfile::RegulatingCondEq with other classes**

mult from	name	mult to	type	description
0..*	EquipmentController	0..1	<a href="#">EquipmentController</a>	(NC)
1..*	Circuit	0..1	<a href="#">Circuit</a>	(NC) inherited from: <a href="#">Equipment</a>
0..*	AggregatedEquipment	0..1	<a href="#">Equipment</a>	(NC) inherited from: <a href="#">Equipment</a>

### 3.91 (NC) ScheduleResource

Inheritance path = [PowerSystemResource](#) : [IdentifiedObject](#)



A schedule resource is a market-based method for handling participation of small units, particularly located on the lower voltage level that is controlled by a Distributed System Operator (DSO). It is a collection of units that can operate in the market by providing bids, offers and a resulting committed operational schedule for the collection.

Table 157 shows all attributes of ScheduleResource.

**Table 157 – Attributes of EquipmentReliabilityProfile::ScheduleResource**

name	mult	type	description
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 158 shows all association ends of ScheduleResource with other classes.

**Table 158 – Association ends of EquipmentReliabilityProfile::ScheduleResource with other classes**

mult from	name	mult to	type	description
0..*	SchedulingArea	0..1	<a href="#">SchedulingArea</a>	(NC) The scheduling area that has this schedule resource.
0..*	ResourceOf	0..1	<a href="#">ScheduleResource</a>	(NC) The schedule resource that has this subschedule resource.

### 3.92 (NC) SchedulingArea

Inheritance path = [PowerSystemResource](#) : [IdentifiedObject](#)

An area where production and/or consumption of energy can be forecasted, scheduled and measured. The area is operated by only one system operator, typically a Transmission System Operator (TSO). The area can consist of a sub area, which has the same definition as the main area, but it can be operated by another system operator (typically Distributed System Operator (DSO) or a Closed Distributed System Operator (CDSO)). This includes microgrid concept. A substation is the smallest grouping that can be included in the area. The area size should be considered in terms of the possibility of accumulated reading (settlement metering) and the capability of operating as an island.

Table 159 shows all attributes of SchedulingArea.

**Table 159 – Attributes of EquipmentReliabilityProfile::SchedulingArea**

name	mult	type	description
isIslandingEnabled	0..1	<a href="#">Boolean</a>	(NC) Identifies if the area can operate in island operation. If true, the area is enabled (capable) of operating as an electrical island. If false, the area does not have the capability or it is not enabled to operate as an electrical island.
isMeteringGridArea	0..1	<a href="#">Boolean</a>	(NC) Identifies if the area is settlement metered for all import and export to the area. If true, the area is metered area. If false, it is not.
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 160 shows all association ends of SchedulingArea with other classes.

**Table 160 – Association ends of EquipmentReliabilityProfile::SchedulingArea with other classes**

mult from	name	mult to	type	description
0..*	EnergyCoordinationRegion	0..1	<a href="#">EnergyCoordinationRegion</a>	(NC) The energy coordination region that has this scheduling area.
0..*	LoadFrequencyControlArea	0..1	<a href="#">LoadFrequencyControlArea</a>	(NC) The load frequency control area which has this scheduling area.
0..*	SystemOperator	0..1	<a href="#">SystemOperator</a>	(NC) The system operator for this scheduling area.
0..*	SynchronousArea	0..1	<a href="#">SynchronousArea</a>	(NC) The synchronous area that has this scheduling area.
1..*	BiddingZone	1..1	<a href="#">BiddingZone</a>	(NC) The bidding zone related to this scheduling area.
1..*	ControlArea	0..1	<a href="#">ControlArea</a>	(NC) The control area for this scheduling area.

### 3.93 (NC) SecurityCoordinator

Inheritance path = [SystemOperationCoordinator](#) : [PowerSystemOrganisationRole](#) : [OrganisationRole](#) : [IdentifiedObject](#)

A role that coordinates the relevant remedial actions and their optimisation to ensure efficient use to achieve required operational security of the power system.

Table 161 shows all attributes of SecurityCoordinator.

**Table 161 – Attributes of EquipmentReliabilityProfile::SecurityCoordinator**

name	mult	type	description
globalLocationNumber	0..1	<a href="#">String</a>	(NC) inherited from: <a href="#">OrganisationRole</a>
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 162 shows all association ends of SecurityCoordinator with other classes.

**Table 162 – Association ends of EquipmentReliabilityProfile::SecurityCoordinator with other classes**

mult from	name	mult to	type	description
0..*	Organisation	0..1	<a href="#">Organisation</a>	inherited from: <a href="#">OrganisationRole</a>

### 3.94 (NC) SolarRadiationDependencyCurve

Inheritance path = [LimitDependencyCurve](#) : [Curve](#)

A curve or functional relationship between

- the solar radiation independent variable (X-axis), and

- relative dependent (Y-axis) variables.

Table 163 shows all attributes of SolarRadiationDependencyCurve.

**Table 163 – Attributes of EquipmentReliabilityProfile::SolarRadiationDependencyCurve**

name	mult	type	description
curveStyle	1..1	<a href="#">CurveStyle</a>	inherited from: <a href="#">Curve</a>
xMultiplier	0..1	<a href="#">UnitMultiplier</a>	inherited from: <a href="#">Curve</a>
xUnit	1..1	<a href="#">UnitSymbol</a>	inherited from: <a href="#">Curve</a>
y1Multiplier	0..1	<a href="#">UnitMultiplier</a>	inherited from: <a href="#">Curve</a>
y1Unit	0..1	<a href="#">UnitSymbol</a>	inherited from: <a href="#">Curve</a>

**3.95 (NC) StaticSynchronousCompensator**

Inheritance path = [FACTSEquipment](#) : [RegulatingCondEq](#) : [EnergyConnection](#) : [ConductingEquipment](#) : [Equipment](#) : [PowerSystemResource](#) : [IdentifiedObject](#)

Static synchronous compensator (STATCOM), also known as a static synchronous condenser (STATCON), is a type of flexible AC transmission system regulating equipment used on alternating current electricity transmission networks. It is based on a power electronics voltage-source converter and can act as either a source or sink of reactive AC power to an electricity network. If connected to a source of power it can also provide active AC power.

Table 164 shows all attributes of StaticSynchronousCompensator.

**Table 164 – Attributes of EquipmentReliabilityProfile::StaticSynchronousCompensator**

name	mult	type	description
capacitiveRating	1..1	<a href="#">Reactance</a>	inherited from: <a href="#">FACTSEquipment</a>
inductiveRating	1..1	<a href="#">Reactance</a>	inherited from: <a href="#">FACTSEquipment</a>
slope	1..1	<a href="#">VoltagePerReactivePower</a>	inherited from: <a href="#">FACTSEquipment</a>
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 165 shows all association ends of StaticSynchronousCompensator with other classes.

**Table 165 – Association ends of  
EquipmentReliabilityProfile::StaticSynchronousCompensator with other classes**

mult from	name	mult to	type	description
0..*	EquipmentController	0..1	<a href="#">EquipmentController</a>	(NC) inherited from: <a href="#">RegulatingCondEq</a>
1..*	Circuit	0..1	<a href="#">Circuit</a>	(NC) inherited from: <a href="#">Equipment</a>
0..*	AggregatedEquipment	0..1	<a href="#">Equipment</a>	(NC) inherited from: <a href="#">Equipment</a>

**3.96 (NC) StaticSynchronousSeriesCompensator**

Inheritance path = [FACTSEquipment](#) : [RegulatingCondEq](#) : [EnergyConnection](#) : [ConductingEquipment](#) : [Equipment](#) : [PowerSystemResource](#) : [IdentifiedObject](#)

Static synchronous series compensator (SSSC) is a type of flexible AC transmission system which consists of a solid-state voltage source inverter coupled with a transformer that is connected in series with a transmission line. This device can inject an almost sinusoidal voltage in series with the line. This injected voltage could be considered as an inductive or capacitive reactance, which is connected in series with the transmission line. This feature can provide

controllable voltage compensation. In addition, SSSC is able to reverse the power flow by injecting a sufficiently large series reactive compensating voltage.  
Table 166 shows all attributes of StaticSynchronousSeriesCompensator.

**Table 166 – Attributes of  
EquipmentReliabilityProfile::StaticSynchronousSeriesCompensator**

name	mult	type	description
capacitiveRating	1..1	<a href="#">Reactance</a>	inherited from: <a href="#">FACTSEquipment</a>
inductiveRating	1..1	<a href="#">Reactance</a>	inherited from: <a href="#">FACTSEquipment</a>
slope	1..1	<a href="#">VoltagePerReactivePower</a>	inherited from: <a href="#">FACTSEquipment</a>
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 167 shows all association ends of StaticSynchronousSeriesCompensator with other classes.

**Table 167 – Association ends of  
EquipmentReliabilityProfile::StaticSynchronousSeriesCompensator with other classes**

mult from	name	mult to	type	description
0..*	EquipmentController	0..1	<a href="#">EquipmentController</a>	(NC) inherited from: <a href="#">RegulatingCondEq</a>
1..*	Circuit	0..1	<a href="#">Circuit</a>	(NC) inherited from: <a href="#">Equipment</a>
0..*	AggregatedEquipment	0..1	<a href="#">Equipment</a>	(NC) inherited from: <a href="#">Equipment</a>

### 3.97 (NC) SubSchedulingArea

Inheritance path = [SchedulingArea](#) : [PowerSystemResource](#) : [IdentifiedObject](#)

An area that is a specialisation of scheduling area that is a part of another scheduling area. Typically part of a Transmission System Operator (TSO) scheduling area which is typically operated by a Distributed System Operator (DSO) or a Close Distributed System Operator (CDSO). This includes microgrid concept. A sub scheduling area can contain other sub areas. A sub scheduling area leaf will form the smallest entity of any given energy area.  
Table 168 shows all attributes of SubSchedulingArea.

**Table 168 – Attributes of EquipmentReliabilityProfile::SubSchedulingArea**

name	mult	type	description
isIslandingEnabled	0..1	<a href="#">Boolean</a>	(NC) inherited from: <a href="#">SchedulingArea</a>
isMeteringGridArea	0..1	<a href="#">Boolean</a>	(NC) inherited from: <a href="#">SchedulingArea</a>
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 169 shows all association ends of SubSchedulingArea with other classes.

**Table 169 – Association ends of EquipmentReliabilityProfile::SubSchedulingArea with other classes**

mult from	name	mult to	type	description
0..*	SchedulingArea	1..1	<a href="#">SchedulingArea</a>	(NC) The scheduling area that has this subscheduling area.
0..*	EnergyCoordinationRegion	0..1	<a href="#">EnergyCoordinationRegion</a>	(NC) inherited from: <a href="#">SchedulingArea</a>
0..*	LoadFrequencyControlArea	0..1	<a href="#">LoadFrequencyControlArea</a>	(NC) inherited from: <a href="#">SchedulingArea</a>
0..*	SystemOperator	0..1	<a href="#">SystemOperator</a>	(NC) inherited from: <a href="#">SchedulingArea</a>
0..*	SynchronousArea	0..1	<a href="#">SynchronousArea</a>	(NC) inherited from: <a href="#">SchedulingArea</a>
1..*	BiddingZone	1..1	<a href="#">BiddingZone</a>	(NC) inherited from: <a href="#">SchedulingArea</a>
1..*	ControlArea	0..1	<a href="#">ControlArea</a>	(NC) inherited from: <a href="#">SchedulingArea</a>

**3.98 (Description) Substation**

Inheritance path = [EquipmentContainer](#) : [ConnectivityNodeContainer](#) : [PowerSystemResource](#) : [IdentifiedObject](#)

A collection of equipment for purposes other than generation or utilization, through which electric energy in bulk is passed for the purposes of switching or modifying its characteristics. Table 170 shows all attributes of Substation.

**Table 170 – Attributes of EquipmentReliabilityProfile::Substation**

name	mult	type	description
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 171 shows all association ends of Substation with other classes.

**Table 171 – Association ends of EquipmentReliabilityProfile::Substation with other classes**

mult from	name	mult to	type	description
0..*	SchedulingArea	0..1	<a href="#">SchedulingArea</a>	(NC) The scheduling area that has this substation.

**3.99 (NC) SubstationController**

Inheritance path = [EquipmentController](#) : [AutomationFunction](#) : [PowerSystemResource](#) : [IdentifiedObject](#)

Substation controller is controlling the equipment to optimize the use of the controlling equipment within a substation.

Table 172 shows all attributes of SubstationController.

**Table 172 – Attributes of EquipmentReliabilityProfile::SubstationController**

name	mult	type	description
type	0..1	<a href="#">String</a>	(NC) inherited from: <a href="#">AutomationFunction</a>

name	mult	type	description
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 173 shows all association ends of SubstationController with other classes.

**Table 173 – Association ends of EquipmentReliabilityProfile::SubstationController with other classes**

mult from	name	mult to	type	description
0..*	PartOf	0..1	<a href="#">AutomationFunction</a>	(NC) inherited from: <a href="#">AutomationFunction</a>

### 3.100 (NC) SynchronousArea

Inheritance path = [PowerSystemResource](#) : [IdentifiedObject](#)

A Synchronous Area is an electrical area covered by interconnect with a common System Frequency in a steady-state.

Table 174 shows all attributes of SynchronousArea.

**Table 174 – Attributes of EquipmentReliabilityProfile::SynchronousArea**

name	mult	type	description
nominalFrequency	1..1	<a href="#">Frequency</a>	(NC) The nominal frequency for the Synchronous Area, e.g. 50 Hz for Europe.
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

### 3.101 (abstract,NC) SystemOperationCoordinator

Inheritance path = [PowerSystemOrganisationRole](#) : [OrganisationRole](#) : [IdentifiedObject](#)

A role that coordinates relevant information and impact in regards to operating the power system.

Table 175 shows all attributes of SystemOperationCoordinator.

**Table 175 – Attributes of EquipmentReliabilityProfile::SystemOperationCoordinator**

name	mult	type	description
globalLocationNumber	0..1	<a href="#">String</a>	(NC) inherited from: <a href="#">OrganisationRole</a>
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 176 shows all association ends of SystemOperationCoordinator with other classes.

**Table 176 – Association ends of EquipmentReliabilityProfile::SystemOperationCoordinator with other classes**

mult from	name	mult to	type	description
0..*	Organisation	0..1	<a href="#">Organisation</a>	inherited from: <a href="#">OrganisationRole</a>

### 3.102 (abstract,NC) SystemOperator

Inheritance path = [PowerSystemOrganisationRole](#) : [OrganisationRole](#) : [IdentifiedObject](#)  
System operator.

Table 177 shows all attributes of SystemOperator.

**Table 177 – Attributes of EquipmentReliabilityProfile::SystemOperator**

name	mult	type	description
globalLocationNumber	0..1	<a href="#">String</a>	(NC) inherited from: <a href="#">OrganisationRole</a>
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 178 shows all association ends of SystemOperator with other classes.

**Table 178 – Association ends of EquipmentReliabilityProfile::SystemOperator with other classes**

mult from	name	mult to	type	description
0..*	Organisation	0..1	<a href="#">Organisation</a>	inherited from: <a href="#">OrganisationRole</a>

### 3.103 (abstract) TapChanger

Inheritance path = [PowerSystemResource](#) : [IdentifiedObject](#)

Mechanism for changing transformer winding tap positions.

Table 179 shows all attributes of TapChanger.

**Table 179 – Attributes of EquipmentReliabilityProfile::TapChanger**

name	mult	type	description
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

### 3.104 (abstract) Terminal

Inheritance path = [ACDCTerminal](#) : [IdentifiedObject](#)

An AC electrical connection point to a piece of conducting equipment. Terminals are connected at physical connection points called connectivity nodes.

Table 180 shows all attributes of Terminal.



1809 **Table 180 – Attributes of EquipmentReliabilityProfile::Terminal**

name	mult	type	description
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

1810

1811 **3.105 (NC) TieCorridor**1812 Inheritance path = [PowerSystemResource](#) : [IdentifiedObject](#)1813 A collection of one or more tie-lines or direct current poles that connect two different control  
1814 areas together.

1815 Table 181 shows all attributes of TieCorridor.

1816 **Table 181 – Attributes of EquipmentReliabilityProfile::TieCorridor**

name	mult	type	description
delayFRR	0..1	<a href="#">Seconds</a>	(NC) A positive number that is a multiple of Automatic Generation Control (AGC) run cycles that describes the delay in adapting imbalance of the tie corridor.
maxFRRramp	0..1	<a href="#">Float</a>	(NC) Maximum authorized ramp for both Frequency Reserve Restoration (FRR) dispatching and ramp to zero.
thresholdFRR	0..1	<a href="#">ActivePower</a>	(NC) Frequency Reserve Restoration (FRR) coherency check threshold.
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

1817

1818 **3.106 (NC) ThyristorControlledSeriesCompensator**1819 Inheritance path = [FACTSEquipment](#) : [RegulatingCondEq](#) : [EnergyConnection](#) :  
1820 [ConductingEquipment](#) : [Equipment](#) : [PowerSystemResource](#) : [IdentifiedObject](#)1821 Thyristor-controlled series capacitors (TCSC) is a type of flexible AC transmission system  
1822 regulating equipment that is configured with controlled reactors in parallel with sections of a  
1823 capacitor bank. This combination allows smooth control of the fundamental frequency  
1824 capacitive reactance over a wide range. The thyristor valve contains a string of series connected  
1825 high power thyristors. TCSC can control power flows in order to achieve eliminating of line  
1826 overloads, reducing loop flows and minimising system losses.

1827 Table 182 shows all attributes of ThyristorControlledSeriesCompensator.

1828 **Table 182 – Attributes of**  
1829 **EquipmentReliabilityProfile::ThyristorControlledSeriesCompensator**

name	mult	type	description
flexibleCapacitiveRating	0..1	<a href="#">Reactance</a>	Flexible capacitive reactance that can be controlled by the controller at maximum capacitive reactive power. Shall always be positive.



name	mult	type	description
flexibleInductiveRating	0..1	<a href="#">Reactance</a>	Flexible inductive reactance that can be controlled by the controller at maximum inductive reactive power. Shall always be negative.
capacitiveRating	1..1	<a href="#">Reactance</a>	inherited from: <a href="#">FACTSEquipment</a>
inductiveRating	1..1	<a href="#">Reactance</a>	inherited from: <a href="#">FACTSEquipment</a>
slope	1..1	<a href="#">VoltagePerReactivePower</a>	inherited from: <a href="#">FACTSEquipment</a>
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 183 shows all association ends of ThyristorControlledSeriesCompensator with other classes.

**Table 183 – Association ends of EquipmentReliabilityProfile::ThyristorControlledSeriesCompensator with other classes**

mult from	name	mult to	type	description
0..*	EquipmentController	0..1	<a href="#">EquipmentController</a>	(NC) inherited from: <a href="#">RegulatingCondEq</a>
1..*	Circuit	0..1	<a href="#">Circuit</a>	(NC) inherited from: <a href="#">Equipment</a>
0..*	AggregatedEquipment	0..1	<a href="#">Equipment</a>	(NC) inherited from: <a href="#">Equipment</a>

### 3.107 (NC) TransmissionSystemOperator

Inheritance path = [SystemOperator](#) : [PowerSystemOrganisationRole](#) : [OrganisationRole](#) : [IdentifiedObject](#)

A system operator role that is responsible for operating of an energy transmission network.

Table 184 shows all attributes of TransmissionSystemOperator.

**Table 184 – Attributes of EquipmentReliabilityProfile::TransmissionSystemOperator**

name	mult	type	description
globalLocationNumber	0..1	<a href="#">String</a>	(NC) inherited from: <a href="#">OrganisationRole</a>
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 185 shows all association ends of TransmissionSystemOperator with other classes.

**Table 185 – Association ends of EquipmentReliabilityProfile::TransmissionSystemOperator with other classes**

mult from	name	mult to	type	description
0..*	Organisation	0..1	<a href="#">Organisation</a>	inherited from: <a href="#">OrganisationRole</a>

**3.108 (NC) UnifiedPowerFlowController**

Inheritance path = [EquipmentController](#) : [AutomationFunction](#) : [PowerSystemResource](#) : [IdentifiedObject](#)

Unified power flow controller (UPFC) is providing fast-acting reactive power compensation on high-voltage electricity transmission networks.

Table 186 shows all attributes of UnifiedPowerFlowController.

**Table 186 – Attributes of EquipmentReliabilityProfile::UnifiedPowerFlowController**

name	mult	type	description
type	0..1	<a href="#">String</a>	(NC) inherited from: <a href="#">AutomationFunction</a>
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 187 shows all association ends of UnifiedPowerFlowController with other classes.

**Table 187 – Association ends of EquipmentReliabilityProfile::UnifiedPowerFlowController with other classes**

mult from	name	mult to	type	description
0..*	PartOf	0..1	<a href="#">AutomationFunction</a>	(NC) inherited from: <a href="#">AutomationFunction</a>

**3.109 (NC) VoltageAngleLimit**

Inheritance path = [OperationalLimit](#) : [IdentifiedObject](#)

The voltage angle limit for a two terminal ConductingEquipment. The association OperationalLimitSet.Terminal shall be instantiated for Terminal with sequenceNumber equal to 1.

Table 188 shows all attributes of VoltageAngleLimit.

**Table 188 – Attributes of EquipmentReliabilityProfile::VoltageAngleLimit**

name	mult	type	description
value	1..1	<a href="#">AngleDegrees</a>	(NC) The difference in angle degrees between Terminal with sequenceNumber equal to 1 and the Terminal referenced by the association VoltageAngleLimit.AngleReferenceTerminal. The value can be positive, negative or zero depending on the angle difference between the two terminals.
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 189 shows all association ends of VoltageAngleLimit with other classes.

**Table 189 – Association ends of EquipmentReliabilityProfile::VoltageAngleLimit with other classes**

mult from	name	mult to	type	description
0..*	AngleReferenceTerminal	1..1	<a href="#">Terminal</a>	(NC) The angle reference terminal for the voltage angle limit.
1..*	OperationalLimitType	1..1	<a href="#">OperationalLimitType</a>	inherited from: <a href="#">OperationalLimit</a>
1..*	OperationalLimitSet	1..1	<a href="#">OperationalLimitSet</a>	inherited from: <a href="#">OperationalLimit</a>

**3.110 (NC) VoltageControlFunction**

Inheritance path = [ControlFunctionBlock](#) : [FunctionBlock](#) : [IdentifiedObject](#)

Voltage control function is a function block that calculate the controlled equipment operation point to archive the target voltage.

Table 190 shows all attributes of VoltageControlFunction.

**Table 190 – Attributes of EquipmentReliabilityProfile::VoltageControlFunction**

name	mult	type	description
isDiscrete	1..1	<a href="#">Boolean</a>	(NC) inherited from: <a href="#">ControlFunctionBlock</a>
targetDeadband	0..1	<a href="#">Float</a>	(NC) inherited from: <a href="#">ControlFunctionBlock</a>
maxAllowedTargetValue	0..1	<a href="#">PerCent</a>	(NC) inherited from: <a href="#">ControlFunctionBlock</a>
minAllowedTargetValue	0..1	<a href="#">PerCent</a>	(NC) inherited from: <a href="#">ControlFunctionBlock</a>
priority	0..1	<a href="#">Integer</a>	(NC) inherited from: <a href="#">FunctionBlock</a>
energyIdentCodeEic	0..1	<a href="#">String</a>	(deprecated, European) inherited from: <a href="#">IdentifiedObject</a>
description	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
mRID	1..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>
name	0..1	<a href="#">String</a>	inherited from: <a href="#">IdentifiedObject</a>

Table 191 shows all association ends of VoltageControlFunction with other classes.

**Table 191 – Association ends of EquipmentReliabilityProfile::VoltageControlFunction with other classes**

mult from	name	mult to	type	description
0..*	AutomationFunction	0..1	<a href="#">AutomationFunction</a>	(NC) inherited from: <a href="#">FunctionBlock</a>
1..1	FunctionOutputVariable	1..*	<a href="#">FunctionOutputVariable</a>	(NC) inherited from: <a href="#">FunctionBlock</a>

**3.111 Currency enumeration**

Monetary currencies. ISO 4217 standard including 3-character currency code.

Table 192 shows all literals of Currency.

**Table 192 – Literals of EquipmentReliabilityProfile::Currency**

literal	value	description
AED	784	United Arab Emirates dirham.
AFN	971	Afghan afghani.
ALL	008	Albanian lek.

literal	value	description
AMD	051	Armenian dram.
ANG	532	Netherlands Antillean guilder.
AOA	973	Angolan kwanza.
ARS	032	Argentine peso.
AUD	036	Australian dollar.
AWG	533	Aruban florin.
AZN	944	Azerbaijani manat.
BAM	977	Bosnia and Herzegovina convertible mark.
BBD	052	Barbados dollar.
BDT	050	Bangladeshi taka.
BGN	975	Bulgarian lev.
BHD	048	Bahraini dinar.
BIF	108	Burundian franc.
BMD	060	Bermudian dollar (customarily known as Bermuda dollar).
BND	096	Brunei dollar.
BOB	068	Boliviano.
BOV	984	Bolivian Mvdol (funds code).
BRL	986	Brazilian real.
BSD	044	Bahamian dollar.
BTN	064	Bhutanese ngultrum.
BWP	072	Botswana pula.
BYR	974	Belarusian ruble.
BZD	084	Belize dollar.
CAD	124	Canadian dollar.
CDF	976	Congolese franc.
CHF	756	Swiss franc.
CLF	990	Unidad de Fomento (funds code), Chile.
CLP	152	Chilean peso.
CNY	156	Chinese yuan.
COP	170	Colombian peso.
COU	970	Unidad de Valor Real.
CRC	188	Costa Rican colon.
CUC	931	Cuban convertible peso.
CUP	192	Cuban peso.
CVE	132	Cape Verde escudo.
CZK	203	Czech koruna.
DJF	262	Djiboutian franc.
DKK	208	Danish krone.
DOP	214	Dominican peso.
DZD	012	Algerian dinar.

literal	value	description
EEK	233	Estonian kroon.
EGP	818	Egyptian pound.
ERN	232	Eritrean nakfa.
ETB	230	Ethiopian birr.
EUR	978	Euro.
FJD	242	Fiji dollar.
FKP	238	Falkland Islands pound.
GBP	826	Pound sterling.
GEL	981	Georgian lari.
GHS	936	Ghanaian cedi.
GIP	929	Gibraltar pound.
GMD	270	Gambian dalasi.
GNF	324	Guinean franc.
GTQ	320	Guatemalan quetzal.
GYD	328	Guyanese dollar.
HKD	344	Hong Kong dollar.
HNL	340	Honduran lempira.
HRK	191	Croatian kuna.
HTG	332	Haitian gourde.
HUF	348	Hungarian forint.
IDR	360	Indonesian rupiah.
ILS	376	Israeli new sheqel.
INR	356	Indian rupee.
IQD	368	Iraqi dinar.
IRR	364	Iranian rial.
ISK	352	Icelandic króna.
JMD	388	Jamaican dollar.
JOD	400	Jordanian dinar.
JPY	392	Japanese yen.
KES	404	Kenyan shilling.
KGS	417	Kyrgyzstani som.
KHR	116	Cambodian riel.
KMF	174	Comoro franc.
KPW	408	North Korean won.
KRW	410	South Korean won.
KWD	414	Kuwaiti dinar.
KYD	136	Cayman Islands dollar.
KZT	398	Kazakhstani tenge.
LAK	418	Lao kip.
LBP	422	Lebanese pound.
LKR	144	Sri Lanka rupee.

literal	value	description
LRD	430	Liberian dollar.
LSL	426	Lesotho loti.
LTL	440	Lithuanian litas.
LVL	428	Latvian lats.
LYD	434	Libyan dinar.
MAD	504	Moroccan dirham.
MDL	498	Moldovan leu.
MGA	969	Malagasy ariary.
MKD	807	Macedonian denar.
MMK	104	Myanma kyat.
MNT	496	Mongolian tugrik.
MOP	446	Macanese pataca.
MRO	478	Mauritanian ouguiya.
MUR	480	Mauritian rupee.
MVR	462	Maldivian rufiyaa.
MWK	454	Malawian kwacha.
MXN	484	Mexican peso.
MYR	458	Malaysian ringgit.
MZN	943	Mozambican metical.
NAD	516	Namibian dollar.
NGN	566	Nigerian naira.
NIO	558	Cordoba oro.
NOK	578	Norwegian krone.
NPR	524	Nepalese rupee.
NZD	554	New Zealand dollar.
OMR	512	Omani rial.
PAB	590	Panamanian balboa.
PEN	604	Peruvian nuevo sol.
PGK	598	Papua New Guinean kina.
PHP	608	Philippine peso.
PKR	586	Pakistani rupee.
PLN	985	Polish zloty.
PYG	600	Paraguayan guaraní.
QAR	634	Qatari rial.
RON	946	Romanian new leu.
RSD	941	Serbian dinar.
RUB	643	Russian rouble.
RWF	646	Rwandan franc.
SAR	682	Saudi riyal.
SBD	090	Solomon Islands dollar.
SCR	690	Seychelles rupee.

literal	value	description
SDG	938	Sudanese pound.
SEK	752	Swedish krona/kronor.
SGD	702	Singapore dollar.
SHP	654	Saint Helena pound.
SLL	694	Sierra Leonean leone.
SOS	706	Somali shilling.
SRD	968	Surinamese dollar.
STD	678	São Tomé and Príncipe dobra.
SYP	760	Syrian pound.
SZL	748	Lilangeni.
THB	764	Thai baht.
TJS	972	Tajikistani somoni.
TMT	934	Turkmenistani manat.
TND	788	Tunisian dinar.
TOP	776	Tongan pa'anga.
TRY	949	Turkish lira.
TTD	780	Trinidad and Tobago dollar.
TWD	901	New Taiwan dollar.
TZS	834	Tanzanian shilling.
UAH	980	Ukrainian hryvnia.
UGX	800	Ugandan shilling.
USD	840	United States dollar.
UYU	858	Uruguayan peso.
UZS	860	Uzbekistan som.
VEF	937	Venezuelan bolívar fuerte.
VND	704	Vietnamese Dong.
VUV	548	Vanuatu vatu.
WST	882	Samoan tala.
XAF	950	CFA franc BEAC.
XCD	951	East Caribbean dollar.
XOF	952	CFA Franc BCEAO.
XPF	953	CFP franc.
YER	886	Yemeni rial.
ZAR	710	South African rand.
ZMK	894	Zambian kwacha.
ZWL	932	Zimbabwe dollar.

1886

1887 **3.112 CurveStyle enumeration**

1888 Style or shape of curve.

1889 Table 193 shows all literals of CurveStyle.

1890

**Table 193 – Literals of EquipmentReliabilityProfile::CurveStyle**

literal	value	description
constantYValue		The Y-axis values are assumed constant until the next curve point and prior to the first curve point.
straightLineYValues		The Y-axis values are assumed to be a straight line between values. Also known as linear interpolation.

1891

**1892 3.113 (NC) EnergyKind enumeration**

1893 Energy group given by the needed categorization given by energy origination directive.

1894 Table 194 shows all literals of EnergyKind.

1895

**Table 194 – Literals of EquipmentReliabilityProfile::EnergyKind**

literal	value	description
hydroRunOfRiver		Hydro run of river.
hydroWaterReservoir		Hydro water reservoir.
hydroPump		Hydro pump.
biomass		Biomass.
fossil		Fossil.
geothermal		Geothermal.
marine		Marine.
nuclear		Nuclear.
uncontrollableConsumption		Uncontrollable consumption.
timeShiftConsumption		Time shift consumption.
battery		Battery storage.
bufferConsumption		Buffer consumption.
solar		Solar.
unconstrainedConsumption		Unconstrained consumption.
waste		Waste.
wind		Wind.
other		Other.

1896

**1897 3.114 (NC) MarineUnitKind enumeration**

1898 Kind of marine energy capture.

1899 Table 195 shows all literals of MarineUnitKind.

1900

**Table 195 – Literals of EquipmentReliabilityProfile::MarineUnitKind**

literal	value	description
currents		Capture energy from ocean current which are caused by forces like breaking waves, wind, Coriolis effect etc.
pressure		Capture energy from pressure.
tidal		Capture energy from tidal power, which captures the energy of the current caused by the gravitational pull of the Sun and Moon.



literal	value	description
wave		Capture energy from wind waves.
other		other way of capture energy from marine elements.

1901

1902 **3.115 OperationalLimitDirectionKind enumeration**

1903 The direction attribute describes the side of a limit that is a violation.

1904 Table 196 shows all literals of OperationalLimitDirectionKind.

1905 **Table 196 – Literals of EquipmentReliabilityProfile::OperationalLimitDirectionKind**

literal	value	description
high		High means that a monitored value above the limit value is a violation. If applied to a terminal flow, the positive direction is into the terminal.
low		Low means a monitored value below the limit is a violation. If applied to a terminal flow, the positive direction is into the terminal.
absoluteValue		An absoluteValue limit means that a monitored absolute value above the limit value is a violation.

1906

1907 **3.116 (NC) PinTerminalKind enumeration**

1908 The kind of quantities that can serve as an input value for the pin.

1909 Table 197 shows all literals of PinTerminalKind.

1910 **Table 197 – Literals of EquipmentReliabilityProfile::PinTerminalKind**

literal	value	description
activePower		Active power on the Terminal.
apparentPower		Apparent power on the Terminal.
voltageMagnitude		Voltage magnitude on the Terminal.
voltageAngle		Voltage angle on the Terminal.
current		Current on the Terminal.
reactivePower		Reactive power on the Terminal.

1911

1912 **3.117 (NC) NuclearReactorKind enumeration**

1913 Kind of nuclear reactor.

1914 Table 198 shows all literals of NuclearReactorKind.

1915 **Table 198 – Literals of EquipmentReliabilityProfile::NuclearReactorKind**

literal	value	description
breeder		Reactor which the heat source is a nuclear reactor that generates more fissile material than it consumes.
graphite		Reactor which the heat source is a graphite-moderated reactor that is a nuclear reactor that uses carbon as a neutron moderator, which allows natural uranium to be used as nuclear fuel.
heavyWater		Reactor which the heat source is a pressurized heavy-water reactor (PHWR) that uses heavy

literal	value	description
		water (deuterium oxide D2O) as its coolant and neutron moderator.
lightWater		Reactor which the heat source is a light-water reactor (LWR) that is a type of thermal-neutron reactor that uses normal water, as both its coolant and neutron moderator – furthermore a solid form of fissile elements is used as fuel.
liquidMetal		Reactor which is a liquid metal cooled nuclear reactor, liquid metal fast reactor or LMFR is an advanced type of nuclear reactor where the primary coolant is a liquid metal.
other		Other type of nuclear reactors.

1916

1917 **3.118 (NC) GeothermalUnitKind enumeration**

1918 Kind of geothermal.

1919 Table 199 shows all literals of GeothermalUnitKind.

1920 **Table 199 – Literals of EquipmentReliabilityProfile::GeothermalUnitKind**

literal	value	description
binaryCycle		The moderately hot geothermal water is passed by a secondary fluid with a much lower boiling point than water.
drySteam		Uses geothermal steam of 150 degree Celsius or greater to turn turbines.
flashSteam		Pull deep, high-pressure hot water into lower-pressure tanks and use the resulting flashed steam to drive turbines.
other		Other type of geothermal generating unit.

1921

1922 **3.119 (NC) LogicalOperatorsKind enumeration**

1923 Kinds of logical operators for comparison.

1924 Table 200 shows all literals of LogicalOperatorsKind.

1925 **Table 200 – Literals of EquipmentReliabilityProfile::LogicalOperatorsKind**

literal	value	description
notEqual		Not equal (unlike) comparison operation.
equals		Equals (like) comparison operation.
lessThanOrEquals		Less than or equals comparison operation.
lessThan		Less than comparison operation.
greaterThanOrEquals		Greater than or equals comparison operation.
greaterThan		Greater than comparison operation.

1926

1927 **3.120 (NC) PowerElectricalChemicalUnitKind enumeration**

1928 Kind of power electrical chemical unit.

1929 Table 201 shows all literals of PowerElectricalChemicalUnitKind.

1930 **Table 201 – Literals of EquipmentReliabilityProfile::PowerElectricalChemicalUnitKind**

literal	value	description
electrolyticCell		An electrolytic cell is an electrochemical cell that drives a non-spontaneous redox reaction through the application of electrical energy. Example are the decomposition of water into hydrogen and oxygen.
fuelCell		A fuel cell is an electrochemical cell that converts the chemical energy from a fuel into electricity through an electrochemical reaction of hydrogen fuel with oxygen or another oxidizing agent.
other		Other type of cell used in chemical reactions.

1931

1932 **3.121 UnitMultiplier enumeration**

1933 The unit multipliers defined for the CIM. When applied to unit symbols, the unit symbol is  
 1934 treated as a derived unit. Regardless of the contents of the unit symbol text, the unit symbol  
 1935 shall be treated as if it were a single-character unit symbol. Unit symbols should not contain  
 1936 multipliers, and it should be left to the multiplier to define the multiple for an entire data type.  
 1937 For example, if a unit symbol is "m2Pers" and the multiplier is "k", then the value is  $k(m^{**2}/s)$ ,  
 1938 and the multiplier applies to the entire final value, not to any individual part of the value. This  
 1939 can be conceptualized by substituting a derived unit symbol for the unit type. If one imagines  
 1940 that the symbol "P" represents the derived unit "m2Pers", then applying the multiplier "k" can  
 1941 be conceptualized simply as "kP".

1942 For example, the SI unit for mass is "kg" and not "g". If the unit symbol is defined as "kg", then  
 1943 the multiplier is applied to "kg" as a whole and does not replace the "k" in front of the "g". In  
 1944 this case, the multiplier of "m" would be used with the unit symbol of "kg" to represent one gram.  
 1945 As a text string, this violates the instructions in IEC 80000-1. However, because the unit symbol  
 1946 in CIM is treated as a derived unit instead of as an SI unit, it makes more sense to conceptualize  
 1947 the "kg" as if it were replaced by one of the proposed replacements for the SI mass symbol. If  
 1948 one imagines that the "kg" were replaced by a symbol "P", then it is easier to conceptualize the  
 1949 multiplier "m" as creating the proper unit "mP", and not the forbidden unit "mkg".

1950 Table 202 shows all literals of UnitMultiplier.

1951 **Table 202 – Literals of EquipmentReliabilityProfile::UnitMultiplier**

literal	value	description
y	-24	Yocto $10^{*-24}$ .
z	-21	Zepto $10^{*-21}$ .
a	-18	Atto $10^{*-18}$ .
f	-15	Femto $10^{*-15}$ .
p	-12	Pico $10^{*-12}$ .
n	-9	Nano $10^{*-9}$ .
micro	-6	Micro $10^{*-6}$ .
m	-3	Milli $10^{*-3}$ .
c	-2	Centi $10^{*-2}$ .
d	-1	Deci $10^{*-1}$ .
none	0	No multiplier or equivalently multiply by 1.
da	1	Deca $10^{*1}$ .
h	2	Hecto $10^{*2}$ .
k	3	Kilo $10^{*3}$ .

literal	value	description
M	6	Mega 10**6.
G	9	Giga 10**9.
T	12	Tera 10**12.
P	15	Peta 10**15.
E	18	Exa 10**18.
Z	21	Zetta 10**21.
Y	24	Yotta 10**24.

1952

1953

**3.122 UnitSymbol enumeration**

1954

1955

1956

1957

1958

1959

1960

1961

1962

1963

1964

1965

1966

1967

1968

1969

1970

1971

1972

1973

1974

1975

1976

1977

The derived units defined for usage in the CIM. In some cases, the derived unit is equal to an SI unit. Whenever possible, the standard derived symbol is used instead of the formula for the derived unit. For example, the unit symbol Farad is defined as "F" instead of "CPerV". In cases where a standard symbol does not exist for a derived unit, the formula for the unit is used as the unit symbol. For example, density does not have a standard symbol and so it is represented as "kgPerm3". With the exception of the "kg", which is an SI unit, the unit symbols do not contain multipliers and therefore represent the base derived unit to which a multiplier can be applied as a whole.

Every unit symbol is treated as an unparseable text as if it were a single-letter symbol. The meaning of each unit symbol is defined by the accompanying descriptive text and not by the text contents of the unit symbol.

To allow the widest possible range of serializations without requiring special character handling, several substitutions are made which deviate from the format described in IEC 80000-1. The division symbol "/" is replaced by the letters "Per". Exponents are written in plain text after the unit as "m3" instead of being formatted as "m" with a superscript of 3 or introducing a symbol as in "m^3". The degree symbol "°" is replaced with the letters "deg". Any clarification of the meaning for a substitution is included in the description for the unit symbol.

Non-SI units are included in list of unit symbols to allow sources of data to be correctly labelled with their non-SI units (for example, a GPS sensor that is reporting numbers that represent feet instead of meters). This allows software to use the unit symbol information correctly convert and scale the raw data of those sources into SI-based units.

The integer values are used for harmonization with IEC 61850.

Table 203 shows all literals of UnitSymbol.

**Table 203 – Literals of EquipmentReliabilityProfile::UnitSymbol**

literal	value	description
none	0	Dimension less quantity, e.g. count, per unit, etc.
m	2	Length in metres.
kg	3	Mass in kilograms. Note: multiplier "k" is included in this unit symbol for compatibility with IEC 61850-7-3.
s	4	Time in seconds.
A	5	Current in amperes.
K	6	Temperature in kelvins.
mol	7	Amount of substance in moles.
cd	8	Luminous intensity in candelas.
deg	9	Plane angle in degrees.
rad	10	Plane angle in radians (m/m).
sr	11	Solid angle in steradians (m2/m2).

literal	value	description
Gy	21	Absorbed dose in grays (J/kg).
Bq	22	Radioactivity in becquerels (1/s).
degC	23	Relative temperature in degrees Celsius. In the SI unit system the symbol is °C. Electric charge is measured in coulomb that has the unit symbol C. To distinguish degree Celsius from coulomb the symbol used in the UML is degC. The reason for not using °C is that the special character ° is difficult to manage in software.
Sv	24	Dose equivalent in sieverts (J/kg).
F	25	Electric capacitance in farads (C/V).
C	26	Electric charge in coulombs (A·s).
S	27	Conductance in siemens.
H	28	Electric inductance in henrys (Wb/A).
V	29	Electric potential in volts (W/A).
ohm	30	Electric resistance in ohms (V/A).
J	31	Energy in joules (N·m = C·V = W·s).
N	32	Force in newtons (kg·m/s <sup>2</sup> ).
Hz	33	Frequency in hertz (1/s).
lx	34	Illuminance in lux (lm/m <sup>2</sup> ).
lm	35	Luminous flux in lumens (cd·sr).
Wb	36	Magnetic flux in webers (V·s).
T	37	Magnetic flux density in teslas (Wb/m <sup>2</sup> ).
W	38	Real power in watts (J/s). Electrical power may have real and reactive components. The real portion of electrical power ( $I^2R$ or $VI\cos(\phi)$ ), is expressed in Watts. See also apparent power and reactive power.
Pa	39	Pressure in pascals (N/m <sup>2</sup> ). Note: the absolute or relative measurement of pressure is implied with this entry. See below for more explicit forms.
m2	41	Area in square metres (m <sup>2</sup> ).
m3	42	Volume in cubic metres (m <sup>3</sup> ).
mPers	43	Velocity in metres per second (m/s).
mPers2	44	Acceleration in metres per second squared (m/s <sup>2</sup> ).
m3Pers	45	Volumetric flow rate in cubic metres per second (m <sup>3</sup> /s).
mPerm3	46	Fuel efficiency in metres per cubic metres (m/m <sup>3</sup> ).
kgm	47	Moment of mass in kilogram metres (kg·m) (first moment of mass). Note: multiplier "k" is included in this unit symbol for compatibility with IEC 61850-7-3.
kgPerm3	48	Density in kilogram/cubic metres (kg/m <sup>3</sup> ). Note: multiplier "k" is included in this unit symbol for compatibility with IEC 61850-7-3.
m2Pers	49	Viscosity in square metres / second (m <sup>2</sup> /s).
WPermK	50	Thermal conductivity in watt/metres kelvin.

literal	value	description
JPerK	51	Heat capacity in joules/kelvin.
ppm	52	Concentration in parts per million.
rotPers	53	Rotations per second (1/s). See also Hz (1/s).
radPers	54	Angular velocity in radians per second (rad/s).
WPerm2	55	Heat flux density, irradiance, watts per square metre.
JPerm2	56	Insulation energy density, joules per square metre or watt second per square metre.
SPerm	57	Conductance per length (F/m).
KPers	58	Temperature change rate in kelvins per second.
PaPers	59	Pressure change rate in pascals per second.
JPerkgK	60	Specific heat capacity, specific entropy, joules per kilogram Kelvin.
VA	61	Apparent power in volt amperes. See also real power and reactive power.
VAr	63	Reactive power in volt amperes reactive. The "reactive" or "imaginary" component of electrical power ( $V I \sin(\phi)$ ). (See also real power and apparent power).  Note: Different meter designs use different methods to arrive at their results. Some meters may compute reactive power as an arithmetic value, while others compute the value vectorially. The data consumer should determine the method in use and the suitability of the measurement for the intended purpose.
cosPhi	65	Power factor, dimensionless.  Note 1: This definition of power factor only holds for balanced systems. See the alternative definition under code 153.  Note 2 : Beware of differing sign conventions in use between the IEC and EEI. It is assumed that the data consumer understands the type of meter in use and the sign convention in use by the utility.
Vs	66	Volt seconds (Ws/A).
V2	67	Volt squared ( $W^2/A^2$ ).
As	68	Ampere seconds (A·s).
A2	69	Amperes squared ( $A^2$ ).
A2s	70	Ampere squared time in square amperes ( $A^2s$ ).
VAh	71	Apparent energy in volt ampere hours.
Wh	72	Real energy in watt hours.
VArh	73	Reactive energy in volt ampere reactive hours.
VPerHz	74	Magnetic flux in volt per hertz.
HzPers	75	Rate of change of frequency in hertz per second.
character	76	Number of characters.
charPers	77	Data rate (baud) in characters per second.
kgm2	78	Moment of mass in kilogram square metres ( $kg \cdot m^2$ ) (Second moment of mass, commonly called the moment of inertia). Note: multiplier "k"

literal	value	description
		is included in this unit symbol for compatibility with IEC 61850-7-3.
dB	79	Sound pressure level in decibels. Note: multiplier "d" is included in this unit symbol for compatibility with IEC 61850-7-3.
WPers	81	Ramp rate in watts per second.
IPers	82	Volumetric flow rate in litres per second.
dBm	83	Power level (logarithmic ratio of signal strength , Bel-mW), normalized to 1mW. Note: multiplier "d" is included in this unit symbol for compatibility with IEC 61850-7-3.
h	84	Time in hours, hour = 60 min = 3600 s.
min	85	Time in minutes, minute = 60 s.
Q	100	Quantity power, Q.
Qh	101	Quantity energy, Qh.
ohmm	102	Resistivity, ohm metres, (rho).
APerm	103	A/m, magnetic field strength, amperes per metre.
V2h	104	Volt-squared hour, volt-squared-hours.
A2h	105	Ampere-squared hour, ampere-squared hour.
Ah	106	Ampere-hours, ampere-hours.
count	111	Amount of substance, Counter value.
ft3	119	Volume, cubic feet.
m3Perh	125	Volumetric flow rate, cubic metres per hour.
gal	128	Volume in gallons, US gallon (1 gal = 231 in3 = 128 fl ounce).
Btu	132	Energy, British Thermal Units.
l	134	Volume in litres, litre = dm3 = m3/1000.
lPerh	137	Volumetric flow rate, litres per hour.
lPerl	143	Concentration, The ratio of the volume of a solute divided by the volume of the solution. Note: Users may need use a prefix such as 'µ' to express a quantity such as 'µL/L'.
gPerg	144	Concentration, The ratio of the mass of a solute divided by the mass of the solution. Note: Users may need use a prefix such as 'µ' to express a quantity such as 'µg/g'.
molPerm3	145	Concentration, The amount of substance concentration, (c), the amount of solvent in moles divided by the volume of solution in m³.
molPermol	146	Concentration, Molar fraction, the ratio of the molar amount of a solute divided by the molar amount of the solution.
molPerkg	147	Concentration, Molality, the amount of solute in moles and the amount of solvent in kilograms.
sPers	149	Time, Ratio of time. Note: Users may need to supply a prefix such as 'µ' to show rates such as 'µs/s'.
HzPerHz	150	Frequency, rate of frequency change. Note: Users may need to supply a prefix such as 'm' to show rates such as 'mHz/Hz'.

literal	value	description
VPerV	151	Voltage, ratio of voltages. Note: Users may need to supply a prefix such as 'm' to show rates such as 'mV/V'.
APerA	152	Current, ratio of amperages. Note: Users may need to supply a prefix such as 'm' to show rates such as 'mA/A'.
VPerVA	153	Power factor, PF, the ratio of the active power to the apparent power. Note: The sign convention used for power factor will differ between IEC meters and EEI (ANSI) meters. It is assumed that the data consumers understand the type of meter being used and agree on the sign convention in use at any given utility.
rev	154	Amount of rotation, revolutions.
kat	158	Catalytic activity, katal = mol / s.
JPerkg	165	Specific energy, Joules / kg.
m3Uncompensated	166	Volume, cubic metres, with the value uncompensated for weather effects.
m3Compensated	167	Volume, cubic metres, with the value compensated for weather effects.
WPerW	168	Signal Strength, ratio of power. Note: Users may need to supply a prefix such as 'm' to show rates such as 'mW/W'.
therm	169	Energy, therms.
onePerm	173	Wavenumber, reciprocal metres, (1/m).
m3Perkg	174	Specific volume, cubic metres per kilogram, v.
Pas	175	Dynamic viscosity, pascal seconds.
Nm	176	Moment of force, newton metres.
NPerm	177	Surface tension, newton per metre.
radPers2	178	Angular acceleration, radians per second squared.
JPerm3	181	Energy density, joules per cubic metre.
VPerm	182	Electric field strength, volts per metre.
CPerm3	183	Electric charge density, coulombs per cubic metre.
CPerm2	184	Surface charge density, coulombs per square metre.
FPerm	185	Permittivity, farads per metre.
HPerm	186	Permeability, henrys per metre.
JPermol	187	Molar energy, joules per mole.
JPermolK	188	Molar entropy, molar heat capacity, joules per mole kelvin.
CPerkg	189	Exposure (x rays), coulombs per kilogram.
GyPers	190	Absorbed dose rate, grays per second.
WPersr	191	Radiant intensity, watts per steradian.
WPerm2sr	192	Radiance, watts per square metre steradian.
katPerm3	193	Catalytic activity concentration, katals per cubic metre.
d	195	Time in days, day = 24 h = 86400 s.



literal	value	description
anglemin	196	Plane angle, minutes.
anglesec	197	Plane angle, seconds.
ha	198	Area, hectares.
tonne	199	Mass in tons, "tonne" or "metric ton" (1000 kg = 1 Mg).
bar	214	Pressure in bars, (1 bar = 100 kPa).
mmHg	215	Pressure, millimetres of mercury (1 mmHg is approximately 133.3 Pa).
M	217	Length, nautical miles (1 M = 1852 m).
kn	219	Speed, knots (1 kn = 1852/3600) m/s.
Mx	276	Magnetic flux, maxwells (1 Mx = 10 <sup>-8</sup> Wb).
G	277	Magnetic flux density, gaussses (1 G = 10 <sup>-4</sup> T).
Oe	278	Magnetic field in oersteds, (1 Oe = (103/4p) A/m).
Vh	280	Volt-hour, Volt hours.
WPerA		Active power per current flow, watts per Ampere.
onePerHz		Reciprocal of frequency (1/Hz).
VPerVAr		Power factor, PF, the ratio of the active power to the apparent power. Note: The sign convention used for power factor will differ between IEC meters and EEI (ANSI) meters. It is assumed that the data consumers understand the type of meter being used and agree on the sign convention in use at any given utility.
ohmPerm	86	Electric resistance per length in ohms per metre ((V/A)/m).
kgPerJ		Weight per energy in kilograms per joule (kg/J). Note: multiplier "k" is included in this unit symbol for compatibility with IEC 61850-7-3.
JPers		Energy rate in joules per second (J/s).

1978

1979 **3.123 ActivePower datatype**1980 Product of RMS value of the voltage and the RMS value of the in-phase component of the  
1981 current.

1982 Table 204 shows all attributes of ActivePower.

1983 **Table 204 – Attributes of EquipmentReliabilityProfile::ActivePower**

name	mult	type	description
multiplier	0..1	<a href="#">UnitMultiplier</a>	
unit	0..1	<a href="#">UnitSymbol</a>	(const=W)
value	0..1	<a href="#">Float</a>	

1984

1985 **3.124 ActivePowerChangeRate datatype**

1986 Rate of change of active power per time.

1987 Table 205 shows all attributes of ActivePowerChangeRate.

1988 **Table 205 – Attributes of EquipmentReliabilityProfile::ActivePowerChangeRate**

name	mult	type	description
multiplier	0..1	<a href="#">UnitMultiplier</a>	
unit	0..1	<a href="#">UnitSymbol</a>	(const=WPers)
value	0..1	<a href="#">Float</a>	

1989

1990 **3.125 AngleDegrees datatype**

1991 Measurement of angle in degrees.

1992 Table 206 shows all attributes of AngleDegrees.

1993 **Table 206 – Attributes of EquipmentReliabilityProfile::AngleDegrees**

name	mult	type	description
value	0..1	<a href="#">Float</a>	
unit	0..1	<a href="#">UnitSymbol</a>	(const=deg)
multiplier	0..1	<a href="#">UnitMultiplier</a>	(const=none)

1994

1995 **3.126 Frequency datatype**

1996 Cycles per second.

1997 Table 207 shows all attributes of Frequency.

1998 **Table 207 – Attributes of EquipmentReliabilityProfile::Frequency**

name	mult	type	description
value	0..1	<a href="#">Float</a>	
unit	0..1	<a href="#">UnitSymbol</a>	(const=Hz)
multiplier	0..1	<a href="#">UnitMultiplier</a>	

1999

2000 **3.127 Impedance datatype**

2001 Ratio of voltage to current.

2002 Table 208 shows all attributes of Impedance.

2003 **Table 208 – Attributes of EquipmentReliabilityProfile::Impedance**

name	mult	type	description
value	0..1	<a href="#">Float</a>	
unit	0..1	<a href="#">UnitSymbol</a>	(const=ohm)
multiplier	0..1	<a href="#">UnitMultiplier</a>	

2004

2005 **3.128 Money datatype**

2006 Amount of money.

2007 Table 209 shows all attributes of Money.

2008 **Table 209 – Attributes of EquipmentReliabilityProfile::Money**

name	mult	type	description
multiplier	0..1	<a href="#">UnitMultiplier</a>	
unit	0..1	<a href="#">Currency</a>	

name	mult	type	description
value	0..1	<a href="#">Decimal</a>	

2009

2010 **3.129 PerCent datatype**

2011 Percentage on a defined base. For example, specify as 100 to indicate at the defined base.

2012 Table 210 shows all attributes of PerCent.

2013 **Table 210 – Attributes of EquipmentReliabilityProfile::PerCent**

name	mult	type	description
value	0..1	<a href="#">Float</a>	Normally 0 to 100 on a defined base.
unit	0..1	<a href="#">UnitSymbol</a>	(const=none)
multiplier	0..1	<a href="#">UnitMultiplier</a>	(const=none)

2014

2015 **3.130 Reactance datatype**

2016 Reactance (imaginary part of impedance), at rated frequency.

2017 Table 211 shows all attributes of Reactance.

2018 **Table 211 – Attributes of EquipmentReliabilityProfile::Reactance**

name	mult	type	description
value	0..1	<a href="#">Float</a>	
unit	0..1	<a href="#">UnitSymbol</a>	(const=ohm)
multiplier	0..1	<a href="#">UnitMultiplier</a>	

2019

2020 **3.131 Seconds datatype**

2021 Time, in seconds.

2022 Table 212 shows all attributes of Seconds.

2023 **Table 212 – Attributes of EquipmentReliabilityProfile::Seconds**

name	mult	type	description
value	0..1	<a href="#">Float</a>	Time, in seconds
unit	0..1	<a href="#">UnitSymbol</a>	(const=s)
multiplier	0..1	<a href="#">UnitMultiplier</a>	(const=none)

2024

2025 **3.132 VoltagePerReactivePower datatype**

2026 Voltage variation with reactive power.

2027 Table 213 shows all attributes of VoltagePerReactivePower.

2028 **Table 213 – Attributes of EquipmentReliabilityProfile::VoltagePerReactivePower**

name	mult	type	description
multiplier	0..1	<a href="#">UnitMultiplier</a>	
unit	0..1	<a href="#">UnitSymbol</a>	(const=VPerVAr)
value	0..1	<a href="#">Float</a>	

2029

2030 **3.133 Boolean primitive**

2031 A type with the value space "true" and "false".

2032 **3.134 Date primitive**

2033 Date as "yyyy-mm-dd", which conforms with ISO 8601. UTC time zone is specified as "yyyy-

2034 mm-ddZ". A local timezone relative UTC is specified as "yyyy-mm-dd(+/-)hh:mm".

2035 **3.135 DateTime primitive**

2036 Date and time as "yyyy-mm-ddThh:mm:ss.sss", which conforms with ISO 8601. UTC time zone

2037 is specified as "yyyy-mm-ddThh:mm:ss.sssZ". A local timezone relative UTC is specified as

2038 "yyyy-mm-ddThh:mm:ss.sss-hh:mm". The second component (shown here as "ss.sss") could

2039 have any number of digits in its fractional part to allow any kind of precision beyond seconds.

2040 **3.136 Decimal primitive**

2041 Decimal is the base-10 notational system for representing real numbers.

2042 **3.137 Duration primitive**

2043 Duration as "PnYnMnDTnHnMnS" which conforms to ISO 8601, where nY expresses a number

2044 of years, nM a number of months, nD a number of days. The letter T separates the date

2045 expression from the time expression and, after it, nH identifies a number of hours, nM a number

2046 of minutes and nS a number of seconds. The number of seconds could be expressed as a

2047 decimal number, but all other numbers are integers.

2048 **3.138 Float primitive**

2049 A floating point number. The range is unspecified and not limited.

2050 **3.139 Integer primitive**

2051 An integer number. The range is unspecified and not limited.

2052 **3.140 String primitive**

2053 A string consisting of a sequence of characters. The character encoding is UTF-8. The string

2054 length is unspecified and unlimited.

2055

2056

## 2057 **Annex A(informative): Sample data**

### 2058 **A.1 General**

2059 This Annex is designed to illustrate the profile by using fragments of sample data. It is not meant  
2060 to be a complete set of examples covering all possibilities of using the profile. Defining a  
2061 complete set of test data is considered a separate activity to be performed for the purpose of  
2062 setting up interoperability testing and conformity related to this profile.

### 2063 **A.2 Sample instance data**

2064 Intentionally left blank. Sample data will be produced at later stage.