

We believe that the Belgian interpretation of Article 15 2 is incorrect. We agree that the text could be interpreted in this way based on the exact wording use, but we believe that it is an incorrect interpretation of what was intended.

The GB interpretation has always been that if a connexion point is exporting power, then the full range of power factors should be available, subject to the maxima of Article 15 1(b). Conversely, if importing real power, the export of VAr will be constrained to zero at low forward power to limit voltage rise on the transmission system.

Adopting the drawing conventions of the Belgian paper, we believe it should look like this:

