

Indicative values for Net Transfer Capacities (NTC) in Europe
Winter 1999-2000, working day, peak hours
(Non binding values)

FROM	TO	MW	VALUE PROVIDED BY
Albania	Greece	200	Greece
Austria	Germany	1850	Germany
	Italy	200	Italy
	Centrel	1300	Austria
	Italy + Slovenia	750	Austria
	Germany + Switzerland	3300	Switzerland and Austria
Belgium	France	1250	Belgium
	Netherlands	1100	Belgium
Belgium + Germany	Netherlands	3200	Netherlands
Bulgaria	Greece	600	Greece
Centrel	Austria	850	Austria
	Germany	2520	Germany
Czech Republic	Germany	2200	Germany
Denmark (West)	Germany	1150	Germany, Elkraft System, ELTRA
Denmark (East)	Germany	540	Elkraft System
Denmark (West)	Sweden	610	SvK, Elkraft System, ELTRA
Denmark (East)	Sweden	1700	SvK, Elkraft System, ELTRA
Denmark (West)	Norway	950	ELTRA Denmark
Finland	Sweden	1350	Fingrid, SvK Sweden
	Norway	100	Fingrid, Statnett
France	Great Britain	2000	France and Great Britain
	Belgium + Germany	3700	France
	Switzerland + Italy	4900	France
	Spain	1100	France and Spain
	Germany	2850	Germany
	Italy	2000	Italy
FYROM	Greece	500	Greece

These indicative values have been computed by extrapolation from standard situations, in order to evaluate the transfer capacity through a single interface at the same time. Thus these figure should be considered separately and are not cumulative. When the evaluation of a transfer limit requires to use a set of assumption which are too far from usual or foreseeable situation (leading to high inaccuracies), the NTC figure has been replaced by « no realistic limit »

FROM	TO	MW	VALUE PROVIDED BY
Greece	Albania	200	Greece
	FYROM	600	Greece
	Bulgaria	700	Greece
Germany	Austria	250	Germany
	Belgium + Netherlands	3710	Germany
	Switzerland	750	Germany
	France	2250	Germany
	Denmark (west)	800	Germany (1200), ELTRA (800)
	Poland	200	Germany
	Sweden	0	390 MW after cable repair / SvK, Germany
	Denmark (east)	550	Elkraft System
	Centrel	420	Germany
	Czech Republic	300	Germany
Great Britain	France	2000	France and Great Britain
Italy	Austria + Slovenia	No realistic limit	
	France + Switzerland	No realistic limit	
Italy + Slovenia	Austria	1050	Austria
Morocco	Spain	300	Spain
Netherlands	Belgium + Germany	3200	Netherlands
Netherlands + Belgium	Germany	2200	Germany
Northern Ireland	Republic of Ireland	Not available	
Norway	Denmark (West)	1000	ELTRA Denmark
	Sweden	2450	SvK Sweden, Statnett Norway
	Finland	70	Fingrid, Statnett
Poland	Germany	800	Germany
Portugal	Spain	650	Portugal and Spain
Republic of Ireland	Northern Ireland	Not available	
Russia	Finland	1000	Fingrid
Slovenia	Italy	300	Italy

These indicative values have been computed by extrapolation from standard situations, in order to evaluate the transfer capacity through a single interface at the same time. Thus these figure should be considered separately and are not cumulative. When the evaluation of a transfer limit requires to use a set of assumption which are too far from usual or foreseeable situation (leading to high inaccuracies), the NTC figure has been replaced by « no realistic limit ».

FROM	TO	MW	VALUE PROVIDED BY
Spain	Portugal	750	Portugal and Spain
	France	1000	France and Spain
	Morroco	350	Spain
Sweden	Germany	0	460MW after cable repair / SvK, Germany
	Denmark (West)	610	SvK Sweden
	Denmark (East)	1300	SvK Sweden
	Finland	1850	Fingrid, SvK Sweden
	Norway	2400	SvK Sweden, Statnett Norway
Switzerland	Austria	No realistic limit	
	Germany	1550	Germany
	France	No realistic limit	
	Italy	2900	Italy
Switzerland + Germany	Austria	2000	Switzerland and Austria

These indicative values have been computed by extrapolation from standard situations, in order to evaluate the transfer capacity through a single interface at the same time. Thus these figure should be considered separately and are not cumulative. When the evaluation of a transfer limit requires to use a set of assumption which are too far from usual or foreseeable situation (leading to high inaccuracies), the NTC figure has been replaced by « no realistic limit ».