

**Indicative values for Net Transfer Capacities (NTC) in Europe
Summer 2001, working day, peak hours
(Non binding values)**

FROM	TO	MW	VALUE PROVIDED BY
Albania	Greece	250	Greece
Albania+Bulgaria+FYROM	Greece	700	Greece
Austria	Germany	1150	Germany
	Italy	200	Italy
	Centrel	1100	Austria
	Italy + Slovenia	650	Austria
	Germany + Switzerland	2900	Austria and Switzerland
	Hungary	700	Austria and Hungary
Belgium	France	1600	Belgium
	Netherlands	2200	Belgium
Belgium + Germany	Netherlands	3600	Netherlands
Bulgaria	Greece	600	Greece
Centrel	Austria	1400	Austria
	Germany	2350	Germany
Denmark (West)	Germany	1200	Denmark and Germany
Denmark (East)	Germany	550	Denmark and Germany
Denmark (West)	Sweden	610	Denmark and Sweden
Denmark (East)	Sweden	1700	Denmark and Sweden
Denmark (West)	Norway	950	Denmark and Norway
Finland	Sweden	1500	Finland and Sweden
	Norway	100	Finland and Norway
France	Great Britain	2000	France and Great Britain
	Belgium	1500	France and Belgium
	Germany	2350	France and Germany
	Belgium + Germany	2600	France
	Italy	1800	Italy
	Switzerland + Italy	4600	France
	Spain	900	Spain
France+Switzerland	Italy	4500	Italy

These indicative values have been computed by extrapolation from standard situations, in order to evaluate the transfer capacity through a single interface at the same time. Thus these figures should be considered separately and are not cumulative. When the evaluation of a transfer limit requires to use a set of assumption which are too far from usual or foreseeable situation (leading to high inaccuracies), the NTC figure has been replaced by « no realistic limit »

FROM	TO	MW	VALUE PROVIDED BY
FYROM	Greece	600	Greece
Greece	Albania	250	Greece
	FYROM	600	Greece
	Bulgaria	600	Greece
	Albania+Bulgaria+FYROM	700	Greece
Germany	Austria	1850	Germany
	Belgium + Netherlands	3800	Germany
	Switzerland	850	Germany
	France	1750	Germany
	Denmark (west)	800	Germany and Denmark
	Sweden	370	Germany and Sweden
	Denmark (east)	550	Germany and Denmark
	Centrel	2000	Germany
Germany and Switzerland	Austria	1800	Austria
Great Britain	France	2000	France and Great Britain
Italy	Austria + Slovenia	<i>no realistic limit</i>	
	France + Switzerland	<i>no realistic limit</i>	
Italy + Slovenia	Austria	750	Austria
Morocco	Spain	300	Spain
Netherlands	Belgium	1700	Belgium
Netherlands	Belgium + Germany	3600	Netherlands
Netherlands + Belgium	Germany	1700	Germany
Northern Ireland	Republic of Ireland	120	Republic of Ireland
Norway	Denmark (West)	950	Norway and Denmark
	Sweden	2800	Norway and Sweden
	Finland	70	Norway and Finland
Portugal	Spain	550	Portugal and Spain
Republic of Ireland	Northern Ireland	50	Republic of Ireland
Russia	Finland	900	Finland
Slovenia	Italy	300	Italy

These indicative values have been computed by extrapolation from standard situations, in order to evaluate the transfer capacity through a single interface at the same time. Thus these figures should be considered separately and are not cumulative. When the evaluation of a transfer limit requires to use a set of assumption which are too far from usual or foreseeable situation (leading to high inaccuracies), the NTC figure has been replaced by « no realistic limit ».

FROM	TO	MW	VALUE PROVIDED BY
Spain	Portugal	600	Spain and Portugal
	France	700	Spain
	Morocco	350	Spain
Sweden	Germany	460	Sweden and Germany
	Denmark (West)	610	Sweden and Denmark
	Denmark (East)	1300	Sweden and Denmark
	Finland	1900	Sweden and Finland
	Norway	2800	Sweden and Norway
Switzerland	Austria	<i>no realistic limit</i>	Switzerland
	Germany	1450	Germany
	France	<i>no realistic limit</i>	Switzerland
	Italy	2700	Italy
Switzerland + Germany	Austria	1800	Switzerland and Austria

These indicative values have been computed by extrapolation from standard situations, in order to evaluate the transfer capacity through a single interface at the same time. Thus these figures should be considered separately and are not cumulative. When the evaluation of a transfer limit requires to use a set of assumption which are too far from usual or foreseeable situation (leading to high inaccuracies), the NTC figure has been replaced by « no realistic limit ».