

**Indicative values for Net Transfer Capacities ( NTC ) in Europe  
Summer 2003, working day, peak hours  
(Non binding values)**

<b>FROM</b>	<b>TO</b>	<b>MW</b>	<b>VALUE PROVIDED BY</b>
Albania	Greece	<b>250</b>	Greece
Albania+Bulgaria+FYROM	Greece	<b>600</b>	Greece
Austria	Germany	<b>1150</b>	Germany
	Italy	<b>200</b>	Italy
	Czech Rep.	<b>390</b>	Czech Rep.
	Italy + Slovenia	<b>650</b>	Austria
	Slovenia	<b>600</b>	Slovenia
	Germany + Switzerland	<b>2900</b>	Austria and Switzerland
	Hungary	<b>300</b>	Hungary
Belgium	France	<b>3100</b>	Belgium
	Netherlands	<b>2200</b>	Belgium
Belgium + Germany	Netherlands	<b>4700</b>	Netherlands
Czech Rep. + Poland	Germany	<b>2350</b>	Germany
Czech Rep.	Germany	<b>2040</b>	Czech Rep.
	Austria	<b>1030</b>	Czech Rep.
	Poland	<b>550</b>	Czech Rep.
	Slovakia	<b>1320</b>	Czech Rep. and Slovakia
Denmark (West)	Germany	<b>1200</b>	Denmark and Germany
Denmark (East)	Germany	<b>550</b>	Denmark and Germany
Denmark (West)	Sweden	<b>610</b>	Denmark and Sweden
Denmark (East)	Sweden	<b>1700</b>	Denmark and Sweden
Denmark (West)	Norway	<b>950</b>	Denmark and Norway
Finland	Sweden	<b>1600</b>	Finland and Sweden
	Norway	<b>100</b>	Finland and Norway
France	United Kingdom	<b>2000</b>	France and United Kingdom
	Belgium	<b>1500</b>	Belgium
	Germany	<b>2350</b>	Germany
	Belgium + Germany	<b>3600</b>	France
	Italy	<b>2400</b>	Italy
	Switzerland + Italy	<b>5000</b>	France
	Spain	<b>1400//1200</b>	France//Spain
France+Switzerland	Italy	<b>4900</b>	France, Italy and Switzerland

These indicative values have been computed by extrapolation from standard situations, in order to evaluate the transfer capacity through a single interface at the same time. Thus these figures should be considered separately and are not cumulative. When the evaluation of a transfer limit requires to use a set of assumption which are too far from usual or foreseeable situation (leading to high inaccuracies), the NTC figure has been replaced by « no realistic limit ».

FROM	TO	MW	VALUE PROVIDED BY
Greece	Albania	250	Greece
	JIEL/EKC block*	600	Greece
	Bulgaria	600	Greece
	Italy	330	Italy and Greece
	Albania+Bulgaria+JIEL/EKC block*	600	Greece
Germany	Austria	1850	Germany
	Belgium + Netherlands	3800	Germany
	Czech Rep. + Poland	2000	Germany and Poland
	Czech Rep.	390	Czech. Rep.
	Denmark (east)	550	Germany and Denmark
	Denmark (west)	800	Germany and Denmark
	France	1750	Germany
	Poland	1300	Poland
	Sweden	370	Germany and Sweden
	Switzerland	4000	Germany and Switzerland
Germany and Switzerland	Austria	1800	Austria and Switzerland
Hungary	Austria	700	Hungary
	Slovakia	650	Slovakia
Italy	Austria + Slovenia	<i>no realistic limit</i>	Italy
	France + Switzerland	<i>no realistic limit</i>	
	Greece	500	
Italy + Slovenia	Austria	<i>no realistic limit</i>	
Morocco	Spain	400	Spain
Netherlands	Belgium	1700	Belgium
	Belgium + Germany	4700	Netherlands
	Germany	1700	Germany
Norway	Denmark (West)	1000	Norway and Denmark
	Sweden	3350	Norway and Sweden
	Finland	70	Norway and Finland
Poland	Czech Rep.	1645	Czech Rep. and Poland
	Germany	1800	Poland
	Slovakia	500	Poland
	Sweden	200	Poland
Portugal	Spain	550	Portugal and Spain
Republic of Ireland	United Kingdom	<i>values under review</i>	Republic of Ireland
Russia	Finland	1300	Finland

These indicative values have been computed by extrapolation from standard situations, in order to evaluate the transfer capacity through a single interface at the same time. Thus these figures should be considered separately and are not cumulative. When the evaluation of a transfer limit requires to use a set of assumption which are too far from usual or foreseeable situation (leading to high inaccuracies), the NTC figure has been replaced by « no realistic limit ».

FROM	TO	MW	VALUE PROVIDED BY
Slovakia	Czech Rep.	<b>750</b>	Slovakia and Czech Rep.
	Hungary	<b>950</b>	Slovakia
	Poland	<b>500</b>	Slovakia and Poland
Slovenia	Italy	<b>300</b>	Slovenia and Italy
	Austria	<b>600</b>	Slovenia
	Croatia	<i>no realistic limit</i>	
Spain	Portugal	<b>600</b>	Spain and Portugal
	France	<b>700</b>	Spain
	Morocco	<b>400</b>	Spain
Sweden	Germany	<b>460</b>	Sweden and Germany
	Denmark (West)	<b>580</b>	Sweden and Denmark
	Denmark (East)	<b>1300</b>	Sweden and Denmark
	Finland	<b>1900</b>	Sweden and Finland
	Norway	<b>2850</b>	Sweden and Norway
	Poland	<b>600</b>	Sweden and Poland
Switzerland	Austria	<i>no realistic limit</i>	
	Germany	<b>2950</b>	Switzerland and Germany
	France	<i>no realistic limit</i>	
	Italy	<b>2500</b>	Switzerland and Italy
United Kingdom	France	<b>2000</b>	United Kingdom and France
	Republic of Ireland	<i>values under review</i>	Republic of Ireland

\* JIEL block -Serbia and Montenegro, FYROM & part of B&H (ERS).

These indicative values have been computed by extrapolation from standard situations, in order to evaluate the transfer capacity through a single interface at the same time. Thus these figures should be considered separately and are not cumulative. When the evaluation of a transfer limit requires to use a set of assumption which are too far from usual or foreseeable situation (leading to high inaccuracies), the NTC figure has been replaced by « no realistic limit ».