

**Indicative values for Net Transfer Capacities (NTC) in Europe
winter 2000-2001, working day, peak hours
(Non binding values)**

FROM	TO	MW	VALUE PROVIDED BY
Albania	Greece	200	Greece
Austria	Germany	1150	Germany
	Italy	200	Italy
	Centrel	2000	Austria and Centrel
	Italy + Slovenia	750	Austria
	Germany + Switzerland	3000	Austria and Germany
Austria + Slovenia	Italy	500	Italy
Belgium	France	2500	Belgium
	Netherlands	1400	Belgium
Belgium + Germany	Netherlands	3600	Netherlands
Bulgaria	Greece	600	Greece
Centrel	Austria	1400	Austria and Centrel
	Germany	2250	Germany and Centrel
	Sweden	600	Sweden
Denmark (West)	Germany	1200	Germany and Denmark
Denmark (East)	Germany	550	Germany and Denmark
Denmark (West)	Sweden	610	Denmark and Sweden
Denmark (East)	Sweden	1700	Denmark and Sweden
Denmark (West)	Norway	950	Denmark and Norway
Finland	Sweden	1350	Finland and Sweden
	Norway	100	Finland and Norway
France	Great Britain	2000	France and Great Britain
	Belgium	1800	Belgium
	Belgium + Germany	3750	France
	Switzerland + Italy	4950	France
	Spain	1100	France and Spain
	Germany	2850	Germany
	Italy	2000	Italy
France + Switzerland	Italy	4900	Italy

These indicative values have been computed by extrapolation from standard situations, in order to evaluate the transfer capacity through a single interface at the same time. Thus these figure should be considered separately and are not cumulative. When the evaluation of a transfer limit requires to use a set of assumption which are too far from usual or foreseeable situation (leading to high inaccuracies), the NTC figure has been replaced by « no realistic limit ».

FROM	TO	MW	
FYROM	Greece	500	Greece
Greece	Albania	200	Greece
	FYROM	600	Greece
	Bulgaria	700	Greece
Germany	Austria	1650	Germany
	Netherlands	2800	Germany and Netherlands
	Switzerland	2000	Germany and Switzerland
	France	2250	Germany
	Denmark (west)	800	Denmark
	Sweden	370	Germany and Sweden
	Denmark (east)	550	Germany and Denmark
	Centrel	1200	Germany and Centrel
Great Britain	France	2000	France and Great Britain
Italy	Austria + Slovenia	No realistic limit	
	France + Switzerland	No realistic limit	
Italy + Slovenia	Austria	1050	Austria
Morroco	Spain	300	Spain
Netherlands	Belgium	1700	Belgium
Netherlands	Belgium + Germany	3600	Netherlands
Netherlands	Germany	1350	Germany and Netherlands
Northern Ireland	Republic of Ireland	100	Republic of Ireland
Norway	Denmark (West)	1000	Norway and Denmark
	Sweden	2450	Norway and Sweden
	Finland	70	Norway and Finland
Portugal	Spain	725	Spain and Portugal

These indicative values have been computed by extrapolation from standard situations, in order to evaluate the transfer capacity through a single interface at the same time. Thus these figure should be considered separately and are not cumulative. When the evaluation of a transfer limit requires to use a set of assumption which are too far from usual or foreseeable situation (leading to high inaccuracies), the NTC figure has been replaced by « no realistic limit ».

FROM	TO	MW	
Republic of Ireland	Northern Ireland	30	Republic of Ireland
Russia	Finland	1000	Finland
Slovenia	Italy	300	Italy
Spain	Portugal	850	Spain and Portugal
	France	1000	France and Spain
	Morocco	350	Spain
Sweden	Germany	460	Germany and Sweden
	Denmark (West)	400	Sweden and Denmark
	Denmark (East)	1300	Sweden and Denmark
	Finland	1850	Sweden and Finland
	Norway	2400	Sweden and Norway
	Centrel	600	Sweden
Switzerland	Austria	No realistic limit	
	Germany	No realistic limit	
	France	No realistic limit	
	Italy	2900	Italy
Switzerland + Germany	Austria	2000	Austria and Germany

These indicative values have been computed by extrapolation from standard situations, in order to evaluate the transfer capacity through a single interface at the same time. Thus these figure should be considered separately and are not cumulative. When the evaluation of a transfer limit requires to use a set of assumption which are too far from usual or foreseeable situation (leading to high inaccuracies), the NTC figure has been replaced by « no realistic limit ».