












SINGLE TEST RECORD FORM

Test No: 13_1	Profile edition No: 2	Tool: ODMS	Score: 4
Test files:			
Import		Export	
ENTISO- E_Boundary_Set_28_June_2011_2ndEdition _EU.zip ENTISOE_16_BE.zip ENTISOE_16_NL.zip		ENTISOE_16_BE_OD_Diff_15J12h.xml ENTISOE_16_NL_OD_Diff_15J12h.xml ENTISOE_16_OD_15J12h_BE_TP.xml ENTISOE_16_OD_15J12h_NL_TP.xml ENTISOE_16_OD_15J12h_SV.xml	
Comments/Results/Issues:			
<p>Imported the boundary zip file, the BE MAS zip file and the NL MAS zip file. We calculated the load flow after the import. See "ODMS_S1_Loadflow_before.pdf" and substation PP_Brussels, "ODMS_S1_Loadflow_before_PP_Brussels.tif" and changes to "ODMS_S1_Loadflow_before_Amsterdam.tif"</p> <p>Made the following changes using Project module:</p> <ul style="list-style-type: none"> - Add new conforming load L2_conf P 5 MW and Q 5 Mvar in substation PP_Brussels on bus 51 - Add new conforming load L3_conf P 4 MW and Q 6 Mvar in substation PP_Amsterdam on bus BB <p>The changes were exported as two difference file, "ENTISOE_16_BE_OD_Diff_15J12h.xml" and "ENTISOE_16_NL_OD_Diff_15J12h.xml". Committed the changes to the model and run load flow. The result is shown in the file "ODMS_Amsterdam_AfterChanges.tif" and "ODMS_Brussels_AfterChanges.tif" and the total is shown in "ODMS_S2_Table_Loadflow_after.png".</p> <p>Exported the full TP for both MAS and a SV for the total. The file was exported separately as: "ENTISOE_16_OD_15J12h_BE_TP.xml", "ENTISOE_16_OD_15J12h_NL_TP.xml" and "ENTISOE_16_OD_15J12h_SV.xml" The difference file and the full TPx2 and full solution file was zipped to a common file, "ENTISOE_16_OD_15J12h_all.zip"</p> <p>The TP and SV file were validated by CIMdesk without any errors. See file starting with "CIMdesk". The validation of the difference files failed on the CIMdesk validation. It states that the file is a full model rather than a DifferenceModel. This is a profile issue. The export of the difference file is valid.</p>			
Supplementary files:			



	CIMdesk_OD_15J12h_BE_TP.PNG	15.07.2011 12:20
	CIMdesk_OD_15J12h_NL_TP.PNG	15.07.2011 12:21
	CIMdesk_OD_15J12h_SV.PNG	15.07.2011 12:22
	ODMS_Amsterdam_AfterChanges.tif	15.07.2011 12:00
	ODMS_Brussels_AfterChanges.tif	15.07.2011 12:01
	ODMS_Loadflow_Table_Solution1.PNG	15.07.2011 11:23
	ODMS_Loadflow_Table_Solution2.PNG	15.07.2011 12:01
	ODMS_S1_Loadflow_before.pdf	15.07.2011 11:25
	ODMS_S1_Loadflow_before_PP_Brussels.tif	15.07.2011 11:16

Date	Vendor		Test witness	
2011-07-15	Name	Signature	Name	Signature
	Michael Ford		Svein Olsen	

SINGLE TEST RECORD FORM



Test No: 14_1	Profile edition No: 2	Tool: ODMS	Score: 4																							
Test files:																										
Import		Export																								
ENTISO- E_Boundary_Set_28_June_2011_2ndEdition _EU.zip ENTISOE_16_BE.zip ENTISOE_16_NL.zip TNA__ENTSOE_16_BE_EQ_DIFF.xml TNA__ENTSOE_16_NL_EQ_DIFF.xml TNA__ENTSOE_16_BE_TP.xml TNA__ENTSOE_16_NL_TP.xml TNA_Test11.1_2sc_SV.xml																										
Comments/Results/Issues:																										
<p>Imported the boundary zip file, the BE MAS zip file and the NL MAS zip file. We calculated the load flow after the import. See "ODMS_S1_Loadflow_before.pdf".</p> <p>We imported the differential files from DMSGROUP & EKC (TNA) without any error message. We then imported the two TP files and then the SV file without any error message.</p> <p>From the difference file we could see that the following changes had been done:</p> <ul style="list-style-type: none"> - BE MAS had Load response for D1 was changed <ul style="list-style-type: none"> o pConstantCurrent 0 -> 0.2 o pConstantImpedance 0 -> 0.3 o pConstantPower 1 -> 0.5 - NL MAS had the TapChanger on the PhaseShifter T1 <ul style="list-style-type: none"> o name from empty to SymmNL o neutral step from 31 to 35 <p>These changes were picked up by ODMS. See and "ODMS_BE_LoadResponse_AfterImport.PNG" "ODMS_NL_PhaseShifterTap_AfterImport.PNG"</p> <p>The load flow was then calculated and the result was exported in the file "ODMS_Powerflow_AfterImport_15J12h.pdf"</p> <p>The following node were checked:</p> <table border="1"> <thead> <tr> <th></th> <th></th> <th>TNA</th> <th>ODMS</th> <th>delta</th> </tr> </thead> <tbody> <tr> <td rowspan="2">S4</td> <td>U [kV]</td> <td>22.0</td> <td>21.987</td> <td>0.06%</td> </tr> <tr> <td>angle [°]</td> <td>-11.8</td> <td>-11.695</td> <td>0.90%</td> </tr> <tr> <td rowspan="2">F5</td> <td>P [MW]</td> <td>90.0</td> <td>90.000</td> <td>0.00%</td> </tr> <tr> <td>Q [Mvar]</td> <td>84.1</td> <td>84.833</td> <td>0.86%</td> </tr> </tbody> </table> <p>The result from TNA is stored in the file "Test11.1_d_2sc_TN_13J16h30.jpg".</p>						TNA	ODMS	delta	S4	U [kV]	22.0	21.987	0.06%	angle [°]	-11.8	-11.695	0.90%	F5	P [MW]	90.0	90.000	0.00%	Q [Mvar]	84.1	84.833	0.86%
		TNA	ODMS	delta																						
S4	U [kV]	22.0	21.987	0.06%																						
	angle [°]	-11.8	-11.695	0.90%																						
F5	P [MW]	90.0	90.000	0.00%																						
	Q [Mvar]	84.1	84.833	0.86%																						






The results are acceptable.

Supplementary files:







ODMS_BE_LoadResponse_AfterImport.PNG
ODMS_NL_PhaseShifterTap_AfterImport.PNG
ODMS_Powerflow_AfterImport_15J12h.pdf
Test11.1_d_2sc_TN_13J16h30.jpg

Date	Vendor		Test witness	
	Name	Signature	Name	Signature
2011-07-15	Michael Ford		Svein Olsen	




SINGLE TEST RECORD FORM

Test No: 15_1	Profile edition No: 2	Tool: ODMS/PSSE	Score: 3
Test files:			
Import		Export	
ENTSO- E_Boundary_Set_28_June_2011_2ndEdition_EU.zip ENTSOE_16_BE.zip ENTSOE_16_NL.zip			
Comments/Results/Issues:			
<p>Imported the boundary zip file and then the BE MAS and NL MAS zip file. Built Case and Exported PSSE v32 raw and dyr files.</p> <p>Discovered problem setting duplicate unit identifiers used in internal PTI Software. Repaired and proceeded with test.</p> <p>Compared data between original xml data in the ENTSOE_16_BE_DY file against the PSSE dyr data for unit G1 at Brussels.</p> <p>Loaded network and dynamics data into PSSE, solved powerflow and Initialized successfully.</p>			
Supplementary files:			
 <p>C:\AAA Dynamics Test\Test15\Test 15</p>			
Date	Vendor	Signature	Test witness
2011-07-11	Name	Signature	Name
	Chuck DuBose		Chavdar Ivanov
			



SINGLE TEST RECORD FORM

Test No: 16_1	Profile edition No: 2	Tool: ODMS	Score: 4
Test files:			
Import		Export	
ENTISO- E_Boundary_Set_28_June_2011_2ndEdition_EU.zip ENTISOE_16_BE.zip ENTISOE_16_NL.zip		ENTISOE_2_BE_OD_Dynamics.zip ENTISOE_2_NL_OD_Dynamics.zip	
Comments/Results/Issues:			
<p>Imported the boundary zip file and then the BE MAS and NL MAS zip file.</p> <p>Exported BE MAS and NL MAS.</p> <p>Noted that the model version incremented and uri is different. Attached jpeg</p> <p>Validated against CIMdesk. Attached jpeg. Produced one unexplainable error stating that the vmin is greater than or equal to upper limit for the ExcAC1A standard model. Compared the only ExcAC1A model in the data located in the NL MAS. vmin was 0 and vmax was 10. Also checked the rest of the data in the ExcAC1A model. Attached jpeg.</p> <p>Compared the large GovSteam model in the BE MAS. Attached jpeg</p>			
Supplementary files:			
			
C:\AAA Dynamics Test\Test16\Input vs	C:\AAA Dynamics Test\Test16\CIMdesk	C:\AAA Dynamics Test\Test16\ExcAC1A/	C:\AAA Dynamics Test\Test16\Belgium
Date	Vendor		Test witness
2011-07-11	Name	Signature	Name
	Chuck DuBose		Chavdar Ivanov
			


SINGLE TEST RECORD FORM

Test No: 17_1	Profile edition No: 2	Tool: ODMS/PSSE	Score: 4
Test files:			
Import		Export	
ENTSO- E_Boundary_Set_28_June_2011_2ndEdition_EU.zip ENTSOE_16_BE.zip ENTSOE_16_NL.zip			
Comments/Results/Issues:			
<p>Imported the boundary zip file and then the BE MAS and NL MAS zip file. Built Case and Exported PSSE v32 raw and dyr files.</p> <p>Discovered problem setting duplicate unit identifiers used in internal PTI Software. Repaired and proceeded with test.</p> <p>Loaded network and dynamics data into PSSE, solved powerflow and Initialized successfully. Ran dynamics simulation and compared results against DigSILENT simulation. Attached pictures of solution criteria, initialization and simulation plot.</p>			
Supplementary files:			
<div style="display: flex; justify-content: space-around; align-items: center;"> <div style="text-align: center;">  C:\AAA Dynamics Test\Test17\PSSE Sol </div> <div style="text-align: center;">  C:\AAA Dynamics Test\Test17\Dynamic </div> <div style="text-align: center;">  C:\AAA Dynamics Test\Test17\G1 Resp </div> </div>			
Date	Vendor	Signature	Test witness
2011-07-11	Name	Name	Signature
	Chuck DuBose	Chavdar Ivanov	



SINGLE TEST RECORD FORM

Test No: 27_1	Profile edition No: 2	Tool: ODMS	Score: 4				
Test files:							
Import		Export					
ge1_operational.zip (ge1_EQ.xml) (ge1_TP.xml) (ge1_SV.xml)		GE_Operation_Planning_OD_15J09h.zip					
Comments/Results/Issues:							
<p>ODMS imported the GE Operational (CPSM) model without any errors. The screenshot "OMDS_InstanceData.png" that shows the data imported. The file "ODMS_Loadflow_Summary_Operation.png" shows the high-level load flow result.</p> <p>We check that LOAD_564 is imported.</p> <pre><cim:ConformLoad rdf:ID="xaLoad564"><cim:IdentifiedObject.name>LOAD_564</cim:IdentifiedObject.name>< cim:EnergyConsumer.pfixed>10.7</cim:EnergyConsumer.pfixed><cim:EnergyConsumer.pfix edPct>4.867841</cim:EnergyConsumer.pfixedPct><cim:EnergyConsumer.qfixed>- 2.2</cim:EnergyConsumer.qfixed><cim:EnergyConsumer.qfixedPct>- 1.225081</cim:EnergyConsumer.qfixedPct><cim:Equipment.EquipmentContainer rdf:resource="#xaBus482"/><cim:EnergyConsumer.LoadResponse rdf:resource="#xaZipLoad564"/><cim:ConformLoad.LoadGroup rdf:resource="#xaLoadGroup7"/></cim:ConformLoad></pre> <p>The values in the XML file were the same as the data shown in the screen.</p> <p>The operational (CPSM) was exported as planning model (ENTSO-E ed2). The export file was validated with CIMdesk. The validation for the EQ original and the exported file give the same result. There is an additional warning in the exported TP:</p> <table border="1"> <tr> <td>Warning</td> <td>Terminal</td> <td>974/974</td> <td>Property ClassLink is undeclared for Class Terminal in the profile.</td> </tr> </table> <p>This warning is OK. The SV validation was OK.</p>				Warning	Terminal	974/974	Property ClassLink is undeclared for Class Terminal in the profile.
Warning	Terminal	974/974	Property ClassLink is undeclared for Class Terminal in the profile.				
Supplementary files:							
CIMdesk_OD_15J09h_SV.PNG CIMdesk_OD_15J09h_TP.PNG CIMdesk_OD_15J09h_EQ.PNG ODMS_InstanceData.PNG CIMdesk_ge1_SV.PNG – the validation done on the original GE file CIMdesk_ge1_TP.PNG – the validation done on the original GE file CIMdesk_ge1_EQ.PNG – the validation done on the original GE file ODMS_Loadflow_Summary_Operation.PNG							
Date	Vendor	Test witness					
2011-07-15	Name	Signature	Name				
	Michael Ford		Svein Olsen				
			Signature				
							

SINGLE TEST RECORD FORM

Test No: 28_1	Profile edition No: 2	Tool: ODMS	Score: 4
Test files:			
Import		Export	
GE_Operation_Planning_OD_15J08h.zip			
Comments/Results/Issues:			
<p>ODMS imported the file that was exported from Test 27 without any errors. The result of the load flow calculation was stored in the file "ODMS_Loadflow.png". It shows the high-level load flow result.</p> <p>The same file was imported by PowerFactory and the result was compared for the overall flow. See result from PowerFactory in the file: "PF_Idfresults.png"</p> <p>The validation was OK.</p>			
Supplementary files:			
ODMS_Loadflow_Summary_Operation.PNG ODMS_Loadflow_Summary_Planning.PNG PF_Idfresults.png			
Date	Vendor	Test witness	
2011-07-15	Name	Name	Signature
	Michael Ford	Svein Olsen	


SINGLE TEST RECORD FORM

Test No: 29_1	Profile edition No: 2	Tool: ODMS	Score: 4																																															
Test files:																																																		
Import		Export																																																
ge1_operational.zip (ge1_EQ.xml) (ge1_TP.xml) (ge1_SV.xml)																																																		
Comments/Results/Issues:																																																		
ODMS imported the GE Operational (CPSM) model without any errors. The screenshot "OMDS_InstanceData.png" that shows the data imported. The file "ODMS_Loadflow_Summary_Operation.png" shows the high-level load flow result.																																																		
	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th colspan="2">ODMS</th> <th colspan="2">GE</th> <th colspan="2">delta</th> </tr> <tr> <th>MW</th> <th>Mvar</th> <th>MW</th> <th>Mvar</th> <th>%</th> <th>%</th> </tr> </thead> <tbody> <tr> <td>Generation</td> <td>2170,7</td> <td>-709,5</td> <td>2166</td> <td>-901</td> <td>0,22 %</td> <td>-21,25 %</td> </tr> <tr> <td>Load</td> <td>2094,5</td> <td>654,6</td> <td>2096</td> <td>816</td> <td>-0,07 %</td> <td>-19,78 %</td> </tr> <tr> <td>Bus Shunt</td> <td>0</td> <td>-265,7</td> <td>0</td> <td>-327</td> <td></td> <td>-18,75 %</td> </tr> <tr> <td>Line Charging</td> <td></td> <td>2513,9</td> <td></td> <td>2698</td> <td></td> <td>-6,82 %</td> </tr> <tr> <td>Loss</td> <td>75,3</td> <td>723,6</td> <td>71</td> <td>-2046</td> <td>6,06 %</td> <td>-135,37 %</td> </tr> </tbody> </table>		ODMS		GE		delta		MW	Mvar	MW	Mvar	%	%	Generation	2170,7	-709,5	2166	-901	0,22 %	-21,25 %	Load	2094,5	654,6	2096	816	-0,07 %	-19,78 %	Bus Shunt	0	-265,7	0	-327		-18,75 %	Line Charging		2513,9		2698		-6,82 %	Loss	75,3	723,6	71	-2046	6,06 %	-135,37 %	
ODMS		GE		delta																																														
MW	Mvar	MW	Mvar	%	%																																													
Generation	2170,7	-709,5	2166	-901	0,22 %	-21,25 %																																												
Load	2094,5	654,6	2096	816	-0,07 %	-19,78 %																																												
Bus Shunt	0	-265,7	0	-327		-18,75 %																																												
Line Charging		2513,9		2698		-6,82 %																																												
Loss	75,3	723,6	71	-2046	6,06 %	-135,37 %																																												
The MW looks very good. Even if the Mvar has a big difference the result is accepted.																																																		
Supplementary files:																																																		
ODMS_Loadflow_Summary_Operation.PNG eg_ge1_resolution_screen.doc – the solution from GE Summary.xlsx – shows the differences																																																		
Date	Vendor		Test witness																																															
2011-07-15	Name	Signature	Name	Signature																																														
	Michael Ford		Svein Olsen																																															



SINGLE TEST RECORD FORM

Test No: 30_1	Profile edition No: 2	Tool: ODMS	Score: 4
Test files:			
Import		Export	
ENTSO- E_Boundary_Set_28_June_2011_2ndEdition_EU.zip ENTSOE_16_BE.zip ENTSOE_16_NL.zip ENTSOE_16_BE_FullExport_OD_15J11h.zip		ENTSOE_16_OD_15J16h.zip	
Comments/Results/Issues:			
<p>Imported the boundary zip file, the BE MAS zip file and the NL MAS zip file. We calculated the load flow after the import. See "ODMS_S1_Loadflow_before.pdf" and substation PP_Brussels, "ODMS_S1_Loadflow_before_PP_Brussels.tif"</p> <p>We imported the full MAS model that was exported from Test 12 where we have imported the changes in a differential file, and then exported the full MAS in the file "ENTSOE_16_BE_FullExport_OD_15J11h.zip". We expect the following changes to occur in the new full model after we have imported</p> <ul style="list-style-type: none"> - Add a new load D2_conf (confirming load) with 50 MW and 45 Mvar - Change the existing load D1 name to D1_nonconf and P from 100 MW to 50 MW and Q from 90 Mvar to 45 Mvar <p>We verified that the changes were imported. We calculated the new load flow result and stored it in "OMD_Loadflow_table.lng"</p> <p>A full model including the boundary was exported into "ENTSOE_16_OD_15J16h.zip"</p> <p>It was unclear how the test should be completed, and at the time of execution there were no other vendor that was ready to test the import and compare result.</p>			
Supplementary files:			
ODMS_S1_Loadflow_before.pdf ODMS_S1_Loadflow_before_PP_Brussels.tif ODMS_S2_Loadflow_after.png ODMS_S2_Loadflow_after_PP_Brussels.tif			
Date	Vendor	Signature	Test witness
2011-07-15	Name	Name	Signature
	Michael Ford	Svein Olsen	



SINGLE TEST RECORD FORM

Test No: 31_1	Profile edition No: 2	Tool: ODMS	Score: 4
Test files:			
Import		Export	
ENTSO- E_Boundary_Set_28_June_2011_2ndEdition_EU.zip ENTSOE_16_BE_MOD.zip			
Comments/Results/Issues:			
<p>The test was done on the BE MAS. The EQ file header was modified with the following changes:</p> <p>The incorrect header referents was added to the file: <code><md:Model.DependentOn rdf:resource="urn:uuid:2399cbd0-9a39-11e0-9999-0800200c9a66" /></code></p> <p>The model profile reference was changed from: <code><md:Model.profile>http://iec.ch/TC57/61970-452/Equipment/2</md:Model.profile></code> To <code><md:Model.profile>http://iec.ch/TC57/61970-452/Equipment/3</md:Model.profile></code></p> <p>When importing the file the import failed. The following error messages is displayed in the screen:</p>			
			
<p>We pressed Yes and we got an error message that the import failed. The following line was written to the log file:</p> <p>"</p> <p>File "ENTSOE_16_BE_EQ.xml" depends on "urn:uuid:2399cbd0-9a39-11e0-9999-0800200c9a66", but that ID is not found in the files or in the database!</p> <p>"</p> <p>This is acceptable error messaged for this profile. However, moving to next profile the error message should point out which profile it will import it to.</p>			
Supplementary files:			
ODMS_ProfileHeaderError.PNG			


MTO

xmlImport_ENTSOE_16_BE_MOD.log				
Date	Vendor		Test witness	
2011-07-14	Name	Signature	Name	Signature
	Michael Ford		Svein Olsen	

SINGLE TEST RECORD FORM

Test No: 32_1	Profile edition No: 2	Tool: ODMS	Score: 4
Test files:			
Import		Export	
ENTSO- E_Boundary_Set_28_June_2011_2ndEdition_EU.zip ENTISOE_16_NL.zip ENTISOE_16_BE.zip ENTISO-E_16_PF_12J17h_NL.zip		entso-e_16_od_15j14h_nl.zip	
Comments/Results/Issues:			
<p>Imported the boundary zip file, the BE MAS zip file and the NL MAS zip file.</p> <p>The we imported diagram file created by DIgSILENT, "ENTSO-E_16_PF_12J17h_NL.zip"</p> <p>The diagram based on this import is stored in the file "ODMS_imported_entso-e_16_pf_15j14h_nl.JPG". This is verified by DIgSILENT to be OK.</p> <p>We then make changes represented in the file "ODMS_exported_entso-e_16_od_15j14h_nl.JPG".</p> <p>This was exported as an xml in the file "entso-e_16_od_15j14h_nl.zip".</p> <p>This file was imported by DIgSILENT and the result is stored in the file "PowerFactoryImport.wmf".</p> <p>The diagrams are not identical, but the changes are reflected in the screenshot from PowerFactory. It looks like the coordination system is different in the two systems.</p>			
Supplementary files:			
ODMS_exported_entso-e_16_od_15j14h_nl.JPG – diagram showing the export from ODMS ODMS_imported_ENTISOE_16_BL_DI_CP_15J11h.JPG – result from importing Open Grid Systems changed diagram ODMS_imported_ENTISOE_16_NL_TN_15J11h50_DI.JPG – result from importing DMSGROUP changed diagram ODMS_imported_entso-e_16_pf_15j14h_nl.JPG – result from importing PowerFactory changed diagram PowerFactoryImport.wmf – result from PowerFactory after importing the changed diagram from ODMS			
Date	Vendor		Test witness
2011-07-14	Name	Signature	Name
	Michael Ford		Signature
			Svein Olsen 

SINGLE TEST RECORD FORM

Test No: 33_1	Profile edition No: 2	Tool: ODMS	Score: 4
Test files:			
Import		Export	
ENTSO- E_Boundary_Set_28_June_2011_2ndEdition_EU.zip ENTISOE_16_BE.zip		ENTISOE_16_BE_OD_GE_14J13h.zip	
Comments/Results/Issues:			
<p>The test was done on the BE MAS. Imported the boundary zip file and then the BE MAS zip file.</p> <p>The "ENTISOE_16_BE.zip" includes the "ENTISOE_16_BE_GE.xml" file that described the geographical data.</p> <p>SubStation: PP_Brussels (c1d5bfbf8f8011e08e4d00247eb1f55e): xPosition : 4.3450927734375 and yPosition : 50.92900848388672</p> <p>The file "ODMS_PP_Brussels_GE_Before.PNG" show this result.</p> <p>This position was changed to: xPosition = 4.35 and yPosition = 50.93 The file "ODMS_PP_Brussels_GE_After.PNG" shows these changes.</p> <p>The file was exported and checked to have the same numbers.</p> <p>The file was imported by Open Grid Systems with the correct result. See file "GeoLocationSiemensImport.png"</p>			
Supplementary files:			
GeoLocationSiemensImport.png ODMS_PP_Brussels_GE_After.PNG ODMS_PP_Brussels_GE_AfterCPIImport.PNG ODMS_PP_Brussels_GE_Before.PNG			
Date	Vendor	Signature	Test witness
2011-07-14	Name	Signature	Name
	Michael Ford		Svein Olsen
			